



Progress Energy

Docket No. 50-302
Operating License No. DPR-72

Ref: ITS 5.7.1.2

January 13, 2004
3F0104-01

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

Subject: Crystal River Unit 3 – December 2003 Monthly Operating Report

Dear Sir:

Progress Energy Florida, Inc. hereby submits the Crystal River Unit 3 (CR-3) December 2003 Monthly Operating Report in accordance with CR-3 Improved Technical Specification 5.7.1.2.

If you have any questions regarding this submittal, please contact Mr. Sid Powell, Supervisor, Licensing and Regulatory Programs at (352) 563-4883.

Sincerely,

J. A. Franke
Plant General Manager

JAF/ff

Attachment

xc: Regional Administrator, Region II
Senior Resident Inspector
NRR Project Manager

Progress Energy Florida, Inc.
Crystal River Nuclear Plant
15760 W. Powerline Street
Crystal River, FL 34428

JEZ4

APPENDIX A OPERATING DATA REPORT

DOCKET NO. 50-302
UNIT NAME FLCRP-3
DATE January 2, 2004
COMPLETED BY J. E. Lane 
TELEPHONE (352) 795-6486 x3698

REPORTING PERIOD (Month/Year):

December 2003

	MONTH	YEAR TO DATE	CUMULATIVE
1 DESIGN ELECTRICAL RATING (MWe-Net)	860		
2 MAXIMUM DEPENDABLE CAPACITY (Mwe-Net)	834		
3 NUMBER OF HOURS REACTOR WAS CRITICAL	744.0	7,956.4	166,071
4 NUMBER OF HOURS THE GENERATOR WAS ON LINE	734.8	7,912.2	163,728
5 UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	0
6 NET ELECTRICAL ENERGY GENERATED (MWH)	630,171	6,579,430	127,849,001

APPENDIX B UNIT SHUTDOWNS

DOCKET NO. 50-302
 UNIT NAME FLCRP-3
 DATE January 2, 2004
 COMPLETED BY J.E. Lane
 TELEPHONE (352) 795-6486 x3698

REPORTING PERIOD: December 2003

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reason (1)	Method of Shutting Down (2)	Cause / Corrective Actions
						Comments
03-04	12/09/2003	F	9.15	A	1	The plant shut down to repair an EHC fluid leak on RHV-5..

SUMMARY:

Crystal River Unit 3 shut down the unit on 12/09/03 to repair an EHC fluid leak on RHV-5. The generator was back on-line on 12/10/03.

(1) Reason:

A-EQUIPMENT FAILURE (Explain)
 B-MAINTENANCE OR TEST
 C-REFUELING
 D-REGULATORY RESTRICTION
 E-OPERATOR TRAINING / LICENSE EXAMINATION
 F-ADMINISTRATIVE
 G-OPERATIONAL ERROR (Explain)
 H-OTHER (Explain)

(2) Method:

1-MANUAL
 2-MANUAL TRIP / SCRAM
 3-AUTO TRIP / SCRAM
 4-CONTINUATION
 5-OTHER (Explain)