

FENOC

First Energy Nuclear Operating Company

Perry Nuclear Power Plant
10 Center Road
Perry, Ohio 44081

Edward M. Root
Manager – Radwaste, Environmental, Chemistry

440-280-5646
Fax: 440-280-5681

January 9, 2004
PY-CEI/LCDU-0071L


Attention: Robert Shelby, Mentor Waste Facility
Lake County Department of Utilities
P.O. Box 490
Painesville, Ohio 44077-0490

Ladies and Gentlemen:

Enclosed are the results of an isotopic analysis performed for industrial wastewater from the Perry Nuclear Power Plant. No radioactive material attributable to the Perry Nuclear Power Plant was detected.

If you have questions or require additional information, please contact Mr. Leo Harte at (440) 280-5514.

Sincerely,



Enclosures

cc: NRC Region III
NRC Resident Inspector Office
NRC Project Manager
NRC Document Control Desk (Docket No. 50-440)

IE25

Note:

Test Information by Sample Screen

MPL Number: SEWAGE

Sched Sampled Date: 0:00:00 12/01/03

Sample ID: 425360

Actual Sampled Date: 12:30:00 12/29/03

System Name: ENVIRONMEN

Desc: Environmental Sample

Mode Number: 6

Desc: At All Times

Reason/Freq: SA

Desc: Semi-Annual

Status: PV

Isotopic by Gamma Spectroscopy

Limit:

0.00 to 0.00

0.00E+00 uCi/ml

uCi/cc for N/G samples

uCi/sec for O/G pre and post samples

uCi/gm for resin samples

MCA: 1002

NOTE: For OFFGAS PRE samples, the result is the Undecayed Release Rate.

NOTE: A numeric result of zero indicates 'None Detected'