

AmerGen Energy Company, LLC
Oyster Creek
US Route 9 South
P.O. Box 388
Forked River, NJ 08731-0388

GL 97-02

January 15, 2003
2130-04-20006

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555 - 0001

Oyster Creek Generating Station
Facility Operating License No. DPR-16
NRC Docket No. 50-219

Subject: Monthly Operating Report - December 2003

Enclosed is the December 2003 Monthly Operating Report for Oyster Creek Generating Station. The content and format of information submitted in this report is in accordance with the guidance provided by Generic Letter 97-02

If any further information or assistance is needed, please contact William Stewart at 609-971-4775.

Sincerely,



Ernest J. Harkness P. E.
Vice President, Oyster Creek Generating Station

EJHWVS
Enclosure

cc: H. J. Miller, Administrator, USNRC Region I
P. S. Tam, USNRC Senior Project Manager, Oyster Creek
R. J. Summers, USNRC Senior Resident Inspector, Oyster Creek
File No. 04002

IE24

OPERATING DATA REPORT

DOCKET NO.	50-219
UNIT NAME	Oyster Creek 1
DATE	January 13, 2004
COMPLETED BY	W. V. Stewart
TELEPHONE	(609) 971-4775

REPORTING PERIOD: December 2003

1. Design Electrical Rating	650.00		
2. Maximum Dependable Capacity (MWe-Net)	619.00		
	<u>This Month</u>	<u>Yr-to-Date</u>	<u>Cumulative</u>
3. Number of Hours the Reactor was Critical	744.00	8,515.92	218,437.02
4. Number of Hours Generator On-line	744.00	8,468.45	214,195.65
5. Reserve Shutdown Hours	0.00	0.00	918.20
6. Net Electrical Energy Generated (MWHrs)	476,234.00	5,256,325.00	122,394,753.0

UNIT SHUTDOWNS

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reason 1	Method of Shutting Down 2	Cause & Corrective Action Comments
-----	------	-----------------------------------	---------------------	----------	---------------------------------	---------------------------------------

SUMMARY: During December, Oyster Creek generated 476,234 net MWh electric, which was 103.4% of its MDC rating.

1

Reason:

- A Equipment Failure (Explain)
- B Maintenance or Test
- C Refueling
- D Regulatory Restriction
- E Operator Training & License Examination
- F Administration
- G Operational Error (Explain)
- H Other (Explain)

2

Method:

- 1 Manual
- 2 Manual Trip/Scram
- 3 Automatic Trip/Scram
- 4 Continuation
- 5 Other (Explain)