



JAN 14 2004
L-2004-006
10 CFR 50.36

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Re: Turkey Point Units 3 and 4
Docket Nos. 50-250 and 50-251
Monthly Operating Report - December 2003

In accordance with the requirements of Turkey Point Units 3 and 4 Technical Specification 6.9.1.5, and the guidance of Generic Letter 97-02, attached are the December 2003 Operating Data Reports and Summaries of Operating Experience for Turkey Point Units 3 and 4.

Very truly yours,

A handwritten signature in black ink that reads "Terry O. Jones". The signature is written in a cursive style with a large, prominent initial "T".

Terry O. Jones
Vice President
Turkey Point Plant

LDT

Attachments

NRC Regulatory Issue Summary 2001-05 waived the requirements that multiple copies of documents be submitted to the NRC.

IE24

DOCKET NO.: 50-250
 UNIT: Turkey Point Unit 3
 DATE: 01/05/2004
 COMPLETED BY: Linda Tudor
 TELEPHONE: (305) 246-6408

Reporting Period December, 2003

OPERATING DATA REPORT

Design Electrical Rating (MWe-Net)	720		
Maximum Dependable Capacity (MWe-Net)	693		
	Month	Year-to-date	Cumulative
No. of hours reactor was critical	744	7993.8	202533.2
No. of hours generator was on line (service hours)	724.5	7932.3	200140.5
Unit reserve shutdown hours	0	0	121.8
Net Electrical Energy (MWH)	484014	5445568	130804645

UNIT SHUTDOWNS

No.	Date	Type F=Forced S=Scheduled	Duration (hours)	Reason (1)	Method of Shutting Down (2)	Corrective Action/ Comments
20030027	12/06/03	F	19.54	A	5	Turbine Governor Failure. The reactor remained critical with the plant offline.

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

Summary Of Monthly Operating Experience

Unit 3 operated at essentially 100% power for the month of December 2003, except for a scheduled Turbine Valve Test and Water Box Cleaning from December 2 through December 4, which subsequently resulted in a unit reduction to Mode 2 to perform a repair to the Turbine Governor. Unit 3 returned to 100% power on December 8 and remained at essentially 100% power for the remainder of the month of December 2003.

DOCKET NO.: 50-251
 UNIT: Turkey Point Unit 4
 DATE: 01/05/04
 COMPLETED BY: Linda Tudor
 TELEPHONE: (305) 246-6408

Reporting Period December, 2003

Design Electrical Rating (MWe-Net)	720		
Maximum Dependable Capacity (MWe-Net)	693		
	Month	Year-to-date	Cumulative
No. of hours reactor was critical	744	8057.1	199419.8
No. of hours generator was on line (service hours)	744	8033.2	194978.4
Unit reserve shutdown hours	0	0	577.2
Net Electrical Energy (MWH)	543607	5562478	128521568

UNIT SHUTDOWNS

No.	Date	Type F=Forced S=Scheduled	Duration (hours)	Reason (1)	Method of Shutting Down (2)	Corrective Action/ Comments
N/A	N/A	N/A	N/A	N/A	N/A	N/A

(1) Reason

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other

(2) Method

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

Summary Of Monthly Operating Experience

Unit 4 operated at essentially 100% power for the month of December 2003.