

January 8, 2004

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Mail Stop P1-137  
Washington, DC 20555-0001



Ladies & Gentlemen:

ULNRC04934

**DOCKET NUMBER 50-483  
UNION ELECTRIC CO.  
CALLAWAY PLANT UNIT 1  
FACILITY OPERATING LICENSE NPF-30  
MONTHLY OPERATING REPORT  
DECEMBER/2003**

The enclosed Monthly Operating Report for December/2003 is submitted pursuant to Section 5.6.4 of the Callaway Unit 1 Technical Specifications.

A handwritten signature in black ink that reads "Keith D. Young".

Keith D. Young  
Manager, Regulatory Affairs

KDY/JER/slk

Enclosure

IE24

ULNRC04934  
January 8, 2004  
Page 2

cc: Mr. Bruce S. Mallett  
Regional Administrator  
U.S. Nuclear Regulatory Commission  
Region IV  
611 Ryan Plaza Drive, Suite 400  
Arlington, TX 76011-4005

Senior Resident Inspector  
Callaway Resident Office  
U.S. Nuclear Regulatory Commission  
8201 NRC Road  
Steedman, MO 65077

Mr. Jack Donohew (2 copies)  
Licensing Project Manager, Callaway Plant  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Mail Stop 7E1  
Washington, DC 20555-2738

Manager, Electric Department  
Missouri Public Service Commission  
PO Box 360  
Jefferson City, MO 65102

Enclosure  
ULNRC04934  
January 8, 2004

DOCKET NO.: 50-483  
UNIT NAME: CALLAWAY UNIT 1  
COMPLETED BY: J. E. Ready  
TELEPHONE: 573/676-8617  
FAX: 573/676-4202

REPORTING PERIOD: December/2003  
1. DESIGN ELECTRICAL RATING (MWe-Net): 1171  
2. MAX. DEPEND. CAPACITY (MWe-Net): 1125

	<u>THIS MONTH</u>	<u>YR TO DATE</u>	<u>CUMULATIVE</u>
3. NUMBER OF HOURS REACTOR WAS CRITICAL	744	8,429	149,946
4. HOURS GENERATOR ON-LINE	744	8,398	147,994
5. REACTOR RESERVE SHUTDOWN HOURS	0.0	0.0	0.0
6. NET ELECTRICAL ENERGY GENERATED (MWH)	872,168	9,699,743	163,243,839

Enclosure  
ULNRC04934  
January 8, 2004

UNIT SHUTDOWNS

DOCKET NO.: 50-483  
UNIT NAME: CALLAWAY UNIT 1  
COMPLETED BY: J. E. Ready  
TELEPHONE: 573/676-8617  
FAX: 573/676-4202

REPORT: December/2003

<u>NO.</u>	<u>DATE</u>	TYPE <u>F: FORCED</u> <u>S: SCHEDULED</u>	<u>DURATION</u> <u>(HOURS)</u>	<u>REASON</u>	METHOD OF SHUTTING DOWN <u>THE REACTOR</u>	CORRECTIVE <u>ACTIONS/</u> <u>COMMENTS</u>
------------	-------------	---	-----------------------------------	---------------	--	--

SUMMARY The Callaway Plant operated at approximately 100% power for the month of December.

<u>REASON</u>	<u>METHOD</u>
A: EQUIPMENT FAILURE (EXPLAIN)	1: MANUAL
B: MAINT. OR TEST	2: MANUAL SCRAM
C: REFUELING	3: AUTOMATIC SCRAM
D: REGULATORY RESTRICTION	4. CONTINUATION
E: OPERATOR TRAINING / LICENSE EXAMINATION	5: OTHER (EXPLAIN)
F: ADMINISTRATIVE	
G: OPERATIONAL ERROR (EXPLAIN)	
H: OTHER (EXPLAIN)	