



444 South 16th Street Mall
Omaha NE 68102-2247

January 8, 2004
LIC-04-0001

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001


Reference: Docket No. 50-285

SUBJECT: December 2003 Monthly Operating Report (MOR)

Pursuant to Fort Calhoun Station (FCS) Unit No. 1 Technical Specification 5.9.1.c, Omaha Public Power District (OPPD) submits the attached MOR for December 2003. No commitments are made to the NRC in this letter.

If you have any questions, please contact Mr. Erick Matzke at (402) 533-6855.

Sincerely,



R. T. Ridenoure
Vice President

RTR/EPM/epm

Attachment

c: B. S. Mallett, NRC Regional Administrator, Region IV
A. B. Wang, NRC Project Manager
J. G. Kramer, NRC Senior Resident Inspector
INPO Records Center

LIC-04-0001
Attachment

OPERATING DATA REPORT

DOCKET NO. 50-285
UNIT NAME Fort Calhoun Station
DATE January 2, 2004
COMPLETED BY E. P. Matzke
TELEPHONE (402) 533-6855

REPORT PERIOD: December 2003

Design Electrical Rating (MWe-Net): 478
Maximum Dependable Capacity (MWe-Net): 478

	<u>MONTH</u>	<u>YR-TO-DATE</u>	<u>CUMULATIVE</u>
Number of Hours Reactor was Critical:	744	7,626	214,868
Number of Hours Generator was On-line:	744	7,597	213,525
Unit Reserve Shutdown Hours:	0	0	0
Net Electrical Energy Generated (MWh):	365,757	3,510,073	92,526,103

UNIT SHUTDOWNS

No.	Date (yy/mm/dd)	Type F: Forced S: Scheduled	Duration (Hours)	Reason ¹	Method of Shutting Down Reactor ²	Cause & Corrective Action Comments

(1) Reason:

- A-Equipment Failure (Explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training/License Examination
- F-Administrative
- G-Operational Error (Explain)
- H-Other (Explain)

(2) Method:

- 1-Manual
- 2-Manual Trip/Scram
- 3-Automatic Trip/Scram
- 4-Continuation
- 5-Other (Explain)

OPERATIONS SUMMARY

Fort Calhoun Station operated at a nominal 100 percent power for the entire month of December.