



444 South 16th Street Mall
Omaha NE 68102-2247

January 9, 2004
LIC-04-0006

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555-0001


- References:
1. Docket No. 50-285
 2. Letter from OPPD (R. T. Ridenoure) to NRC (Document Control Desk), "Closure of NRC TAC Issues for Fort Calhoun Station," dated February 12, 2003 (LIC-03-0016)

SUBJECT: Closure of NRC TAC Issues for Fort Calhoun Station Unit No. 1

The Omaha Public Power District (OPPPO) has implemented the necessary actions associated with the open TAC issues listed in the Attachment. Subject to agreement by the NRC/NRR Project Manager, these items are ready to close. These actions have been taken since the last TAC Closure letter (Reference 2).

No commitments are made to the NRC in this letter. If you have any questions or require additional information, please contact Dr. R. L. Jaworski at (402) 533-6833.

Sincerely,



J. B. Herman
Manager
Nuclear Licensing

JBH/mle

Attachment

- c: B. S. Mallett, NRC Regional Administrator, Region IV
A. B. Wang, NRC Project Manager
J. G. Kramer, NRC Senior Resident Inspector

A001

**Table of Implemented TAC Actions
 Fort Calhoun Station**

Amendment No.	Description	TAC No.	FCS Implementation Date
214	Relocation Of Nuclear Detector Cooling System To The Updated Safety Analysis Report	MB6470	3/20/03
215	Missed Surveillances And Adoption Of A Technical Specification Bases Control Program	MB5839	3/7/03
216	Relocation Of TS 3.5(5), Requirements For Testing Prestressed Concrete Containment Tendons To The Updated Safety Analysis Report	MB6472	6/5/03
217	Extend Allowed Outage Time For A Single Low Pressure Safety Injection Pump From 24 Hours To 7 Days	MB6469	6/25/03
218	Administrative And Editorial Changes To The FCS Technical Specifications	MB7498	7/8/03
219	Increase "As Found" Pressurizer Safety Valve (Psv) Lift Setting Tolerance	MB7497	8/21/03
220	One-Time Five-Year Extension To The Current Ten-Year Test Interval For The Containment Integrated Leak Rate Testing	MB6473	8/21/03
221	Use Of A Pressure Temperature Limits Report And Revision Of Low Temperature Overpressure Protection (LTOP) Methodology	MB6468	9/5/03
222	Use Of The GOTHIC Computer Program For The Peak Containment Pressure Analysis	MB7496	12/5/03
223	Deletion Of TS 2.3(2)i And The Corresponding Bases That Allows The Performance Of The SR Of Table 3-2, Item 20 (Recirculation Actuation Logic Channel Functional Test) Under Administrative Controls	MB7499	1/6/04

Amendment No.	Description	TAC No.	FCS Implementation Date
N/A	Issuance Of Order For Interim Safeguards And Security Compensatory Measures For Fort Calhoun Station, Unit 1	MB4130	8/31/02
N/A	Issuance Of Order For Compensatory Measures Related To Fitness-For-Duty Enhancements Applicable To Nuclear Facility Security Force Personnel	MB9189	10/29/03
N/A	Response To Order For Compensatory Measures Related To Access Authorization	MB7416	1/7/04