



Entergy Nuclear Northeast
Entergy Nuclear Operations, Inc.
James A. Fitzpatrick NPP
P.O. Box 110
Lycoming, NY 13093
Tel 315 349 6024 Fax 315 349 6480

January 12, 2004
JAFP-04-0004

T.A. Sullivan
Site Vice President - JAF

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station O-P1-17
Washington, DC 20555

SUBJECT: James A. FitzPatrick Nuclear Power Plant
Docket No. 50-333
December 2003 Monthly Operating Report

Dear Sir:

Enclosed is the Monthly Operating Report for the James A. FitzPatrick Nuclear Power Plant for the month of December 2003.

Should you have any questions concerning this report, please direct them to Mr. Mick Baker, Thermal Performance Engineer, at (315) 349-6181.

Very truly yours,


T. A. SULLIVAN

TAS:MB:dr
Enclosure

JE24

cc: Regional Administrator
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Office of the Resident Inspector
James A. FitzPatrick Nuclear Power Plant
U.S. Nuclear Regulatory Commission
P.O. Box 136
Lycoming, NY 13093

Mr. Guy Vissing, Project Manager
Project Directorate I
Division of Licensing Project Management
U.S. Nuclear Regulatory Commission
Mail stop OWFN 8C2
Washington, DC 20555

Mr. R. Toole
ENN BWR SRC Operations Subcommittee Chairman
605 West Horner Street
Ebensburg, PA 15931

Mr. Paul Eddy
Public Service Commission
Office of Electricity and the Environment
3 Empire Plaza
Albany, NY 12223

JENG JAFP Files
RMS (JAF)

**ENTERGY NUCLEAR NORTHEAST
JAMES A. FITZPATRICK NUCLEAR POWER PLANT
OPERATING DATA REPORT**

REPORTING PERIOD: DECEMBER 2003

Docket No.:	50-333
Unit Name:	FitzPatrick
Date:	January 5, 2004
Completed By:	M. Baker
Telephone:	(315) 349-6181

APPENDIX A - OPERATING DATA REPORT

1. Design electrical rating (net MWE): **816**
2. Maximum dependable capacity (net MWE): **813**

NO.	DATA REQUESTED	THIS MONTH	YR-TO-DATE	CUMULATIVE
3	Number of hours reactor was critical:	744.0	8574.0	189904.5
4	Hours generator on-line:	744.0	8436.9	184571.2
5	Unit reserve shutdown hours:	0.0	0.0	0.0
6	Net electrical energy generated (MWH):	629917.0	6965969.0	137905764.0

APPENDIX B - UNIT SHUTDOWNS

NO.	DATE	TYPE (*)	DURATION HOURS	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR (2)	CAUSE / CORRECTIVE ACTIONS / COMMENTS
N/A						

(*) TYPE:
F. FORCED
S. SCHEDULED

(1) REASON:
A. Equipment failure (explain)
B. Maintenance or Test
C. Refueling
D. Regulatory Restriction
E. Operator training/license examination
F. Administrative
G. Operational error (explain)
H. Other (explain)

(2) METHOD:
1. Manual
2. Manual Trip/Scram
3. Automatic Trip/Scram
4. Continuation
5. Other

REPORTING PERIOD: DECEMBER 2003

Docket No.:	50-333
Unit Name:	FitzPatrick
Date:	January 5, 2004
Completed By:	M. Baker
Telephone:	(315) 349-6181

APPENDIX B - OPERATIONAL SUMMARY

The FitzPatrick plant operated at or near rated power for the duration of the month of December 2003.