

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
SR 3.7.3.5 Verify each CREF subsystem can maintain a positive pressure of ≥ 0.125 inches water gauge relative to the outside atmosphere during the recirculation mode of operation at a makeup flow rate of ≤ 1800 cfm.	18 months on a STAGGERED TEST BASIS
SR 3.7.3.6 Verify that unfiltered inleakage from CREF system duct work outside the Control Room envelope that is at negative pressure during accident conditions is within limits.	36 months [#]

[#] This surveillance requirement may be extended on a one-time basis to prior to startup from RF-10.