

DOCKET NUMBER
PROPOSED RULE FR 50
(69FR 00879)

January 27, 2004 (1:23PM)

OFFICE OF THE SECRETARY
RULEMAKINGS AND
ADJUDICATIONS STAFF

Subject: RIN 3150-AH24
(Comments regarding proposed amendment to 10CFR50.55a, FR
Vol. 69, No. 4, 07 Jan 04)

To: SECY@nrc.gov

From: Howard T. Hill

Date: 27 Jan 04

Please consider the following comment on the proposed amendment to 10CFR50.55a.

The initial paragraph of §50.55a(f) states, "Requirements for inservice inspection of Class 1, Class 2, Class 3, Class MC and Class CC components (including their supports) are located in §50.55a(g)". However, §50.55a(g) does not address ISI of Class MC supports (Class CC supports are probably not an issue).

If the intent of 50.55a is to require inservice inspection of Class MC supports, then the following recommended change (underlined) to the regulation would clarify this point.

§50.55a(g)(4)Components (including supports) which are classified as MC pressure retaining components and their integral attachments, and components which are classified as Class CC pressure retaining components and their integral attachments must meet

Comments submitted by,

Howard T. Hill, PhD, P.E.
hthill@hthpe.com

Template = SECY-067

SECY-02