

ENERGY NORTHWEST

P.O. Box 968 ■ Richland, Washington 99352-0968

January 14, 2004
GO2-04-006


U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555-0001

Subject: **COLUMBIA GENERATING STATION, DOCKET NO. 50-397
MONTHLY OPERATING REPORT
DECEMBER 2003**

Dear Sir or Madam:

Transmitted herewith is the Monthly Operating Report for the month of December 2003 as required by Technical Specification 5.6.4.

Respectfully,



WS Oxenford
Plant General Manager
Mail Drop 927M

Attachment

cc: BS Mallett - NRC RIV
BJ Benney - NRC NRR
NRC Senior Resident Inspector - 988C
TC Poindexter - Winston & Strawn
INPO
ANI Library
Utility Data Institute
RN Sherman - BPA / 1399

JE24

OPERATING STATUS REPORT
for Columbia Generating Station

Date: January 1, 2004

1. Docket: 50-397
2. Reporting Period: December 2003
3. Utility Contact: **Patricia Campbell** (509) 377-4664
4. Design Electrical Rating (Net MWe): 1153
5. Maximum Dependable Capacity - summer (Net MWe): 1107

	MONTH	YEAR	CUMULATIVE
6. Hours Reactor Critical	744.0	7,163.0	126,858.5
7. Hours Generator On-Line	744.0	7,042.1	123,413.6
8. Unit Reserve Shutdown Hours	0.0	0.0	3,274.7
9. Net Electrical Energy (MWH)	831,164	7,614,873	122,867,652

UNIT SHUTDOWNS

DOCKET NO.: 50-397
 UNIT NAME: Columbia Generating Station
 DATE: January 1, 2004
 COMPLETED BY: P. Campbell
 TELEPHONE: (509) 377-4664

REPORT PERIOD: December, 2003

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reason (1)	Method of Shutting Down (2)	Cause / Corrective Actions Comments
NA						

SUMMARY:

Columbia Generating Station entered the month at full reactor power. On December 21, 2003 power was reduced to about 60% for scheduled testing and steam leak repairs. Full power operation was resumed early on the morning of December 22, 2003 and sustained through the end of the month.

(1) REASON

A - Equipment Failure
 B - Maintenance or Test
 C - Refueling
 D - Regulatory Restriction

E - Operator Training &
 License Examination
 F - Administration
 G - Operational Error
 H - Other

(2) METHOD

1 - Manual
 2 - Manual Trip/Scram
 3 - Auto Trip/Scram
 4 - Continuation
 5 - Other (Explain)