



- NOTES:**
- FOR NOTES, SYMBOLS AND UNIT #2 ABBREVIATIONS SEE 25001 SH. L. 2 & 3. FOR ALL OTHER ABBREVIATIONS SEE ANSI STANDARD Y11.
 - VALVES 2-SI-701A, 2-SI-702A THRU 2-SI-701D, 2-SI-702D, SHOULD BE LOCATED OUTSIDE THE SECONDARY SHIELD WALL AT EL. (+)14'-6" AS CLOSE AS PRACTICAL TO A DRAIN.
 - OPEN AND CLOSE COILS REMOVED FROM MCC CONTACTOR WHEN UNIT IS IN MODES 1, 2, 3, 5 OR 6 (2-SI-651).
 - CLOSE COIL, REMOVED FROM MCC CONTACTOR WHEN UNIT IS IN MODES 1, 2, OR 3 (2-SI-614, 2-SI-624, 2-SI-634 & 2-SI-644).
 - PORTIONS OF LINE HCD-31 (S.I. TEST HEADER) WAS UPGRADED TO SEISMIC CLASS 1 PER PDCR 2-222-76. THE UPGRADED PORTIONS OF THE LINE TO SEISMIC CLASS 1 ARE NOW REFLECTED AS HCD-31C1.

CHANGES MADE TO THIS P&ID MUST ALSO BE REFLECTED ON THE INSERVICE INSPECTION PROGRAM DRAWING 25203-26700 SH. 13

OPERATIONS CRITICAL

FSAR FIGURE
SAFETY EVALUATION MAY BE REQUIRED PRIOR TO CHANGES

| NO. | DATE | REVISIONS | BY | CHK. | APP. |
|-----|------|-----------|--------------------------|------|------|
| N/A | 00 | 1-86 | INITIAL ISSUE PER REV 23 | CLW | |
| | | | | | |

| REVISED DURING CONSTRUCTION | P.A. NO. |
|-----------------------------|----------|
| | |

| | | | |
|---|----------|--|------|
| COMPONENTS SUBJECT TO AGING MANAGEMENT REVIEW 2301 REACTOR COOLANT 2305 SAFETY INJECTION 2309 SHUTDOWN COOLING 2320 CLEAN LIQUID WASTE PROCESSING 2333 NITROGEN | | Dominion Nuclear Connecticut Inc. Millstone Power Station MILLSTONE NUCLEAR POWER STATION - UNIT 2 LICENSE RENEWAL DIAGRAM SAFETY INJECTION TANKS WATERBURY, CT | |
| DATE | DATE | DATE | DATE |
| SCALE | CNCL NO. | | |
| 25203-LR26015 SH. 3 OF 3 | | 0 | |

| | | | |
|---|----------|--|------|
| COMPONENTS SUBJECT TO AGING MANAGEMENT REVIEW 2301 REACTOR COOLANT 2305 SAFETY INJECTION 2309 SHUTDOWN COOLING 2320 CLEAN LIQUID WASTE PROCESSING 2333 NITROGEN | | Dominion Nuclear Connecticut Inc. Millstone Power Station MILLSTONE NUCLEAR POWER STATION - UNIT 2 LICENSE RENEWAL DIAGRAM SAFETY INJECTION TANKS WATERBURY, CT | |
| DATE | DATE | DATE | DATE |
| SCALE | CNCL NO. | | |
| 25203-LR26015 SH. 3 OF 3 | | 0 | |

2034