SPENT FUEL POOL HEAT EXCHANGER

QUENCH TANK HEAT EXCHANGER

AERATED WASTE EVAPORATOR PACKAGE
RETIRED IN PLACE PER PDCR 2-103-79

SPENT FUEL POOL HEAT EXCHANGER

BORIC ACID EVAPORATOR PACKAGE
RETIRED IN PLACE PER PDCR 2-95-054

SHUTDOWN HEAT EXCHANGER

SHUTDOWN HEAT EXCHANGER

ENGINEERED SAFETY FEATURES ROOM AIR COOLING COIL

ENGINEERED SAFETY FEATURES ROOM AIR COOLING COIL

AFTERCOOLER

AFTERCOOLER

WASTE GAS COMPRESSORS

NOTES:
1. FOR NOTES, SYMBOLS AND UNIT #'s2 ABBREVIATIONS SEE 26001 SH. 1, 2 & 3. FOR ALL OTHER ABBREVIATIONS SEE ANSI STANDARD Y1.1.
2. ALL DRAINS FROM THE R.B.C.C.W. SYSTEM WILL DRAIN TO OPEN DRAINS IN THEIR RESPECTIVE AREAS. FOR FLOOR DRAINS P&ID SEE DRAWING 26024, (SHTS 1-3) A FUNNEL (Y) DENOTES THE OPEN (MSD) DRAIN SYSTEM.

PIPING LINE SYMBOLS
HEADER A
HEADER B
HEADER A OR B (SWING FACILITY)

CHANGES MADE TO THIS P&ID MUST ALSO BE REFLECTED ON THE INSERVICE INSPECTION PROGRAM DRAWING 25203-26700 SH. 18

OPERATIONS CRITICAL

Q.A.

FSAR FIGURE
SAFETY EVALUATION MAY BE REQUIRED PRIOR TO CHANGES

CAD
NOTE: MANUAL REVISIONS TO THIS DOCUMENT WHEN AS-BUILT ARE PROHIBITED.

REDRAWN INPART FROM 25203-26022 SHEET 1 REVISION 15.

REVISIONS DURING CONSTRUCTION	P.A. NO.

NO.	DATE	REVISIONS	BY	CHK.	APP.	APP.
N/A	00	1-24-02	INITIAL ISSUE PER REV 25	CLW		

ISSUED FOR MASTER DRAWING
25203-26022 SH. 2 OF 6
REV 25

Dominion Nuclear Connecticut Inc.
FOR Millstone Power Station
TITLE MILLSTONE NUCLEAR POWER STATION-UNIT 2
LICENSE RENEWAL DIAGRAM
R.B.C.C.W. SYSTEM SPENT FUEL POOL AND SHUT-DOWN HEAT EXCHANGERS
WATERFORD, CT

BY	CHKD.	APPR.	APPR.
DATE	DATE	DATE	DATE

SCALE
DWG. NO. 25203-LR26022 SH. 2 OF 6 0

COMPONENTS SUBJECT TO AGING MANAGEMENT REVIEW

2330	REACTOR BLDG CLOSED COOLING WATER
2337	GASEOUS WASTE PROCESSING
2332B	INSTRUMENT AIR
2318	SHUTDOWN COOLING
2314H	ESF ROOM AIR RECIRCULATION
2316	MAIN STEAM
2305	SPENT FUEL POOL COOLING

NOTE: SOME SHADED LINES MAY CONTAIN COMPONENTS FROM MORE THAN ONE SYSTEM.

Submitted by SEKULIC on Monday December 22 2003 at 07:38:32 AM EST
D 050