DC SWITCHGEAR ROOM A/C UNIT
AUX. BLDG. EL. 14'-6"

ACCESS CONTROL AREA A/C UNIT
EL. 54'-6"

CONTROL ROOM A/C UNIT
(SEE NOTE 2)

DC SWITCHGEAR ROOM A/C UNIT
EL. 14'-6"

CABLE VAULT RECIRC. UNIT
EL. 56'-6"

CHILLED WATER SURGE TANK
EL. 54'-6"

HYDRAZINE FEEDER TANK
T-58

CHILLED WATER PUMP P-122A

CHILLED WATER PUMP P-122B

P-149A

P-149B

P-149C

X-169C EVAPORATOR

X-169D EVAPORATOR

CHILLER X-169A

CHILLER X-169B

NON VITAL CHILLER X-196A

NON VITAL CHILLER X-196B

NON VITAL CHILLED WATER PUMPS

CONDENSER

EVAPORATOR

COMPRESSOR

CAPILLARY TUBE

THERMOSTAT

LOW TEMP. CUT OUT

OPC

HI PRESS. CUT OUT

OIL PRESS. CUT OUT

LOW PRESS. CUT OUT

LTC

T

TBCCW SYSTEM RETURN 26007 SH.1 (B-12)

TBCCW SYSTEM SUPPLY 26007 SH.1 (A-12)

TBCCW SYSTEM 26007 SH.1 (C-12)

CONTAINMENT AND ENCLOSURE BLDG. VENT'L SYSTEM 26028 SH.5 (F-2)

CONTAINMENT AND ENCLOSURE BLDG. VENT'L SYSTEM 26028 SH.5 (E-2)

PWW 26030 SH.1 (C-3)

HCD-62

TO DRAIN HEADER 26029 SH.1 (F-6)

THROTTLED FROM SECONDARY SAMPLE STATION/SINK W-53

ABANDONED IN PLACE

TO SECONDARY SAMPLE STATION/SINK H-53 26025 SH.2 (J-3)

FROM SECONDARY SAMPLE STATION/SINK W-53 26025 SH.2 (K-3)

SERVICE WATER SUPPLY 26008 SH.3 (J-5)

SERVICE WATER RETURN 26008 SH.3 (J-5)

SERVICE WATER RETURN 26008 SH.3 (J-5)

SERVICE WATER SUPPLY 26008 SH.3 (J-5)

TO 2-SW-113 26008 SH.3 (H-6)

TO 2-SW-111 26008 SH.3 (H-2)

CLOSES ON SIAS

SIAS OPENS

SIAS STARTS

NOTE:
1. FOR NOTES, SYMBOLS AND UNIT # 2 ABBREVIATIONS SEE 26001 SH.1, 2 & 3. FOR ALL OTHER ABBREVIATIONS SEE ANSI STANDARD Y1.1.
2. PIPING HAS BEEN CAPPED PER PDCR 2-18-79.

CHANGES MADE TO THIS P&ID MUST ALSO BE REFLECTED ON THE INSERVICE INSPECTION PROGRAM DRAWING 25203-26700 SH. 24

OPERATIONS CRITICAL Q.A.

REDRAWN INPART FROM 25203-26027 SH.2 THRU REV.5

FSAR FIGURE
SAFETY EVALUATION MAY BE REQUIRED PRIOR TO CHANGES

CAD NOTE: MANUAL REVISIONS TO THIS DOCUMENT WHEN AS-BUILT ARE PROHIBITED.

REVISIONS DURING CONSTRUCTION	P.A. NO.

NO.	DATE	REVISIONS	BY	CHK.	APP.	APP.
N/A	00	7-23-02 INITIAL ISSUE PER REV 42	CLW			

ISSUED PER MASTER DRAWING LIST

Dominion Nuclear Connecticut Inc.
FOR Millstone Power Station
TITLE: MILLSTONE NUCLEAR POWER STATION UNIT-2
LICENSE RENEWAL DIAGRAM
TURBINE BLDG., INTAKE STR., WHSE. & D.G. RMS.
CHILLED WATER SYSTEM
WATERFORD, CT

BY	CHKD.	APP.	APP.
DATE	DATE	DATE	DATE

SCALE | DWG. NO. 25203-LR26027 SH. 2 OF 4 | REV. 0

25203-26027 SH. 2 OF 4 | REV. 42

COMPONENTS SUBJECT TO AGING MANAGEMENT REVIEW

2338C	CHILLED WATER
2326A	SERVICE WATER
2335B	NON-RADIOACTIVE AREA VENTILATION
2335D	VITAL SWITCHGEAR VENTILATION

NOTE: SOME SHADED LINES MAY CONTAIN COMPONENTS FROM MORE THAN ONE SYSTEM.

DAC8

Submitted by SEKULIC on Monday December 22 2003 at 07:36:39 AM EST