

To : DOCUMENT CONTROL DESK
 Facility : MP Department : 806
 Address : NUC REGULATORY COMMISSION (0140)
 DOCUMENT CONTROL DESK
 WASHINGTON, DC 20555

From : NDS CONT DOCUMENTS
 Date/Time : 01/22/04 15:47

Trans No. : 000054386 Transmittal Group Id: 04022DT-7
 Total Items: 00001

PASSPORT DOCUMENT

TRANSMITTAL

Page: 1



Item	Facility	Type	Sub	Document Number / Title	Sheet	Revision	Doc Date	Copy #	Media	Copies
* 0001	MP	PROC	EP	MP-26-EPA-FAP01 MANAGEMENT PROGRAM FOR MAINTAINING EMERGENCY		001			P	01
							PREPAREDNESS			

Please check the appropriate response and return form to NDS Bldg 475/3
 Millstone Power Station or Fax to 860-440-2057.

- ☐ All documents received.
☐ Documents noted above not received (identify those not received).
☐ I no longer require distribution of these documents.

Date: _____ Signature: _____

1045

02/27/03
Approval Date

03/07/03
Effective Date

Procedure Action Request

Document No.: MP-26-EPA-FAP01	Writer: Lisa Sinopoli Initiator Kathy Burgess	Rev. No. 001	Minor Rev. 00
Title: Management Program for Maintaining Emergency Preparedness			
For New Documents: Document is QA <input type="checkbox"/> DH Title:			
<input checked="" type="checkbox"/> Revision ^{1/5/04} <input checked="" type="checkbox"/> Minor Revision <input type="checkbox"/> Cleanup Revision <input checked="" type="checkbox"/> Biennial Review			
<input type="checkbox"/> Cancel <input type="checkbox"/> Void (Do Not Use) <input type="checkbox"/> Expire <input type="checkbox"/> Superseded By: _____			
Comments: <input type="checkbox"/> Administrative Correction FLS: _____			
Associated ARs 03008541			

Reviews		Print	Sign	Date	Department
Environmental Screen	<input checked="" type="checkbox"/>	Kathleen R Burgess	Kathleen Burgess	1/5/04	EPD
Writer's Guide	<input checked="" type="checkbox"/>	M Marzyski	M Marzyski	1/6/04	NPD
E-Plan-50.54(q)	<input checked="" type="checkbox"/>	Kathleen R Burgess	Kathleen Burgess	1/8/04	EPD
RCD	<input checked="" type="checkbox"/>	Kathleen R Burgess	Kathleen Burgess	1/2/04	EPD
WC 9 Att 3 Req. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/>				
Licensing Basis / RCD (50.59 Screen Req. <input type="checkbox"/> Yes <input type="checkbox"/> No)	<input type="checkbox"/>				
Tech Independent	<input checked="" type="checkbox"/>	STEVE MARZOWA	Steve Marzow	1/12/04	EPD

Validation	<input type="checkbox"/> None <input type="checkbox"/> Field - Use MP-05-DC-SAP01-004 <input type="checkbox"/> Simulated Performance - Use MP-05-DC-SAP01-004 <input type="checkbox"/> Table Top and Walk-through <input checked="" type="checkbox"/> Comparison
(minimum of two)	Print Sign Date Dept
Coordinator	Kathleen R Burgess Kathleen Burgess 1/20/04 EPD
Member	Thomas J Dembek T. Dembek 1/20/04 EPD
Training:	<input checked="" type="checkbox"/> None <input type="checkbox"/> Nuclear Training <input type="checkbox"/> Briefing <input type="checkbox"/> Familiarization

<input checked="" type="checkbox"/> SQR Review and Approval	<input type="checkbox"/> SORC Review and Approval	<input type="checkbox"/> Department Head Review and Approval
Approval <input checked="" type="checkbox"/> Disapproval <input type="checkbox"/>		
M.E. Birch 1/12/04 (1) SQR Sign/Date	(1) Department Head Sign/Date	(1) Department Head Approval Sign
Daniel Lueck 1/16/04 (2) Department Head Approval Sign	(2) SORC Meeting Number	
	(3) SORC Approval Sign	
Approval Date: 1/16/04 SM	Effective Date: 1/28/04	

**Functional
Administrative
Procedure**



Millstone Station

**Management Program for Maintaining Emergency
Preparedness**

MP-26-EPA-FAP01

Rev. 001

Approval Date: 1/16/04

Effective Date: 1/28/04



TABLE OF CONTENTS

1. <u>PURPOSE</u>	3
1.1 Objective.....	3
1.2 Applicability	3
1.3 Supporting Documents	3
1.4 Discussion.....	4
2. <u>INSTRUCTIONS</u>	5
2.1 Responsibilities of the Manager, Emergency Preparedness Department (EPD) for Maintaining Emergency Preparedness	5
2.2 Responsibilities of the Supervisor, Emergency Preparedness Department (EPD), for Maintaining Emergency Preparedness	6
2.3 Responsibilities of the Emergency Preparedness Specialists for Maintaining Emergency Preparedness.....	7
2.4 SERO Position Owner Actions for Maintaining Emergency Preparedness	8
2.5 Station Management Actions for Maintaining Emergency Preparedness.....	9
2.6 SERO Personnel	11
2.7 Minimum Staffing Positions.....	13
2.8 Full Staffing Positions	15
2.9 On-Shift Positions.....	17
2.10 SERO Assembly Areas.....	18
2.11 Drills and Exercises	19
2.12 Emergency Response Facilities (ERFs) and Equipment.....	21
2.13 Severe Accident Management	22
3. <u>SUMMARY OF CHANGES</u>	23
3.1 Revision 001	23

ATTACHMENTS AND FORMS

Attachment 1 Emergency Preparedness Abbreviations and Definitions	24
Attachment 2 Summary of Department Responsibilities for Facilities, Equipment, and Material Maintenance.....	25
Attachment 3 Documentation of Testing of Dose Assessment Computer	29
Attachment 4 SERO Qualifications and Reporting Location (3)	30
Attachment 5 Roles and Responsibilities For Emergency Preparedness Dose Assessment....	37
Attachment 6 Radiological Dose Assessment Committee	39
MP-26-EPA-FAP01-001, "SERO Removal Form"	
MP-26-EPA-FAP01-002, "Unit Event Backup Codes"	

1. PURPOSE

1.1 Objective

This procedure describes sources of information, responsibilities, organization, and actions necessary to maintain the Millstone Station Emergency Plan.

1.2 Applicability

This procedure is applicable to Station Emergency Response Organization (SERO) Position Owners, Station Management, SERO station personnel, and Emergency Preparedness Department (EPD) individuals who support/administer the Millstone Station Emergency Plan.

1.3 Supporting Documents

1.3.1 TQ 1, "Personnel Qualification and Training"

1.3.2 NTP 7.212, "Training Program Description"

1.3.3 RPM 4.8.5, "Emergency Radiological Equipment Maintenance and Inspection."

1.3.4 OA 8, "Ownership, Maintenance, and Housekeeping of Site Buildings and Facilities and Equipment"

1.3.5 QAP, MP-02-OST-BAP01, "Quality Assurance Program Topical Report"

1.3.6 MP-05-DC-SAP01, "Procedure Modification and Compliance for Millstone Station"

1.3.7 MP-26-EPA-REF04, "Offsite Programs"

1.3.8 Developmental Documents

- a. Millstone Station Emergency Plan
- b. NUREG-0654, Revision 1, "Criteria for Preparation of Radiological Emergency Response Plans and Preparedness in Support of Nuclear Power Plants"
- c. NUREG-0737, "Clarification of TMI Action Plan Requirements, Supplement 1, Requirements for Emergency Response Capability"
- d. MP-28-MET-PRG, "Meteorological Monitoring"
- e. EP 6-year objective schedule
- f. SERO Training Qualification Record (TQR)

1.4 Discussion

MP-26-EPA-FAP01, "Management Program for Maintaining Emergency Preparedness," provides instructions and information for the Station Emergency Response Organization (SERO). The roles and responsibilities for the Emergency Preparedness Department (EPD) are defined. SERO position owners and station management actions are specified to ensure an effective SERO is maintained. The procedure also establishes the method for adding and removing individuals from SERO. Clarification and instructions are provided for SERO minimum staffing, full staffing, and on shift position requirements.

Station personnel may also be required to participate in station evacuation drills. Advance notification will be provided via station information notices.

Department requirements for drills, exercises, and maintaining emergency response facilities (ERFs) are discussed.

2. INSTRUCTIONS

2.1 Responsibilities of the Manager, Emergency Preparedness Department (EPD) for Maintaining Emergency Preparedness

The Manager, EPD, has overall responsibility for the Nuclear Emergency Preparedness Program and is the Chair of the Emergency Preparedness Training Review Board (TRB). Responsibilities are defined below and in the Millstone Station Emergency Plan.

- 2.1.1 Ensure the on-site emergency response facilities and equipment are maintained and in a state of readiness.
- 2.1.2 Maintain the Station Emergency Plan and implementing procedures.
- 2.1.3 Prepare and conduct Emergency Preparedness drills and exercises.
- 2.1.4 Ensure training of offsite emergency response personnel.
- 2.1.5 Review the development of Emergency Preparedness training curriculum.
- 2.1.6 Assist station management to ensure effective Millstone Station Emergency Plan implementation.
- 2.1.7 Collect and review additional EP-related information such as severe accident management research, NRC regulations, and industry research for incorporation into the EP Program.
- 2.1.8 Coordinate with offsite agencies and local officials to ensure the offsite Emergency Preparedness Program is maintained and areas of responsibility are effectively carried out.
- 2.1.9 Coordinate licensee, state and local emergency plans and procedures.
- 2.1.10 Ensure station personnel correct identified emergency preparedness conditions adverse to quality and areas for improvement.
- 2.1.11 Administer the NRC Performance Indicator (PI) Program and track participation and performance during designated PI activities.

- End of Section 2.1 -

2.2 Responsibilities of the Supervisor, Emergency Preparedness Department (EPD), for Maintaining Emergency Preparedness

- 2.2.1 Respond to emergency preparedness audits and evaluations.
- 2.2.2 Assign personnel to develop and conduct station emergency preparedness drills and exercises.
- 2.2.3 Ensure biennial review of station procedures in accordance with the QAP, MP-02-OST-BAP01, "Quality Assurance Program Topical Report," and MP-05-DC-SAP01, "Procedure Modification and Compliance for Millstone Station," and review additional changes for impact on the Millstone Station Emergency Plan.
- 2.2.4 Coordinate the development and distribution of emergency preparedness documents.
- 2.2.5 Establish SERO Position Owners and reference in Attachment 4, "SERO Qualification and Reporting Location (3)."
- 2.2.6 Review the development of emergency preparedness training curriculum.
- 2.2.7 Refer To Attachment 2, "Summary of Department Responsibilities for Facilities, Equipment, and Material Maintenance," and ensure responsible position owners maintain emergency response in a state of readiness at all times.
- 2.2.8 Refer To Training Qualification Record (TQR) for each specific position, and coordinate completion of qualifications for each new SERO member.
- 2.2.9 Maintain Millstone Station Emergency Plan in accordance with regulatory requirements.
- 2.2.10 Refer To Attachment 5, "Roles and Responsibilities for Emergency Preparedness Dose Assessment," and ensure responsibilities are carried out.
- 2.2.11 Ensure training of offsite emergency response personnel.
- 2.2.12 Coordinate with offsite agencies and local officials in accordance with MP-26-EPA-REF04, "Offsite Programs," to ensure the offsite Emergency Preparedness Program is maintained and areas of responsibility are effectively carried out.

- End of Section 2.2 -

2.3 Responsibilities of the Emergency Preparedness Specialists for Maintaining Emergency Preparedness

- 2.3.1 Develop and conduct the station emergency preparedness drills and exercises.
- 2.3.2 Biennially review the Emergency Plan Implementing procedures for changes and revise.
- 2.3.3 Annually identify changes to the Millstone Station Emergency Plan and revise as needed.
- 2.3.4 Maintain the SERO database.
- 2.3.5 Provide technical review of Emergency Preparedness Training lesson material.
- 2.3.6 Perform emergency preparedness facility surveillances to ensure Emergency Response Facility (ERF) readiness.
- 2.3.7 Prepare drill participant comment responses following comment resolution and coordinate the issuance of responses to both onsite and offsite organizations.
- 2.3.8 Conduct training of offsite emergency response personnel.
- 2.3.9 Refer To MP-26-EPA-REF04, "Offsite Programs," and coordinate with offsite agencies and local officials to ensure the offsite Emergency Preparedness Program is carried out.

- End of Section 2.3 -

2.4 SERO Position Owner Actions for Maintaining Emergency Preparedness

NOTE

At least two qualified persons are required in any position in order to support extended event periods with at least two shifts (12 hours each). It is recommended that for minimum staffing and full staffing positions, five individuals be qualified to maintain adequate depth for all call coverage.

SERO Position
Owners

- 2.4.1 Maintain five-deep for SERO positions.
- 2.4.2 IF coverage for any minimum staffing position drops below four, establish an on-call rotation for remaining personnel and inform individuals of rotational assignment and FFD/60-minute requirements.
- 2.4.3 IF vacancies exist, ensure adequate coverage is provided by remaining position holders during reduced staffing periods, and perform the following:
 - a. Coordinate with the following to fill existing or potential vacancies:
 - Emergency Preparedness Department
 - EP Training
- 2.4.4 WHEN choosing a new SERO position holder, consider the following:
 - a. Review normal position/title against the associated emergency position.
 - b. Ensure potential candidate has additional prerequisite knowledge/skills for the position.
 - c. Determine if "upper" management is required to fill the position (i.e., VP, Director, Manager).
 - d. IF position requires plant/system knowledge (ADTS, TIC, CRDC), determine if SRO license/certification (past or present) is required.
- 2.4.5 Refer To the SERO TQRs and initiate the position specific TQR.
- 2.4.6 Ensure adequate station support is provided for emergency preparedness functions (i.e., drill support, controller, exercise development, etc.).
- 2.4.7 Ensure personnel are scheduled for drills and provide EPD with the name and dates when SERO will participate in each scheduled drill.
- 2.4.8 Ensure adequate coverage for holiday and peak vacation periods.
- 2.4.9 To initiate removal of SERO personnel, Refer To and complete MP-26-EPA-FAP01-001, "SERO Removal Form,"
- 2.4.10 Refer to Attachment 4, "SERO Qualifications and Reporting Location," and review for assigned SERO position owners.

- End of Section 2.4 -

2.5 Station Management Actions for Maintaining Emergency Preparedness

Directors

- 2.5.1 Ensure personnel are provided to support emergency preparedness activities.
- 2.5.2 Refer To Attachment 2, "Summary of Department Responsibilities for Facilities, Equipment, and Material Maintenance," and provide a point of contact to the Manager, EPD, for listed organizations.

Managers and Supervisors

- 2.5.3 Ensure personnel within reporting chain who are assigned to SERO maintain their SERO qualifications.
- 2.5.4 Refer To Attachment 2, "Summary of Department Responsibilities for Facilities, Equipment, and Material Maintenance," and perform the following:
 - a. Assign personnel to perform applicable SERO functions as requested.
 - b. Verify actions are scheduled and documented as complete via one of the following:
 - AITTS
 - PMMS
 - Automated work order
 - Completion of inventory from RPM 4.8.5, "Emergency Radiological Equipment Maintenance and Inspection." (copy to EPD)
 - c. At least once each quarter and after each use, verify emergency equipment and instruments are operationally available.
 - d. Prior to conducting work in the Emergency Response Facility, notify the Emergency Preparedness Department and the Unit 3 Control Room.
- 2.5.5 Ensure personnel are briefed on extent of drill participation.

NOTE

A SERO vacancy could occur when an individual leaves the company, training qualifications lapse, or an individual is unable to meet the requirements of the position.

- 2.5.6 IF a SERO vacancy occurs, notify the following:
 - SERO Position Owner
 - Manager, EP
- 2.5.7 Provide personnel to participate in emergency response scenario development, drills, and exercises.

2.5.8 Maintain SERO on-call independent rotation schedules for the following positions:

- Electricians
- Mechanics
- RMTs
- GTS
- I&C Technicians

2.5.9 Refer To MP-26-EPA-FAP01-001, "SERO Removal Form," and complete all information including the following:

- Individual being removed
- Replacement named to fill vacancy
- Approval and concurrences, as appropriate

NFSA

2.5.10 Refer To Attachment 5, "Roles & Responsibilities for Emergency Preparedness Dose Assessment," and ensure areas of responsibility are performed.

RDAC

2.5.11 Refer To and implement Attachment 6, "Radiological Dose Assessment Committee."

- End of Section 2.5 -

2.6 SERO Personnel

NOTE

If an emergency event occurs, pagers will display the following:

- Affected unit
- NRC classification
- State posture code
- Major EAL heading

SERO Members

2.6.1 Refer To Attachment 4, "SERO Qualifications and Reporting Location," and maintain qualifications and proficiency for initial qualification of emergency response duties as follows:

- Refer To the SERO position specific TQR and complete the required SERO Training.
- Maintain "Fitness for Duty" program requirements, as required.
- Maintain station access required by assigned position.
- Maintain job specific requirements including license or certification, as appropriate.

2.6.2 Maintain qualifications and proficiency for annual requalification by performing one of the following:

NOTE

Exceptions to participation in drills may be made by the Position Owner in consultation with EP Management on a case-by-case basis.

- Perform as the designated responder (not a called-in back-up) in at least one drill annually in accordance with Attachment 4, "SERO Qualifications and Reporting Location."
- IF requested, support drills in the following capacity:
 - Drill controller
 - Evaluator
 - Position coach or mentor

2.6.3 Refer To Attachment 4, "SERO Qualifications and Reporting Location," and identify reporting location.

2.6.4 **IF** pager fails to operate properly, obtain a replacement from one of the following:

- During normal working hours, request IT Telecommunications provide replacement pager.
- After normal working hours, request Security Shift Supervisor provide replacement pager from NAP Security Office.

2.6.5 NOTIFY Manager, EPD, of any changes to the following:

- Work extension
- Pager number
- Home phone number
- Home address
- Employment status

2.6.6 Refer To Attachment 4, "SERO Qualifications and Reporting Location," and NTP 7.212, "Training Program Description," and maintain job specific and SERO qualifications current.

- End of Section 2.6 -

2.7 Minimum Staffing Positions

Minimum Staffing Positions

2.7.1 Perform the following:

- Ensure pagers are on at all times and worn or in the immediate vicinity to be heard.
- Remain within appropriate plant proximity to ensure facility activation within 60 minutes from pager notification, as applicable to your position.
- IF fit for duty AND within appropriate plant proximity to ensure facility activation within 60 minutes from pager notification, promptly acknowledge initial pager activations.
- IF not fit for duty and contacted by the MOR, comply with the instructions provided.

NOTE

1. For open positions, the caller will be instructed to report. For filled positions, subsequent callers should report immediately even if the system indicates the position is full.
2. Once you have contacted the call-in system and the line is ringing, your call is in the queue. Do not hang up until the call is completed and ENRS instructs you to hang up.
3. If a position is not acknowledged, the ENRS will automatically page and dial the home telephone number of all personnel assigned to a position until the position is filled.
4. You will be asked to enter a realistic ETA. If you cannot report to your ERF within 60 minutes of notification, *do not* accept the position.
5. A redundant system called the Community Alert Network (CAN) will call you to ensure you received the notification. You will be asked to provide input to questions concerning your response.
6. If a position is vacant, the DSEO may elect to fill the position by appointment until a fully qualified individual is available.

2.7.2 IF a real event notification is received (not a test, drill, or exercise), dial the toll-free telephone number and comply with the instructions provided.

- WHEN calling into ENRS, wait for ENRS instruction. *Do not* hang up.
- IF in close proximity to a phone, promptly acknowledge initial pager activation.
- IF not near a phone, report directly to your designated ERF and then dial into ENRS to acknowledge the page.

- WHEN prompted, enter your individual identification (PIN) code.
- IF position is open, listen to the information and respond appropriately.
- WHEN prompted to enter your ETA, enter a realistic time to report to your designated ERF based upon your current location.
- IF position has been filled, report to the site.
- Once the ERFs are staffed and operational, do not call back into the Emergency Notification and Response System (ENRS).
- IF you are not successful in acknowledging initial pager activation, report directly to designated ERF and dial into ENRS.

2.7.3 IF not available for duty (applicable only to positions remaining on-call in accordance with Attachment 4), notify the Position Owner and obtain a replacement.

NOTE

If Unit Event codes are received, the ENRS is not available to provide any information to callers. MP-26-EPA-FAP01-002 and your SERO cards provide information on unit event backup codes.

2.7.4 IF a unit event code for an Alert or higher (e.g., ID 102, 202, 302) is received, immediately report to assigned emergency response facility.

- End of Section 2.7 -

2.8 Full Staffing Positions

2.8.1 Perform the following:

- Ensure pagers are on at all times and worn or in the immediate vicinity to be heard.
- IF *not* fit for duty and contacted by the MOR, comply with the instructions provided.
- IF fit for duty AND able to respond to your reporting location, promptly acknowledge initial pager activations.

NOTE

1. For open positions, the caller will be instructed to report. For filled positions, subsequent callers should report immediately even if the system indicates the position is full.
2. Once you have contacted the call-in system and the line is ringing, your call is in the queue. Do not hang up until the call is completed and ENRS instructs you to hang up.
3. If a position is not acknowledged, the ENRS will automatically page and dial the home telephone number of all personnel assigned to a position until the position is filled.
4. You will be asked to enter a realistic ETA.
5. A redundant system called the Community Alert Network (CAN) will call you to ensure you received the notification. You will be asked to provide input to questions concerning your response.
6. If a position is vacant, the DSEO may elect to fill the position by appointment until a fully qualified individual is available.

2.8.2 IF a real event notification is received (not a test, drill, or exercise), dial the toll-free telephone number and comply with the instructions provided.

- WHEN calling into ENRS, wait for ENRS instructions. *Do not* hang up.
- IF able to respond and near a phone, promptly acknowledge initial pager activation.
- IF not near a phone, report directly to your designated ERF and then dial into ENRS to acknowledge page.
- WHEN prompted, enter your individual PIN.
- IF position is open, listen to the information and respond appropriately.
- WHEN prompted to enter your ETA, enter a realistic time to report to your designated ERF based upon your current location.

- IF position has been filled, report to the site.
- Once the ERFs are staffed and operational, do not call back into the ENRS.

NOTE

If Unit Event codes are received, the ENRS is not available to provide any information to callers. MP-26-EPA-FAP01-002 and your SERO cards provide information on unit event backup codes.

- 2.8.3 IF a unit event code for an Alert or higher (e.g., ID 102, 202, 302) is received, immediately report to assigned emergency response facility.

- End of Section 2.8 -

2.9 On-Shift Positions

2.9.1 Refer To Attachment 4, "SERO Qualifications and Reporting Location (3)," and identify reporting location.

*Emergency
Communicator
and Station Duty
Officer*

2.9.2 WHEN notified of an Unusual Event or higher, report to affected unit control room.

*All On-shift
SERO Positions*

2.9.3 WHEN notified of an Alert, Site Area Emergency, or General Emergency, report to the designated reporting location.

- End of Section 2.9 -

2.10 SERO Assembly Areas

NOTE

The Simulator Foyer will be used as needed to retain SERO members who may be needed in the near term to support the event. This location is for positions responding to the EOF.

2.10.1 IF an Alert or higher classification has been declared during normal business hours, perform the following:

- Report to your designated Emergency Response Facility (EOF, TSC/OSC, OSCAA).
- IF on-shift AND *not* on duty (i.e., off-duty ROs, COs, PEOs, etc.), report to the OSC Assembly Area (AA) in Bldg 475 cafeteria.

2.10.2 IF an Alert or higher classification has been declared during the off-hours, perform the following:

- IF on-shift AND not on duty, report to the OSC AA in Bldg 475 cafeteria.
- IF reporting from off-site, report to your designated Emergency Response Facility (i.e., TSC, EOF, affected unit control room, etc.).

- End of Section 2.10 -

2.11 Drills and Exercises

NOTE

1. Drills provide a training opportunity to enhance and maintain effective emergency response capabilities.
2. Major objectives of the Millstone Station Emergency Plan are exercised annually. Exercises differ from drills in that the primary result of an exercise is a critical assessment of emergency response capability.
3. In order to fully evaluate SERO performance capability, back-up staffing (e.g., trainees) will normally not be allowed during evaluated drills or exercises.
4. "Hands-On/OJT" drills will be conducted when it is determined that additional training or experience will enhance an individual, selected group, facility staff or the SERO's ability to respond to emergency conditions. This training evaluation may take the form of a walkthrough or a tabletop discussion of an evolution or operation. This type of training evaluation is distinct from those described in Section 2.11.1 because the focus is limited and will generally not include an integrated response.
5. Actual emergency plan activations may be credited in place of selected drills if the Manager, EPD, deems it appropriate. Generally an Alert or higher level emergency may be substituted for a drill. Such events may also replace an exercise with NRC approval.

Manager, EPD

2.11.1 Refer To the EP 6 year objectives schedule and conduct the following drills and tests, as appropriate:

- Health Physics Drills
- Radiological Monitoring Drills
- Medical Emergency Drills
- Communication Tests
- Emergency Preparedness Training Drills
- Exercises
- Off-site Public Alerting Siren Tests
- Off-hour and Unannounced Drills
- Assembly, Accountability, and Evacuation of OCA Personnel Drills

2.11.2 Request drill support from other departments, as applicable.

2.11.3 Ensure Protective Services Department conducts fire and security drills.

2.11.4 Conduct formal critique after each of the following:

- Drill
- Exercise

- End of Section 2.11 -

2.12 Emergency Response Facilities (ERFs) and Equipment

NOTE

1. Each ERF has equipment in place to perform functions assigned in the Millstone Station Emergency Plan. The Manager, EPD, is authorized to perform unannounced, periodic walk-through inspections of ERFs.
2. Additional facility and equipment responsibilities are detailed in OA 8, "Ownership, Maintenance, and Housekeeping of Site Buildings and Facilities, and Equipment," and MP-26-EPA-FAP05, "EP Facility Maintenance."

Station Personnel

- 2.12.1 Refer To Attachment 2, "Summary of Department Responsibilities for Facilities, Equipment, and Material Maintenance," and ensure facilities are maintained, as assigned.
- 2.12.2 Perform equipment check or maintenance at required intervals and after each use.
- 2.12.3 Provide documentation of completed activities to the Manager, EP, or designee.
- 2.12.4 Promptly report problems to the Manager, EP.
- 2.12.5 IF alteration or modification of ERF or equipment is required, notify the Manager, EPD, before alteration or modification is performed.

Unit Chemistry Technicians

- 2.12.6 Refer To Attachment 3, "Documentation of Testing of Dose Assessment Computer Program," and test dose assessment computer program.

- End of Section 2.12 -

2.13 Severe Accident Management

Manager, EP

- 2.13.1 Develop Severe Accident Management (SAM) documents, ensuring Unit Operations Department and Nuclear Fuel Engineering Support provides technical expertise.
- 2.13.2 Conduct SAM Guideline (SAM-G) drills as part of the schedule 6-year objective for each operating unit, including the following:
 - Test and evaluate the unit SAM response capabilities.
 - Develop a drill scenario to challenge the development of multiple SAM strategies.
 - Refer To MP-26-EPA-FAP03, "Drill and Exercise Manual," and include drill core objectives.
- 2.13.3 Ensure SAM-G training is conducted every 2 years for continuing training.

- End of Section 2.13 -

3. SUMMARY OF CHANGES

3.1 Revision 001

- 3.1.1 Updated procedure title in step 1.3.6.
- 3.1.2 Deleted reference to additional personnel support for SERO in Section 1.4.
- 3.1.3 Added information about PIs to Manager Emergency Preparedness responsibilities in Section 2.1.
- 3.1.4 Deleted reference to routinely providing SERO qualification status and personal information to Position Owners in Sections 2.2 and 2.3.
- 3.1.5 Updated MP-05-DC-SAP01 title in step 2.2.3.
- 3.1.6 Changed rotation depth (numbers) from six deep to five deep in step 2.4.1 and Note.
- 3.1.7 Changed Manager EPD to IT Telecommunications in step 2.6.4 as the department responsible for replacing radiopagers.
- 3.1.8 Modified information in Section 2.7 on minimum staffing responsibilities.
- 3.1.9 Deleted redundant information on fit for duty policy in step 2.7.3.
- 3.1.10 Added information on the Community Alert Network (CAN) to the NOTE for step 2.7.1.
- 3.1.11 Added information on acknowledging the initial page to step 2.7.2.
- 3.1.12 Rewrote Section 2.8, Full Staffing Positions.
- 3.1.13 Clarified the ERF locations in step 2.10.1 and moved Note.
- 3.1.14 Added EP designee to step 2.12.3.
- 3.1.15 Added reference on pagers, radios, ENRS to Attachment 2.
- 3.1.16 Modified NOTE on Attachment 3 referencing dose assessment computers and tests.
- 3.1.17 Added EOF EC to Attachment 4.
- 3.1.18 Deleted NOTE for RMT Drivers on Attachment 4 due to the All-Call process.
- 3.1.19 Various grammatical modifications and clarifications.

Attachment 1

Emergency Preparedness Abbreviations and Definitions

(Sheet 1 of 1)

1. ADEOF - Assistant Director Emergency Operations Facility
2. ADTS - Assistant Director Technical Support
3. AMRDA - Assistant Manager of Radiological Dose Assessment
4. EPD - Emergency Preparedness Department
5. ERDS - Emergency Response Data System
6. IDA - Initial Dose Assessment
7. MIDAS - Meteorological Information and Dose Assessment Model
8. NFSA - Nuclear Fuels and Safety Analysis
9. RAE - Radiological Assessment Engineer
10. RDAC - Radiological Dose Assessment Committee
11. RES - Radiological Engineering Section
12. SAM-G - Severe Accident Management Guidelines
13. Millstone Station Emergency Plan: The Millstone Station Emergency Plan contains requirements and organizational responsibilities and serves as the license commitment document for emergency preparedness.
14. Emergency Plan Administrative (EPA)/Functional Administrative Procedure (FAP): Procedures that implement the Station Emergency Plan.

Attachment 2

Summary of Department Responsibilities for Facilities, Equipment, and Material Maintenance

(Sheet 1 of 4)

NOTE

1. D = Daily, W = Weekly, M = Monthly, Q = Quarterly, R = Refuel Outage, A = Annual (not to exceed 25% of surveillance period) AN = As Necessary, AEU = After Each Use. All are also as required by drills, audits, revisions, etc.
2. Maintenance, repair, and test follow up is passed to applicable Unit Maintenance Departments.

Organization	Item	Task	Freq ¹	Reference
Generation Technical Services (GTS)	Public Alerting System	Inspect and Conduct Testing	Q, A	MP-26-EPA-FAP08 MP-26-EPA-FAP09
Chemistry	EOF Multi Channel Analyzer	Inspect and Conduct Testing	AN	RPM; ANSI
Computer Services	ERF Computer Hardware, Software, and Connections	Maintenance, Surveillance, and Control	AN	Help Desk DC 11 MP-26-EPA-FAP05
Telecommunication Services	Pagers, Radios, ENRS	General Support and Testing	AN	C OP 608 C OP 606 MP-26-EPA-FAP01
Document Administration	FSAR, Tech Specs, Aperture Cards	Maintain Control Copies in ERFs	AN	GRITS
Document Administration	Unit - Specific Procedures	Maintain Control Copies in EOF	AN	Passport
Document Administration	EOF and TSC Aperture Card Readers	Update and Check	Q	NDM 04
U-3 Operations	SERO Notification System	Test and Maintain	M	MP-26-EPA-FAP05 C OP 606
Emergency Preparedness	ERF Phone and Fax Equipment	Perform Operability Check	Q	MP-26-EPA-FAP05
Emergency Preparedness	ERF Radios	Perform Operability Check	Q	MP-26-EPA-FAP05

Attachment 2
Summary of Department Responsibilities for Facilities, Equipment, and
Material Maintenance

(Sheet 2 of 4)

Organization	Item	Task	Freq ¹	Reference
Emergency Preparedness	ERF Support Equipment, Furniture, and Supplies	Maintain and Conduct Inventories	Q, AEU	MP-26-EPA-FAP05
Emergency Preparedness	ERF Communications	Surveillance	M	MP-26-EPA-FAP05
Health Physics Support	Emergency Response HP Supplies and Equipment	Maintenance, Surveillance, and Calibration	Q, AEU	RPM 4.8.5
Health Physics Support (Respiratory Protection)	Respiratory Protection Equipment	Maintenance	Q	RPM 2.3.5
Motor Pool	RMT Vehicles	Mechanical and Operational Inspection and Maintenance	Q	
Chemistry Technicians	ERF Dose Assessment Computers	Check Operability	W,M	MP-26-EPA-FAP01 MP-26-EPA-FAP10
Document Administration	Unit - Specific Procedures	Maintain Control Copies in TSC	AN	Passport
Document Administration /EPD	Emergency Preparedness FAPs	Maintain Document Distribution and Control; Audit	AN	Passport
Unit 2 I&C	Meteorological Equipment	Inspect, Calibrate, and Confirm Operability	Q	C SP-400.2
Protective Services	Station Page and Evacuation Siren	Monitor Outside Speakers when Units Conduct Test.	M/Q	C SP 600.1
Protective Services	CR/Security Hot Links	Phone Checks	D	Security Procedure
Site Facilities	Emergency Response Facilities	Building Services (Janitorial, Plumbing, Lighting)	AN	OA 8

Attachment 2

Summary of Department Responsibilities for Facilities, Equipment, and Material Maintenance

(Sheet 3 of 4)

Organization	Item	Task	Freq ¹	Reference
Emergency Preparedness	Millstone EPlan Resource Book	Update	Q	MP-26-EPA-REF08B
I&C; SAB	Radiation Monitors	Maintenance and Calibration; Documentation		
U-2 Operations	Meteorological Tower Generator	Test ²	M	C SP 600.12
U-2 Operations	U-1 PA Speakers	Test	M	C SP 600.1
Station Maintenance	Emergency Operations Facility	Electrical and Mechanical Maintenance of HVAC	Q	Vendor Support Provided
U-2 Operations	EOF Airlock	Test ²	Q	SP 2678C
U-2 Operations	EOF Emergency Diesel Generator	Test ² Operation	M	SP 2678B OP 2399A
U-2 Operations	EOF Fire Detection System	Test ² Operation	Q	SP 2678D OP 2399B
U-2 Operations	EOF Vent (RAD) Filter Systems	Test ²	R	SP 2678A
U-2 Operations	U-2 PA Speakers and Evacuation Alarms	Test	M	C SP 600.1
Station Maintenance	Technical Support Center (TSC)	Electrical and Mechanical Maintenance of HVAC	Q	AWO on 3TS-3900J
Station Maintenance	Technical Support Center (TSC)	Emergency Lights	Q	MP 3780AE
U-3 Operations	TSC Emergency Power (TSC)	Test ²	Q	SP 3666.2
U-3 Operations	TSC Vent (RAD) Filter System	Test ²	R	SP 3666.1
U-3 Operations	U-3 PA Speakers and Evacuation Alarms	Test	M	C SP 600.1

Attachment 2
Summary of Department Responsibilities for Facilities, Equipment, and
Material Maintenance

(Sheet 4 of 4)

Organization	Item	Task	Freq ¹	Reference
Unit Engineering (U-2, 3)	Drawings	Maintain Control Copies in ERFs.	AN	Master Control Index
Unit Operations (U-2, 3)	Radio Communications (Waterford, State, Tri-Town)	Test ²	D	C SP 600.3
Unit Operations (U-3)	Radiopaging ENRS Daily/Weekly Test	Test ²	D, W	C SP 600.4
Unit Operations (U-3)	Radiopaging ENRS Monthly Test	Test ²	M	C OP 606
IT	ERDS, OFIS	General Support and Testing	Q	MP-26-EPA-FAP05 MP-26-EPA-GDL05

Attachment 3

Documentation of Testing of Dose Assessment Computer

(Sheet 1 of 1)

NOTE

IDA is installed in the control rooms and TSC. IDA and other approved dose assessment models such as MIDAS and RASCAL may also be installed on computers in the EOF, TSC, or other ERFs.

Unit Chemistry Technicians

Unit 3

1. Monthly, VERIFY operability of the Technical Support Center Initial Dose Assessment computer and ENSURE results match test case.

Unit 2 and 3

2. Weekly, VERIFY operability of control room initial dose assessment computer program and printer and ENSURE results match test case.
3. COMPLETE surveillance log.
4. IF test results are not satisfactory, NOTIFY EPD.

Attachment 4
SERO Qualifications and Reporting Location (3)
(Sheet 1 of 7)

Position	Code	CAT	LOC	RESP	RAD	SERO Position Owners	Drill Requirements	
							Annual Requal Yes/No	Initial ⁽⁴⁾ Drill/Walk-Thru ⁽⁵⁾
Assistant Director Emergency Operations Facility	ADEOF	MS-AC	EOF	No	No	Director, Nuclear Safety and Licensing	Yes	Drill
Assistant Manager of Radiological Dose Assessment	AMRDA	FS	EOF	No	No	Manager, Radiological Protection and Chemistry	Yes	Drill
Accident Management Team Thermal and Hydraulic Engineer	AMT/TH	FS	TSC/OSC	No	Yes	Manager, Nuclear Fuel Engineering	Yes	Walk-Thru
Accident Management Team Lead	AMTL	FS	TSC/OSC	No	Yes	Manager, Nuclear Fuel Engineering	Yes	Walk-Thru/SAM (8)
Assistant Radiation Protection Supervisor	ARPS	MS-AC	OSC AA	No	Yes	Manager, Radiological Protection and Chemistry	Yes	Walk-Thru
Director of Station Emergency Operations	DSEO	MS-AC	EOF	No	No	Director, Operations and Maintenance	Yes	Drill
EOF Health Physics Technician	EOFHP	MS-OC	EOF	Yes	Yes	Manager, Radiological Protection and Chemistry	Yes	Walk-Thru
EOF Emergency Communicator	EOFEC	MS-AC	EOF	Yes	Yes	Manager, Nuclear Operations	No	Walk-Thru
Chief Technical Spokesperson	CTS	MS-AC	Media Cntr	No	No	Director, Nuclear Safety and Licensing	Yes	Walk-Thru
Fire Brigade/EMT	FB	OS	OSC AA	Yes	Yes	Manager, Nuclear Protection Services	No	Drill (6)
Field Team Data Coordinator	FTDC	FS	EOF	No	No	Manager, Radiological Protection and Chemistry	Yes	Walk-Thru
Generations Technical Services Specialist	GTS	MS-OC	OSC AA	No	Yes	Manager, Nuclear Maintenance	No	Walk-Thru

Category Key:

MS-AC = Minimum Staffing All Call Positions FS = Full Staffing
MS-OC = Minimum Staffing Oncall Positions OS = On Shift

MP-26-EPA-FAP01
Rev. 001
30 of 39

Attachment 4
SERO Qualifications and Reporting Location (3)
(Sheet 2 of 7)

Position	Code	CAT	LOC	RESP	RAD	SERO Position Owners	Drill Requirements	
							Annual Requal Yes/No	Initial ⁽⁴⁾ Drill/Walk-Thru ⁽⁵⁾
Meteorological Assistant	MET	FS	EOF	No	No	Manager, Radiological Protection and Chemistry	Yes	Walk-Thru
Manager of Operational Support Center ⁽¹⁰⁾	MOSC	MS-AC, FS	TSC/OSC	No	Yes	Manager, Nuclear Maintenance	Yes	Drill
Manager of Resources	MOR	MS-AC	EOF	No	No	SCM Site Manager	Yes	Drill
Manager of Security	MOS	FS	TSC/OSC	No	Yes	Manager, Nuclear Protection Services	Yes	Drill
Public Information Technical Advisor	PITA	MS-AC	EOF	No	No	Manager, Emergency Preparedness	Yes	Drill
Manager Radiological Consequence Assessment	MRCA	MS-AC	TSC/OSC	No	Yes	Manager, Radiological Protection and Chemistry	Yes	Drill
Manager of Technical Support Center ⁽¹⁰⁾	MTSC	MS-AC, FS	TSC/OSC	No	Yes	Director, Nuclear Engineering	Yes	Drill
Nuclear News Manager	NNM	MS-AC	Media Cntr	No	No	Director, Nuclear Safety and Licensing	Yes	Drill
CBETS Operator	CBETS	FS	OSC AA	No	Yes	Manager, Radiological Protection and Chemistry	Yes	Walk-Thru
Radiological Communicator	RADCOM	FS	EOF OSC AA	No	Yes	Manager, Radiological Protection and Chemistry	Yes	Walk-Thru
Radiological Assessment Engineer	RAE	FS	EOF	No	No	Manager, Nuclear Fuel Engineering	Yes	Drill
Radiological Monitoring Team 3 Lead	RMT3	MS-OC	EOF	Yes	Yes	Manager, Radiological Protection and Chemistry	Yes	Walk-Thru
Radiological Monitoring Team Driver	RMTDRV	MS-AC	EOF	Yes	Yes	Manager, Nuclear Oversight	Yes	Walk-Thru
Radiological Monitoring Team 4 Lead	RMT4	MS-OC	EOF	Yes	Yes	Manager, Radiological Protection and Chemistry	Yes	Walk-Thru
Radiological Monitoring Team Driver	RMTDRV	MS-AC	EOF	Yes	Yes	Manager, Nuclear Oversight	Yes	Walk-Thru

Category Key:

MS-AC = Minimum Staffing All Call Positions FS = Full Staffing
MS-OC = Minimum Staffing Oncall Positions OS = On Shift

MP-26-EPA-FAP01
Rev. 001
31 of 39

Attachment 4
SERO Qualifications and Reporting Location (3)

(Sheet 3 of 7)

Position	Code	CAT	LOC	RESP	RAD	SERO Position Owners	Drill Requirements	
							Annual Requal Yes/No	Initial ⁽⁴⁾ Drill/Walk-Thru ⁽⁵⁾
Radiological Monitoring Team 5 Lead	RMT5	MS-OC	EOF	Yes	Yes	Manager, Radiological Protection and Chemistry	Yes	Walk-Thru
Radiological Monitoring Team Driver	RMTDRV	MS-AC	EOF	Yes	Yes	Manager, Nuclear Oversight	Yes	Walk-Thru
NAP Radiological Monitoring Team	RMTA	MS-OC	NAP	Yes	Yes	Manager, Radiological Protection and Chemistry	Yes	Walk-Thru
NAP Radiological Monitoring Team	RMTB	MS-OC	NAP	Yes	Yes	Manager, Radiological Protection and Chemistry	Yes	Walk-Thru
SAP Radiological Monitoring Team	RMTC	MS-OC	SAP	Yes	Yes	Manager, Radiological Protection and Chemistry	Yes	Walk-Thru
SAP Radiological Monitoring Team	RMTD	MS-OC	SAP	Yes	Yes	Manager, Radiological Protection and Chemistry	Yes	Walk-Thru
Station Duty Officer	SDO	OS	CR	Yes	Yes	Manager, Nuclear Operations	No	Walk-Thru
Technical Support Center Electrical Engineer ⁽¹⁰⁾	TSCEE	MS-AC, FS	TSC/OSC	No	Yes	Director, Nuclear Engineering	Yes	Walk-Thru
Technical Support Center Mechanical Engineer ⁽¹⁰⁾	TSCME	MS-AC, FS	TSC/OSC	No	Yes	Director, Nuclear Engineering	Yes	Walk-Thru
Technical Support Center Reactor Engineer	TSCRE	MS-AC	TSC/OSC	No	Yes	Manager, Nuclear Fuel Engineering	Yes	Walk-Thru
Technical Assistant	TA	FS	State EOC	No	No	Director, Nuclear Safety and Licensing	Yes	Walk-Thru
Chemistry Technician	CHEM TECH	OS	CR	Yes	Yes	Manager, Radiological Protection and Chemistry	No	Walk-Thru

Category Key:

MS-AC = Minimum Staffing All Call Positions FS = Full Staffing
MS-OC = Minimum Staffing Oncall Positions OS = On Shift

MP-26-EPA-FAP01
Rev. 001
32 of 39

Attachment 4
SERO Qualifications and Reporting Location (3)

(Sheet 4 of 7)

Position	Code	CAT	LOC	RESP	RAD	SERO Position Owners	Drill Requirements	
							Annual Requal Yes/No	Initial ⁽⁴⁾ Drill/ Walk-Thru ⁽⁵⁾
RMT #1	HPTECH	OS	CR	Yes	Yes	Manager, Radiological Protection and Chemistry	No	Walk-Thru
Control Room Emergency Communicator	CREC	OS	CR	Yes	Yes	Manager, Nuclear Operations	Yes	Walk-Thru
Unit 2 Assistant Director Technical Support	U2ADTS	MS-AC	TSC/OSC	No	Yes	Manager, Nuclear Operations	Yes	Drill
Unit 2 Control Room Data Coordinator	U2CRDC	FS	CR	No	Yes	Manager, Nuclear Training	Yes	Walk-Thru
Unit 2 Electrician	U2ELEC	MS-OC	OSC AA	Yes	Yes	Manager, Nuclear Maintenance	No	Walk-Thru
Unit 2 Instrument & Control Operational Support Center	U2I&C OSC	FS	TSC/OSC	No	Yes	Manager, Nuclear Maintenance	Yes	Drill
Unit 2 Instrument & Control Technician	U2I&C TECH	MS-OC	OSC AA	Yes	Yes	Manager, Nuclear Maintenance	No	Walk-Thru
Unit 2 Mechanic	U2MECH	MS-OC	OSC AA	Yes	Yes	Manager, Nuclear Maintenance	No	Walk-Thru
Unit 2 Manager of Communications	U2MOC	MS-AC	EOF	No	No	Manager, Nuclear Training	Yes	Walk-Thru
Unit 2 Operational Support Center Maintenance Assistant	U2 OSMA	FS	TSC/OSC	No	Yes	Manager, Nuclear Maintenance	Yes	Drill
Unit 2 PEO	U2PEO	OS	CR	Yes	Yes	Manager, Nuclear Operations	(1)	(1)
Unit 2 Control Operator	U2CO	OS	CR	Yes	Yes	Manager, Nuclear Operations	(1)	(1)
Unit 2 STA	U2STA	OS	CR	Yes	Yes	Manager, Nuclear Operations	(1)	(1)
Unit 2 Technical Information Coordinator	U2TIC	MS-AC	EOF	No	No	Manager, Nuclear Training	Yes	Walk-Thru
Unit 1/Unit 2 Technical Support Center Shift Manager	U2 TSCSM	FS	TSC/OSC	No	Yes	Manager, Nuclear Operations	No	Walk-Thru

Category Key:

MS-AC = Minimum Staffing All Call Positions FS = Full Staffing
MS-OC = Minimum Staffing Oncall Positions OS = On Shift

MP-26-EPA-FAP01
Rev. 001
33 of 39

Attachment 4
SERO Qualifications and Reporting Location (3)

(Sheet 5 of 7)

Position	Code	CAT	LOC	RESP	RAD	SERO Position Owners	Drill Requirements	
							Annual Requal Yes/No	Initial ⁽⁴⁾ Drill/ Walk-Thru ⁽⁵⁾
Unit 3 Assistant Director Technical Support	U3ADTS	MS-AC	TSC/OSC	No	Yes	Manager, Nuclear Operations	Yes	Drill
Unit 3 Control Room Data Coordinator	U3CRDC	FS	CR	No	Yes	Manager, Nuclear Training	Yes	Walk-Thru
Unit 3 Electrician	U3ELEC	MS-OC	OSC AA	Yes	Yes	Manager, Nuclear Maintenance	No	Walk-Thru
Unit 3 Instrument & Control Operational Support Center	U3I&C OSC	FS	TSC/OSC	No	Yes	Manager, Nuclear Maintenance	Yes	Drill
Unit 3 Instrument & Control Technician	U3I&C TECH	MS-OC	OSC AA	Yes	Yes	Manager, Nuclear Maintenance	No	Walk-Thru
Unit 3 Mechanic	U3MECH	MS-OC	OSC AA	Yes	Yes	Manager, Nuclear Maintenance	No	Walk-Thru
Unit 3 Manager of Communications	U3MOC	MS-AC	EOF	No	No	Manager, Nuclear Training	Yes	Walk-Thru
Unit 3 Operational Support Center Maintenance Assistant	U3 OSCMA	FS	TSC/OSC	No	Yes	Manager, Nuclear Maintenance	Yes	Drill
Unit 3 PEO	U3PEO	OS	CR	Yes	Yes	Manager, Nuclear Operations	(1)	(1)
Unit 3 Control Operator	U3CO	OS	CR	Yes	Yes	Manager, Nuclear Operations	(1)	(1)
Unit 3 STA	U3STA	OS	CR	Yes	Yes	Manager, Nuclear Operations	(1)	(1)
Unit 3 Technical Information Coordinator	U3TIC	MS-AC	EOF	No	No	Manager, Nuclear Training	Yes	Walk-Thru
Unit 3 Technical Support Center Shift Manager	U3 TSCSM	FS	TSC/OSC	No	Yes	Manager, Nuclear Operations	No	Walk-Thru
Unit 2 Unit Supervisor	U2US	OS	CR	Yes	Yes	Manager, Nuclear Operations	(1)	(1)
Unit 3 Unit Supervisor	U3US	OS	CR	Yes	Yes	Manager, Nuclear Operations	(1)	(1)
Security Guard	SECGRD	OS	POST	Yes	Yes	Manager, Nuclear Protection Services	No	(9)

Category Key:

MS-AC = Minimum Staffing All Call Positions FS = Full Staffing
MS-OC = Minimum Staffing Oncall Positions OS = On Shift

MP-26-EPA-FAP01
Rev. 001
34 of 39

Attachment 4
SERO Qualifications and Reporting Location (3)

(Sheet 6 of 7)

Position	Code	CAT	LOC	RESP	RAD	SERO Position Owners	Drill Requirements	
							Annual Requal Yes/No	Initial ⁽⁴⁾ Drill/Walk-Thru
Security Shift Supervisor	SSS	OS	CAS	No	Yes	Manager, Nuclear Protection Services	No	(9)
Manager Radiological Dose Assessment	MRDA	MS-AC	EOF	No	No	Manager, Radiological Protection and Chemistry	Yes	Drill
Unit 1 CFH/MCRO	CFH	OS	CR	Yes	Yes	Manager, Nuclear Operations	No	Walk-Thru
Unit 2 Shift Manager	U2SM	OS	CR	Yes	Yes	Manager, Nuclear Operations	(1)	(1)
Unit 3 Shift Manager	U3SM	OS	CR	Yes	Yes	Manager, Nuclear Operations	(1)	(1)
Alarm Station Supervisor	SECSUP	OS	CAS/SAS	Yes	Yes	Manager, Nuclear Protection Services	No	(9)
Regulatory Liaison (7)	RL	FS	EOF	No	No	Manager, Licensing	No	Walk-Thru
State Emergency Planning Liaison (7)	SEPL	FS	State EOC	No	No	Manager, Emergency Preparedness	No	Walk-Thru
Station Emergency Planning Representative (7)	SEPR	FS	EOF	No	No	Manager, Emergency Preparedness	No	Walk-Thru
Media Center Liaison (7)	MCL	FS	Media Center	No	No	Director, Nuclear Safety and Licensing	No	Walk-Thru
Rumor and Inquiry Control Liaison (7)	RICL	FS	Media Center	No	No	Director, Nuclear Safety and Licensing	No	Walk-Thru
Technical Briefer (7)	TB	FS	Media Center	No	No	Director, Nuclear Safety and Licensing	No	Walk-Thru
Radiological Briefer (7)	RB	FS	Media Center	No	No	Director, Nuclear Safety and Licensing	No	Walk-Thru

Category Key:

MS-AC = Minimum Staffing All Call Positions FS = Full Staffing
MS-OC = Minimum Staffing Oncall Positions OS = On Shift

MP-26-EPA-FAP01
Rev. 001
35 of 39

Attachment 4
SERO Qualifications and Reporting Location (3)

(Sheet 7 of 7)

- (1) Credit will be taken for drill completion when performed as part of Licensed Operator Initial Training (LOIT), Licensed Operator Requalification Training (LORT), Shift Technical Advisor (STA) Program, and Plant Equipment Operator (PEO) Training.
- (2) Deleted
- (3) Additional qualification requirements are contained in NTP 7.212.
- (4) Participation in a drill may satisfy the walk-thru qualifications for initial training.
- (5) Walk-thrus include use of any equipment, identification and location of reference materials, and a knowledge of the facility layout. Training, Emergency Planning, or job incumbents qualify for conducting walk-thrus.
- (6) Tracked by Fire Training Department
- (7) Supplemental positions
- (8) SAM required for initial qualifications
- (9) Security Guard, Security Shift Supervisor (SSS), and Alarm Security Supervisor training is provided by Protective Services personnel.
- (10) One position is minimum staffing, a second position is full staffing.

Category Key:

MS-AC = Minimum Staffing All Call Positions	FS = Full Staffing
MS-OC = Minimum Staffing Oncall Positions	OS = On Shift

MP-26-EPA-FAP01
Rev. 001
36 of 39

Attachment 5

Roles and Responsibilities For Emergency Preparedness Dose Assessment

(Sheet 1 of 2)

Area	Manager, EPD	NFSA
Emergency Plan (Includes Ingestion Pathway Plan)	Manager, EPD, shall: <ul style="list-style-type: none"> • Develop the Emergency Plan • Ensure compliance to regulatory requirements • Request technical support for input and review • Process changes and obtain necessary approvals • Perform necessary 50.54(q) reviews 	NFSA shall: <ul style="list-style-type: none"> • Provide radiological technical expertise requested • Provide compliant support • Support the review and approval process
Radiological Dose Assessment Committee (RDAC)	Manager, EPD, shall: <ul style="list-style-type: none"> • Chair the committee • Develop a charter • Schedule meetings • Develop meeting minutes for RDAC members and upper management • Provide expertise specific to regulatory compliance • Provide input and make contacts to benchmark against the industry • Process change requests 	NFSA shall: <ul style="list-style-type: none"> • Co-chair the committee • Provide input to charter • Provide technical member(s) to the RDAC • Develop technical justification for software / procedure changes • Provide radiological expertise specific to subject matter
Procedures	Manager, EPD, shall: <ul style="list-style-type: none"> • Maintain overall approval or veto of proposed procedures and changes • Ensure compliance to regulatory requirements • Maintain procedures current / schedule biennial reviews if required • Process procedure change requests • Process procedure typing requests • Facilitate writer's guide review by Procedures Group • Perform necessary 50.54(q) reviews • Provide V&V support as necessary • Facilitate scheduling SORC • Set effective implementation dates 	NFSA shall: <ul style="list-style-type: none"> • Provide radiological technical content • Write procedure steps • Provide bases documents • Lead V&V process • Provide V&V input and approvals • Support necessary 50.54(q) review • Present technical changes to SORC for approval

Attachment 5

Roles and Responsibilities For Emergency Preparedness Dose Assessment

(Sheet 2 of 2)

Area	MANAGER, EPD	NFSA
Tools and Software	<p>Manager, EPD, shall:</p> <ul style="list-style-type: none"> • Own required tools and software • Budget new purchases • Fund upgrades and revisions • Ensure compliance to regulatory requirements and intent • Obtain approvals for selected tools and software through RDAC (user) members before committing to a solution, purchase, or change • Own Quality Software (QS) and associated documentation 	<p>NFSA shall:</p> <ul style="list-style-type: none"> • Produce requirements document specifying needs, acceptance criteria and process bids • Recommend the selection of tools and software through the RDAC • Develop internal software (as necessary or as appropriate) • Provide development support • Provide testing • Provide QS documentation • Provide overall radiological technical support
Scenario Development	<p>Manager, EPD, shall:</p> <ul style="list-style-type: none"> • Define scenario radiological package requirements • Develop overall scenario • Provide long-range schedule to allow support resource planning • Define deliverable date for completed package • Provide sufficient lead time for radiological package development 	<p>NFSA shall:</p> <ul style="list-style-type: none"> • Provide an experienced technical lead to develop radiological data packages • Provide support to scenario development meetings • Produce radiological data packages fully meeting expectations • Provide completed radiological data package by the defined deliverable date

Attachment 6

Radiological Dose Assessment Committee

(Sheet 1 of 1)

1. Purpose:

Ensure a regulatory compliant, effective dose assessment capability is maintained at Millstone facilities.

2. Membership:

The following functions shall be represented as members of this committee:

- Emergency Preparedness - Manager, EPD - Chairperson
- Radiological Engineering - Supervisor, Radiological Engineering - Co-chairperson
- Station Health Physics
- Training - EPD Training, Chem/HP training, as available
- Computer Support - Information Technology, as available
- Station Chemistry - as available
- State Department Environmental Protection - as available
- Environmental Services - as available

3. Responsibilities:

This committee is responsible to provide the technical, regulatory based review and recommendations for all changes to calculations methodologies, procedures, software or other tools as applicable to performing the function of off-site dose assessment during emergency situations.

4. Meetings:

This committee shall meet as necessary to review functional status. Meeting notes shall be published and maintained on file in the Emergency Preparedness Department.

5. Authority:

This committee will forward recommended assignments to the Manager, EPD, to assign work to the appropriate organization in order to maintain the full capability of emergency dose assessment. The assigned members shall be sufficiently conversant in the issues to have acceptance authority for their respective organizations.

6. Disposition of Issues:

Issues identified shall be dispositioned through the use of the AITTS assignments. Where disagreement of assignment exist, this issue shall be raised to EPD and NFE management for disposition.