HYDRAZINE SYSTEM SECONDARY

HYDRAZINE SYSTEM PRIMARY (AUXILIARY BUILDING EL 14'-0")

CHEMICAL FEED SAMPLE STATION (C-98B)

TEMPORARY HYDRAZINE HOTWELL INJECTION SYSTEM

NOTES:

1. FOR NOTES, SYMBOLS AND UNIT #2 ABBREVIATIONS SEE 26001 SH. 1, 2 & 3. FOR ALL OTHER ABBREVIATIONS SEE ANSI STANDARD Y1.1.
2. WHEN REQUIRED, A HYDRAZINE SUPPLY DRUM AND HAND PUMP (P-106) ARE HOOKED UP TO THE MEASURING TANK INLET ON TANK (T-6).
3. IN-LINE FILTER WAS DISCONNECTED AND ABANDONED IN PLACE (C-98B).

CHANGES MADE TO THIS P&ID MUST ALSO BE REFLECTED ON THE INSERVICE INSPECTION PROGRAM DRAWING 25203-26700 SH. 27

THIS DRAWING SUPERSEDES IN PART FROM 25203-26031 THRU REV. 27.

OPERATIONS CRITICAL

NON Q.A.

CAD NOTE: MANUAL REVISIONS TO THIS DOCUMENT WHEN AS-BUILT ARE PROHIBITED.

REVISIONS DURING CONSTRUCTION	P.A. NO.

Dominion Nuclear Connecticut Inc.
FOR Millstone Power Station
TITLE MILLSTONE NUCLEAR POWER STATION UNIT - 2
LICENSE RENEWAL DIAGRAM
MISC. CHEMICAL FEED SYSTEM
WATERFORD, CT

BY	CHKD.	APP.	APP.
DATE	DATE	DATE	DATE
SCALE	DWG. NO.	25203-LR26031 SH. 1 OF 2	0

NO.	DATE	REVISIONS	BY	CHK.	APP.	APP.	REV
N/A	00	12-2-02	INITIAL ISSUE PER REV 12	CLW			

ISSUED FOR MASTER DRAWING 25203-26031 SH. 1 OF 2 REV 12

COMPONENTS SUBJECT TO AGING MANAGEMENT REVIEW
2384 CHEMICAL & VOLUME CONTROL
2348B PRIMARY MAKEUP WATER
2319A CONDENSATE
NOTE: SOME SHADED LINES MAY CONTAIN COMPONENTS FROM MORE THAN ONE SYSTEM.

D-079

Submitted by SEKULIC on Monday December 22 2003 at 07:35:23 AM EST