MAIN TRANSFORMER (UPPER LOOP) SEE NOTE 2

MAIN TRANSFORMER (LOWER LOOP) SEE NOTE 2

GAS TURBINE BUILDING ELEV. 14'-6" SEE NOTE 3

LUBE OIL PUMP SKID

YARD

AUXILIARY TRANSFORMER

SHUT-DOWN TRANSFORMER

START-UP TRANSFORMER

(UPPER LOOP)

(MIDDLE AND LOWER LOOP)

RADWASTE SHIPMENT BUILDING EL. 14'-6"

RADWASTE STORAGE BUILDING (COMPACTOR ROOM) EL. 14'-6"

MAINTENANCE SHOP EL. 14'-6"

FOAM TANK (100 GAL.) M7-39

SYSTEM CATEGORIZATION
PROCESS - DEC 1502
LEGEND
BLACK : UNASSESSED
BLUE : AVAILABLE
RED : ABANDONED

SYSTEM CATEGORIZATION
PROCESS - DEC 1502
LEGEND
BLACK : UNASSESSED
BLUE : AVAILABLE
RED : ABANDONED

NOTES:
1. FOR APPLICABLE SYSTEM NOTES SEE DRAWING NUMBER 25202-26019 SH. 2
2. ALL A3YOX TYPE SPRINKLERS INSTALLED ON THE MAIN TRANSFORMER LOOPS WERE SPECIAL ORIENTED WITH A SPRAY ANGLE OF 75°
3. FOR GAS TURBINE GENERATOR CO. FIRE PROTECTION SYSTEM REFERENCE DWG. NO. 25202-26028 SH. 2 (8-11)
4. CMS ALARMS SHOW ON DWG 25202-30091.

OPERATIONS CRITICAL

THIS DRAWING PARTIALLY SUPERSEDES DWG. NO. 25202-26018 REV. 54

Q.A.

CAD
NOTE: ORIGINAL REVISIONS TO THIS DOCUMENT WHEN AS-BUILT ARE PROHIBITED.

REVISIONS DURING CONSTRUCTION	P.A. NO.

Dominion Nuclear Connecticut Inc.
FOR Millstone Power Station
TITLE MILLSTONE NUCLEAR POWER STATION - UNIT 1
LICENSE RENEWAL DIAGRAM
FIRE PROTECTION SYSTEM
(RADWASTE STORAGE, GAS TURBINE BLDGS. & YARD)
WATERFORD, CT.

BY	CHKD.	APP.
DATE	DATE	DATE
SCALE	DWG. NO.	
	25202-LR26019 SH. 3	0

NO.	DATE	REVISIONS	BY	CHK.	APP.	REV
N/A	00	2-26-02	INITIAL ISSUE PER REV 18	CLW		

ISSUED PER MASTER DRAWING 25202-26019 SH. 3 REV 18

COMPONENTS SUBJECT TO AGING MANAGEMENT REVIEW
3341 FIRE PROTECTION SYSTEM
NOTE: SOME SHADED LINES MAY CONTAIN COMPONENTS FROM MORE THAN ONE SYSTEM.

0098

Submitted by AHLUWALIAC on Wednesday January 07 2004 at 12:27:36 PM EST