

February 2, 2004

LICENSEE: Energy Northwest

FACILITY: Columbia Generating Station

SUBJECT: SUMMARY OF JANUARY 13, 2004, MEETING WITH ENERGY NORTHWEST  
ON THE SHUTDOWN COOLING ISOLATION REPORTABILITY

On January 13, 2004, representatives of Energy Northwest met with the NRC staff to discuss recent shutdown cooling isolation reportability issues for the Columbia Generating Station.

Energy Northwest began the meeting by providing background information of the two shutdown cooling isolation events that occurred during the Spring 2003 refueling outage. A detailed explanation of the actions and the conservative nature of those actions followed. Energy Northwest proposed that the events were not reportable based on a number of factors:

- the Technical Specifications allowed the system to be shut down for two of every eight hours,
- the situations covered under 10 CFR 50.73, which would be reported, were not a result of the isolations, and
- the system could be manually restored if needed.

The staff discussed the interpretation that was made from NUREG-1022, "Event Reporting Guidelines 10 CFR 50.72 and 50.73." Energy Northwest presented additional information in the form of a consultant's letter. The staff accepted the letter and agreed to review the licensee's explanation of the basis for retracting the event notification. The meeting concluded with the staff expressing their appreciation for the presentation.

An attendance list is provided in the enclosure. The slides and the contractor's letter used during the meeting are available in ADAMS under accession number ML040140447.

Docket No. 50-397

Enclosure: Meeting Attendees

cc w/encl: See next page

February 2, 2004

LICENSEE: Energy Northwest

FACILITY: Columbia Generating Station

SUBJECT: SUMMARY OF JANUARY 13, 2004, MEETING WITH ENERGY NORTHWEST ON THE SHUTDOWN COOLING ISOLATION REPORTABILITY

On January 13, 2004, representatives of Energy Northwest met with the NRC staff to discuss recent shutdown cooling isolation reportability issues for the Columbia Generating Station.

Energy Northwest began the meeting by providing background information of the two shutdown cooling isolation events that occurred during the Spring 2003 refueling outage. A detailed explanation of the actions and the conservative nature of those actions followed. Energy Northwest proposed that the events were not reportable based on a number of factors:

- the Technical Specifications allowed the system to be shut down for two of every eight hours,
- the situations covered under 10 CFR 50.73, which would be reported, were not a result of the isolations, and
- the system could be manually restored if needed.

The staff discussed the interpretation that was made from NUREG-1022, "Event Reporting Guidelines 10 CFR 50.72 and 50.73." Energy Northwest presented additional information in the form of a consultant's letter. The staff accepted the letter and agreed to review the licensee's explanation of the basis for retracting the event notification. The meeting concluded with the staff expressing their appreciation for the presentation.

An attendance list is provided in the enclosure. The slides and the contractor's letter used during the meeting are available in ADAMS under accession number ML040140447.

Docket No. 50-397

Enclosure: Meeting Attendees

cc w/encl: See next page

DISTRIBUTION:

PUBLIC	RidsNrrLAEPeyton
PDIV-2 Reading	RidsAcrsAcnwMailCenter
RidsNrrDlpm (TMarsh/ELeeds)	RidsOgcRp
RidsNrrDlpmLpdiv (HBerkow)	RidsNrrPMBBenney
ABoland, EDO	SLee
BJones, Region IV	TReis
TMensha	

**Package: ML040310012**

**Meeting Notice No.: ML033630385**

**ADAMS Accession No.: ML040310011**

OFFICE	PDIV-2/PM	PDIV-2/LA	PDIV-2/SC
NAME	BBenney:esp	EPeyton	SDembek
DATE	01/29/04	1/29/04	01/30/04

OFFICIAL RECORD COPY

**MEETING WITH ENERGY NORTHWEST**

**JANUARY 13, 2004**

**ATTENDANCE LIST**

**ENERGY NORTHWEST**

D. Coleman  
C. Sly

**NRC**

B. Benney  
T. Reis  
S. Lee

Columbia Generating Station

cc:

Mr. Dale Atkinson (Mail Drop PE08)  
Vice President, Technical Services  
Energy Northwest  
P.O. Box 968  
Richland, WA 99352-0968

Mr. Rodney L. Webring (Mail Drop PE04)  
Vice President, Nuclear Generation  
Energy Northwest  
P.O. Box 968  
Richland, WA 99352-0968

Mr. Albert E. Mouncer (Mail Drop PE01)  
Vice President, Corporate Services/  
General Counsel/CFO  
Energy Northwest  
P.O. Box 968  
Richland, WA 99352-0968

Thomas C. Poindexter, Esq.  
Winston & Strawn  
1400 L Street, N.W.  
Washington, DC 20005-3502

Chairman  
Energy Facility Site Evaluation Council  
P.O. Box 43172  
Olympia, WA 98504-3172

Mr. Bob Nichols  
Executive Policy Division  
Office of the Governor  
P.O. Box 43113  
Olympia, WA 98504-3113

Mr. D. W. Coleman (Mail Drop PE20)  
Manager, Performance Assessment  
and Regulatory Programs  
Energy Northwest  
P.O. Box 968  
Richland, WA 99352-0968

Ms. Lynn Albin  
Washington State Department of Health  
P.O. Box 7827  
Olympia, WA 98504-7827

Ms. Christina Perino (Mail Drop PE20)  
Manager, Licensing  
Energy Northwest  
P.O. Box 968  
Richland, WA 99352-0968

Mr. J. V. Parrish  
Chief Executive Officer  
Energy Northwest  
P.O. Box 968 (Mail Drop 1023)  
Richland, WA 99352-0968

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 400  
Arlington, TX 76011-4005

Chairman  
Benton County Board of Commissioners  
P.O. Box 190  
Prosser, WA 99350-0190

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
P.O. Box 69  
Richland, WA 99352-0069