

NOP-LP-2001-09		Corrective Action Due Date Extension	
CR #: 02-00921	CA #: 7	Requested Due Date: 9/30/2003	
Extension Number: 1		Category: CF	
Reason for Extension:			
Westinghouse analysis will take 3 months from TA approval. A TA has not yet been approved.			
Justification:			
Plant continues to operate within its design bases. Also, similar analyses for Unit 1 yielded an allowable AFW delay time of 30 minutes for a fire that requires control room evacuation. Similar results are expected for Unit 2. Since the process of initiating AFW for Unit 2 is less work intensive than for Unit 1 (because of the dedicated AFW pump), actual operator response time is expected to be well within 30 minutes.			
Requestor: WOOD, WT		Requestor Date: 5/22/2003	
Approver: Manoleras, M	Approver Date: 5/23/2003	<input checked="" type="checkbox"/> Accept <input type="checkbox"/> Reject	

RR/6