

## Industry/TSTF Standard Technical Specification Change Traveler

**Delete extraneous Action from Refueling Cavity Water Level**

Priority/Classification 2) Consistency/Standardization

NUREGs Affected: ☒ 1430 ☒ 1431 ☒ 1432 ☐ 1433 ☐ 1434

Description:

Delete Required Action A.3 from LCO 3.9.7, Refueling Cavity Water Level.

Justification:

Completion of Required Actions A.1 and A.2 result in exiting the Mode of Applicability. Therefore, A.3 is unnecessary.

### Revision History

**OG Revision 0**

**Revision Status: Active**

**Next Action:**

Revision Proposed by: Ginna

Revision Description:

Original Issue

### Owners Group Review Information

Date Originated by OG: 02-Nov-95

Owners Group Comments  
(No Comments)

Owners Group Resolution: Approved Date: 02-Nov-95

### TSTF Review Information

TSTF Received Date: 02-Nov-95

Date Distributed for Review 02-Nov-95

OG Review Completed: ☒ BWOG ☒ WOG ☒ CEOG ☒ BWROG

TSTF Comments:

(No Comments)

TSTF Resolution: Approved Date: 14-Nov-95

### NRC Review Information

NRC Received Date: 16-Nov-95

NRC Reviewer: M. Weston

NRC Comments:

2/20/96 - Reviewer approved change.

3/4/96 package to C. Grimes to review.

6/11/96 - C. Grimes comment: TSTF-20 to be referred to a Tech Br.

9/18/96 - Pending due to concerns over intruding on NRC generic spent fuel pool issues. Will consider on plant specific basis for now.

10/30/96 - Awaiting SRXB review.

11/13/96 - SRXB returned with comment.

2/3/97 - To C. Grimes for disposition.

3/13/97 - NRC approves.

Final Resolution: NRC Approves

Final Resolution Date: 13-Mar-97

4/2/98

---

**Incorporation Into the NUREGs**

File to BBS/LAN Date:

TSTF Informed Date:

TSTF Approved Date:

NUREG Rev Incorporated:

---

**Affected Technical Specifications**

Action 3.9.6.A	Refueling Canal Water Level	NUREG(s)- 1430 Only
Action 3.9.6.A Bases	Refueling Canal Water Level	NUREG(s)- 1430 Only
Action 3.9.7.A	Refueling Cavity Water Level	NUREG(s)- 1431 Only
Action 3.9.7.A Bases	Refueling Canal Water Level	NUREG(s)- 1431 Only
Action 3.9.6.A	Refueling Water Level	NUREG(s)- 1432 Only
Action 3.9.6.A Bases	Refueling Water Level	NUREG(s)- 1432 Only

---

---

4/2/98

### 3.9 REFUELING OPERATIONS

#### 3.9.6 Refueling Canal Water Level

LC0 3.9.6 Refueling canal water level shall be maintained  $\geq 23$  ft above the top of the reactor vessel flange.

APPLICABILITY: During CORE ALTERATIONS, except during latching and unlatching of CONTROL ROD drive shafts, During movement of irradiated fuel assemblies within containment.

#### ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Refueling cavity water level not within limit.	A.1 Suspend CORE ALTERATIONS.	Immediately
	<u>AND</u>	
	A.2 Suspend movement of irradiated fuel assemblies within containment.	Immediately
TSTF-20	<u>AND</u>	
	<del>A.3 Initiate action to restore refueling cavity water level to within limit.</del>	<del>Immediately</del>

BASES (continued)

---

LCO                      A minimum refueling cavity water level of 23 ft above the reactor vessel flange is required to ensure that the radiological consequences of a postulated fuel handling accident inside containment are within acceptable limits as provided by 10 CFR 100.

---

APPLICABILITY        LCO 3.9.6 is applicable during CORE ALTERATIONS, except during latching and unlatching of CONTROL ROD drive shafts, and when moving irradiated fuel assemblies within the containment. The LCO minimizes the possibility of a fuel handling accident in containment that is beyond the assumptions of the safety analysis. If irradiated fuel is not present in containment, there can be no significant radioactivity release as a result of a postulated fuel handling accident. Requirements for fuel handling accidents in the spent fuel pool are covered by LCO 3.7.14, "Fuel Storage Pool Water Level."

---

ACTIONS

A.1 and A.2

With a water level of < 23 ft above the top of the reactor vessel flange, all operations involving CORE ALTERATIONS or movement of irradiated fuel assemblies shall be suspended immediately to ensure that a fuel handling accident cannot occur.

The suspension of CORE ALTERATIONS and fuel movement shall not preclude completion of movement of a component to a safe position.

A.3

In addition to immediately suspending CORE ALTERATIONS or movement of irradiated fuel, action to restore refueling cavity water level must be initiated immediately.

---

(continued)

### 3.9 REFUELING OPERATIONS

#### 3.9.6 Refueling Water Level

LCO 3.9.6 Refueling water level shall be maintained  $\geq 23$  ft above the top of reactor vessel flange.

APPLICABILITY: During CORE ALTERATIONS, except during latching and unlatching of control rod drive shafts,  
During movement of irradiated fuel assemblies within containment.

#### ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Refueling water level not within limit.	A.1 Suspend CORE ALTERATIONS.	Immediately
	<u>AND</u>	
	A.2 Suspend movement of irradiated fuel assemblies within containment.	Immediately
TSTF-20	<u>AND</u>	
	A.3 Initiate action to restore refueling cavity water level to within limit.	Immediately

#### SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.9.6.1 Verify refueling water level is $\geq 23$ ft above the top of reactor vessel flange.	24 hours

BASES (continued)

---

LCO                      A minimum refueling water level of 23 ft above the reactor vessel flange is required to ensure that the radiological consequences of a postulated fuel handling accident inside containment are within acceptable limits as provided by the guidance of Reference 3.

---

APPLICABILITY        LCO 3.9.6 is applicable during CORE ALTERATIONS, except during latching and unlatching of control rod drive shafts, and when moving fuel assemblies in the presence of irradiated fuel assemblies. The LCO minimizes the possibility of a fuel handling accident in containment that is beyond the assumptions of the safety analysis. If irradiated fuel is not present in containment, there can be no significant radioactivity release as a result of a postulated fuel handling accident. Requirements for fuel handling accidents in the spent fuel pool are covered by LCO 3.7.10, "Fuel Storage Pool Water Level."

---

ACTIONS

A.1 and A.2

With a water level of < 23 ft above the top of the reactor vessel flange, all operations involving CORE ALTERATIONS or movement of irradiated fuel assemblies shall be suspended immediately to ensure that a fuel handling accident cannot occur.

The suspension of CORE ALTERATIONS and fuel movement shall not preclude completion of movement of a component to a safe position.

A.3

In addition to immediately suspending CORE ALTERATIONS or movement of irradiated fuel, action to restore refueling cavity water level must be initiated immediately.

TSTF-20

---

(continued)

### 3.9 REFUELING OPERATIONS

#### 3.9.7 Refueling Cavity Water Level

LC0 3.9.7 Refueling cavity water level shall be maintained  $\geq$  23 ft above the top of reactor vessel flange.

APPLICABILITY: During CORE ALTERATIONS, except during latching and unlatching of control rod drive shafts,  
During movement of irradiated fuel assemblies within containment.

#### ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Refueling cavity water level not within limit.	A.1 Suspend CORE ALTERATIONS.	Immediately
	<u>AND</u>	
	A.2 Suspend movement of irradiated fuel assemblies within containment.	Immediately
TSTF-20	<u>AND</u>	
	A.3 Initiate action to restore refueling cavity water level to within limit.	Immediately

BASES

---

APPLICABLE  
SAFETY ANALYSES  
(continued)

Refueling cavity water level satisfies Criterion 2 of the NRC Policy Statement.

---

LCO

A minimum refueling cavity water level of 23 ft above the reactor vessel flange is required to ensure that the radiological consequences of a postulated fuel handling accident inside containment are within acceptable limits, as provided by the guidance of Reference 3.

---

APPLICABILITY

LCO 3.9.7 is applicable during CORE ALTERATIONS, except during latching and unlatching of control rod drive shafts, and when moving irradiated fuel assemblies within containment. The LCO minimizes the possibility of a fuel handling accident in containment that is beyond the assumptions of the safety analysis. If irradiated fuel assemblies are not present in containment, there can be no significant radioactivity release as a result of a postulated fuel handling accident. Requirements for fuel handling accidents in the spent fuel pool are covered by LCO 3.7.15, "Fuel Storage Pool Water Level."

---

ACTIONS

A.1 and A.2

With a water level of < 23 ft above the top of the reactor vessel flange, all operations involving CORE ALTERATIONS or movement of irradiated fuel assemblies within the containment shall be suspended immediately to ensure that a fuel handling accident cannot occur.

The suspension of CORE ALTERATIONS and fuel movement shall not preclude completion of movement of a component to a safe position.

A.3

In addition to immediately suspending CORE ALTERATIONS or movement of irradiated fuel, action to restore refueling cavity water level must be initiated immediately.

TSTF-20

(continued)