February 26, 2004

MEMORANDUM TO: Laura A. Dudes, Section Chief

New Reactors Section

New, Research and Test Reactors Program

Division of Regulatory Improvement Programs, NRR

Office of Nuclear Reactor Regulation

FROM: Amy Cubbage, Project Manager /RA/

New Reactors Section

New. Research and Test Reactors Program

Division of Regulatory Improvement Programs, NRR

Office of Nuclear Reactor Regulation

SUBJECT: JANUARY 13, 2004, AP1000 TELEPHONE CONFERENCE CALL

SUMMARY

On Tuesday, January 13, 2004, a telephone conference call was held with Westinghouse Electric Company (Westinghouse) representatives and Nuclear Regulatory Commission (NRC) staff to discuss issues related to reactor coolant pressure boundary materials. The NRC staff specifically discussed open item (OI) 5.2.3-3, which was raised by the NRC in a letter dated September 3, 2003 (ML032330275). Westinghouse responded to this open item by letter dated September 8, 2003 (ML032530326). By e-mail sent to Westinghouse on October 28, 2003, (Attachment 1), the NRC staff requested additional information. A list of call participants is included in Attachment 2.

The following is a brief summary of the discussion regarding the staff's request for additional information concerning OI 5.2.3-3:

- a) Westinghouse stated that the hydrogen concentration is 25 to 50 cm³ per kg of water at standard temperature and pressure. This was provided by Westinghouse in the AP1000 design control document (DCD) table 5.2-2.
- b) The NRC staff stated that the question had been broadened because Westinghouse indicated that this was not a pressurized thermal shock (PTS) issue. Westinghouse stated that they would provide a response to this question.
- c) The NRC staff indicated that the DCD was not clear with respect to the material composition of the weld. Westinghouse stated that they would review the issue further.

L. Dudes -2-

d) The NRC staff requested additional detail to quantify the effects. Westinghouse stated that they would revise the OI response and either revise the DCD or provide a justification for not revising the DCD.

Docket No. 52-006

Attachments: As stated

L. Dudes -2-

d) The NRC staff requested additional detail to quantify the effects. Westinghouse stated that they would revise the OI response and either revise the DCD or provide a justification for not revising the DCD.

Docket No. 52-006

Attachments: As stated

Distribution:
Hard Copy
RNRP R/F
JLyons
ACubbage
LDudes
JSegala
JColaccino

E-mail RWeisman, OGC

PUBLIC MMitchell
DMatthews ESullivan
JMoore, OGC SCoffin

ACCESSION NUMBER: ML040370037

OFFICE	RNRP:PM	RNRP:PM	EMCB:SC	RNRP:SC
NAME	ACubbage	JColaccino	SCoffin	LDudes
DATE	2/10/04	2/13/04	2/23/04	2/26/04

Staff Comments on Open Item 5.2.3-3 E-Mailed to Westinghouse on October 28, 2003

The staff has reviewed your September 8, 2003, response on lowered fracture toughness of Alloy 690/52/152 materials after exposure to hydrogenated water. For the staff to evaluate this information, the staff needs the following additional information.

- a. Provide the H₂ concentration of the reactor coolant at normal plant operating conditions.
- b. For a simulated Pressurized Thermal Shock transient, what temperature levels would the most susceptible bi-metallic welds reach? What bi-metallic welds in the reactor coolant system would experience the most significant cooldown effect?
- c. Provide a schematic drawing of welds at these locations. For example, describe whether these welds would consist of Alloy 52 material through the entire wall, or Alloy 52 in contact with the reactor coolant and Alloy 82/182 for the remainder of the wall thickness.
- d. Assume a small ID surface breaking flaw in the bi-metallic weld identified in parts b. and c. above. Evaluate what conditions and effects the flaw would see as a result of a simulated Pressurized Thermal Shock transient (i.e., hydrogen concentration, final temperature, loading rate, and failure potential).

JANUARY 13, 2003 TELEPHONE CONFERENCE CALLS SUMMARY LIST OF PARTICIPANTS

Nuclear Regulatory Commission	<u>Westinghouse</u>
J. Colaccino	R. Gold
M. Mitchell	R. Vijuk
T. Sullivan	W. Banford

CC:

Mr. W. Edward Cummins AP600 and AP1000 Projects Westinghouse Electric Company P.O. Box 355 Pittsburgh, PA 15230-0355

Mr. H. A. Sepp Westinghouse Electric Company P.O. Box 355 Pittsburgh, PA 15230

Lynn Connor
Doc-Search Associates
2211 SW 1ST Ave - #1502
Portland, OR 97201

Barton Z. Cowan, Esq. Eckert Seamans Cherin & Mellott, LLC 600 Grant Street 44th Floor Pittsburgh, PA 15219

Charles Brinkman, Director Washington Operations Westinghouse Electric Company 12300 Twinbrook Parkway, Suite 330 Rockville, MD 20852

Mr. R. Simard Nuclear Energy Institute 1776 I Street NW Suite 400 Washington, DC 20006

Mr. Thomas P. Miller U.S. Department of Energy Headquarters - Germantown 19901 Germantown Road Germantown, MD 20874-1290

Mr. David Lochbaum Nuclear Safety Engineer Union of Concerned Scientists 1707 H Street NW, Suite 600 Washington, DC 20006-3919

Mr. Paul Gunter Nuclear Information & Resource Service 1424 16th Street, NW., Suite 404 Washington, DC 20036

Mr. Tom Clements 6703 Guide Avenue Takoma Park, MD 20912 Mr. James Riccio Greenpeace 702 H Street, NW, Suite 300 Washington, DC 20001

Mr. James F. Mallay, Director Regulatory Affairs FRAMATOME, ANP 3315 Old Forest Road Lynchburg, VA 24501

Mr. Ed Wallace, General Manager Projects PBMR Pty LTD PO Box 9396 Centurion 0046 Republic of South Africa

Mr. Vince Langman Licensing Manager Atomic Energy of Canada Limited 2251 Speakman Drive Mississauga, Ontario Canada L5K 1B2

Mr. Gary Wright, Manager Office of Nuclear Facility Safety Illinois Department of Nuclear Safety 1035 Outer Park Drive Springfield, IL 62704

Dr. Gail H. Marcus U.S. Department of Energy Room 5A-143 1000 Independence Ave., SW Washington, DC 20585

Mr. Paul Leventhal Nuclear Control Institute 1000 Connecticut Avenue, NW Suite 410 Washington, DC 20036

Mr. Jack W. Roe SCIENTECH, INC. 910 Clopper Road Gaithersburg, MD 20878

Patricia Campbell Winston & Strawn 1400 L Street, NW Washington, DC 20005 Mr. David Ritter
Research Associate on Nuclear Energy
Public Citizens Critical Mass Energy
and Environmental Program
215 Pennsylvania Avenue, SE
Washington, DC 20003

Mr. Ronald P. Vijuk Manager of Passive Plant Engineering AP1000 Project Westinghouse Electric Company P. O. Box 355 Pittsburgh, PA 15230-0355