

Industry/TSTF Standard Technical Specification Change Traveler

Revise the wording of SR 3.0.2 to be consistent with the other NUREGs

Priority/Classification 2) Consistency/Standardization

NUREGs Affected: 1430 1431 1432 1433 1434

Description:

Delete the phrase "Required Action requires performance of a surveillance or its" so that SR 3.0.2 would read: "If a Completion Time requires periodic performance on a "once per..." basis, the above Frequency extension applies to each performance after the initial performance."

Justification:

The deleted phrase is unnecessary and potentially confusing. It is unnecessary since all "Once per..." basis requirements for Required Actions are in the Completion Time column. The deleted phrase is potentially confusing since it could be read to imply that the extension could only be applied if the periodic Required Action is a Surveillance. The proposed wording provides all the information that is necessary to correctly apply the extension. The proposed wording is consistent with NUREGs 1431, 1432, 1433, and 1434.

Revision History

OG Revision 0

Revision Status: Active

Next Action:

Revision Proposed by: ANO-1

Revision Description:
Original Issue

Owners Group Review Information

Date Originated by OG: 24-Aug-95

Owners Group Comments
(No Comments)

Owners Group Resolution: Approved Date: 08-Sep-95

TSTF Review Information

TSTF Received Date: 22-Sep-95 Date Distributed for Review 03-Oct-95

OG Review Completed: BWOG WOG CEOG BWROG

TSTF Comments:
N/A - WOG, CEOG, BWR/4, BWR/6

TSTF Resolution: Approved Date: 25-Nov-95

NRC Review Information

NRC Received Date: 03-Jan-96 NRC Reviewer: N. Gilles

NRC Comments:
6/11/96 - C. Grimes comment: decision not made on TSTF-42.
9/18/96 - Approved.

Final Resolution. NRC Approves

Final Resolution Date: 18-Sep-96

4/2/98

Incorporation Into the NUREGs

File to BBS/LAN Date:

TSTF Informed Date: 14-Feb-97

TSTF Approved Date:

NUREG Rev Incorporated:

Affected Technical Specifications

SR 3.0.2

SR Applicability

4/2/98

3.0 SURVEILLANCE REQUIREMENT (SR) APPLICABILITY

SR 3.0.1 SRs shall be met during the MODES or other specified conditions in the Applicability for individual LCOs, unless otherwise stated in the SR. Failure to meet a Surveillance, whether such failure is experienced during the performance of the Surveillance or between performances of the Surveillance, shall be failure to meet the LCO. Failure to perform a Surveillance within the specified Frequency shall be failure to meet the LCO except as provided in SR 3.0.3. Surveillances do not have to be performed on inoperable equipment or variables outside specified limits.

SR 3.0.2 The specified Frequency for each SR is met if the Surveillance is performed within 1.25 times the interval specified in the Frequency, as measured from the previous performance or as measured from the time a specified condition of the Frequency is met.

For Frequencies specified as "once," the above interval extension does not apply.

~~If a Required Action requires performance of a surveillance or its Completion Time requires periodic performance on a "once per . . ." basis, the above Frequency extension applies to each performance after the initial performance.~~

Exceptions to this Specification are stated in the individual Specifications.

SR 3.0.3 If it is discovered that a Surveillance was not performed within its specified Frequency, then compliance with the requirement to declare the LCO not met may be delayed, from the time of discovery, up to 24 hours or up to the limit of the specified Frequency, whichever is less. This delay period is permitted to allow performance of the Surveillance.

If the Surveillance is not performed within the delay period, the LCO must immediately be declared not met, and the applicable Condition(s) must be entered.

When the Surveillance is performed within the delay period and the Surveillance is not met, the LCO must immediately be

(continued)
