

February 10, 2004  
EN-04-005

OFFICE OF ENFORCEMENT  
NOTIFICATION OF SIGNIFICANT ENFORCEMENT ACTION

Licensee: TXU Energy (EA-04-009)  
Comanche Peak Steam Electric Station  
Docket No. 50-445

Subject: ISSUANCE OF FINAL SIGNIFICANCE DETERMINATION AND NOTICE OF VIOLATION

This is to inform the Commission that a Notice of Violation associated with a White Significance Determination Process (SDP) finding will be issued on or around February 13, 2004, to TXU Energy as a result of inspections at the Comanche Peak Steam Electric Station. This White finding, an issue with low to moderate increased importance to safety, involved the failure to identify and correct an indicated flaw in a steam generator tube during Refueling Outage 1RF08, a violation of 10CFR50, Appendix B, Criterion XVI. Failure to remove the tube from service resulted in a steam generator tube leak in September 2002. Accordingly, a Notice of Violation associated with the White finding is being issued.

It should be noted that the licensee has not been specifically informed of the enforcement action. The schedule of issuance and notification is:

Mailing of Final Significance Determination	February 13, 2004
Telephone Notification of Licensee	February 13, 2004

The State of Texas will be notified.

Contacts: J. Dixon-Herrity, OE, 415-1980 J. Luehman, OE, 415-2741

Distribution:

<u>OWFN</u>	<u>OWFN</u>	<u>TWFN</u>	<u>Regional Offices</u>	
Chairman Diaz	EDO	OCFO	RI	RII
Comm. McGaffigan	DEDR	OP CENTER	RIII	RIV
Comm. Merrifield	DEDE	NMSS		
SECY	OE	NSIR		
OCA	OGC	OIG	<u>MAIL</u>	
PA	NRR	OCIO	ADAMS	
IP	OI	RES		
	SP	ACRS		

ADAMS Accession No.: ML040410604

OFFICE	OE-ES	OE
NAME	JDixon-Herrity	JLuehman
DATE	2/10/04	2/10/04