

Industry/TSTF Standard Technical Specification Change Traveler

Clarification of Action B when RCS loops are filled in Mode 5

Priority/Classification 1) Correct Specifications

NUREGs Affected: ☒ 1430 ☐ 1431 ☒ 1432 ☐ 1433 ☐ 1434

Description:

Make clear that the Condition applies when more than one train (or loop) is inoperable by adding an "s" to "train" or "loop"

Justification:

The Bases for Action 3.4.7.B states that this Action applies when no Shutdown Cooling trains (or DHR Loops) are operable. However, the Action states "Required SDC train (DHR loop) inoperable" (note the singular use of "train" and "loop"). This is the same as Action A (which the Bases describe as applying when one SDC train or DHR loop is inoperable). To correct this error, Action B was revised to state "trains" and "loops"

Revision History

OG Revision 0

Revision Status: Active

Next Action:

Revision Proposed by: Calvert Cliffs

Revision Description:
Original Issue

Owners Group Review Information

Date Originated by OG: 17-Jan-96

Owners Group Comments
(No Comments)

Owners Group Resolution: Approved Date: 24-Jan-96

TSTF Review Information

TSTF Received Date: 05-Mar-96 Date Distributed for Review 07-Mar-96

OG Review Completed: ☒ BWOG ☒ WOG ☒ CEOG ☒ BWROG

TSTF Comments:

Already in WOG.
Applicable to BWOG

TSTF Resolution: Approved Date: 16-Apr-96

NRC Review Information

NRC Received Date: 12-Jun-96 NRC Reviewer: M. Weston

NRC Comments:
9/18/96 - Approved.

Final Resolution: NRC Approves

Final Resolution Date: 18-Sep-96

Incorporation Into the NUREGs

4/2/98

File to BBS/LAN Date:

TSTF Informed Date: 11-Mar-97

TSTF Approved Date:

NUREG Rev Incorporated:

Affected Technical Specifications

Action 3.4.7.B

RCS Loops - Mode 5, Loops Filled

4/2/98

TSTF-63

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. One SDC train inoperable.</p> <p><u>AND</u></p> <p>Any SG with secondary side water level not within limit.</p>	<p>A.1 Initiate action to restore a second SDC train to OPERABLE status.</p>	Immediately
	<p><u>OR</u></p> <p>A.2 Initiate action to restore SG secondary side water levels to within limits.</p>	Immediately
<p>B. Required SDC train^S inoperable.</p> <p><u>OR</u></p> <p>No SDC train in operation.</p>	<p>B.1 Suspend all operations involving reduction in RCS boron concentration.</p>	Immediately
	<p><u>AND</u></p> <p>B.2 Initiate action to restore one SDC train to OPERABLE status and operation.</p>	Immediately