		(WOG-27, Rev. 0)	TSTF-99			
Industry/TSTF Standard Tec	nnical Speci	fication Change Travele	er			
Extend the Completion Time for Fq(w) not within	imits from 2 ho	urs to 4 hours				
Priority/Classification 2) Consistency/Standardizati	n					
NUREGS Affected: 1430 🗹 1431 🗌 14	2 🗌 1433	1434				
Description:						
The Completion Time for LCO 3.2.1B, Required Act	on B.1 has been of	extended from 2 hours to 4 hours.				
This change is being proposed to be consistent with t 3.2.1.A	e Completion Ti	me associated with Required Action	n A.2 of LCO			
Revision History						
OG Revision 0 Revision St	tus: Active	Next Action:				
Revision Proposed by:						
Revision Description: Original Issue						
<b>Owners Group Review Information</b> Date Originated by OG: 27-Nov-95						
Owners Group Comments (No Comments)						
Owners Group Resolution: Approved	Date: 27-Nov-95	; 				
• TSTF Review Information						
TSTF Received Date: 27-Nov-95	TSTF Received Date: 27-Nov-95 Date Distributed for Review 27-Nov-95					
OG Review Completed: 🗹 BWOG 🗹 W	OG Review Completed: 🗹 BWOG 🗹 WOG 🗹 CEOG 🗹 BWROG					
TSTF Comments:						
NA CEOG, BWOG, BWRs						
TSTF Resolution: Approved Date:	-Apr-96					
NRC Review Information NRC Received Date: 17-Jul-96 NRC Comments:	NRC Reviewer:	R. Tjader				
9/18/96 - Approved						
Final Resolution: NRC Approves		Final Resolution Date: 18	I-Sep-96			
Incorporation Into the NUREGs						
File to BBS/LAN Date: TSTF Info	ned Date:	TSTF Approved Date:				
NUREG Rev Incorporated:						
		······································				

Traveler Rev. 2. Copyright (C) 1997, Excel Services Corporation. Use by Excel Services associates, utility clients, and the U.S. Nuclear Regulatory Commission is granted. All other use without written permission is prohibited.

#### **Affected Technical Specifications** Action 3.2.1B.B

Fq(z) (Fq Methodology)

Action 3.2.1B.B Bases Fq(z) (Fq Methodology)

Traveler Rev. 2. Copyright (C) 1997, Excel Services Corporation. Use by Excel Services associates, utility clients, and the U.S. Nuclear Regulatory Commission is granted. All other use without written permission is prohibited.

# $F_{a}(Z)$ (F<sub>a</sub> Methodology) 3.2.1B TSTF-99

CONDITION		REQUIRED ACTION		COMPLETION TIME	
Έ <b>Β.</b>	Fo(Z) not within limits.	B.1	Reduce AFD limits ≥ 1% for each 1% FG(Z) exceeds limit.	Shours	
с.	Required Action and associated Completion Time not met.	C.1	Be in MODE 2.	6 hours	

•

BASES

ACTIONS (continued)

<u>A.2</u>

A reduction of the Power Range Neutron Flux-High trip setpoints by  $\geq 1\%$  for each 1% by which  $F_6(Z)$  exceeds its limit, is a conservative action for protection against the consequences of severe transients with unanalyzed power distributions. The Completion Time of 8 hours is sufficient considering the small likelihood of a severe transient in this time period and the preceding prompt reduction in THERMAL POWER in accordance with Required Action A.1.

### <u>A.3</u>

Reduction in the Overpower  $\Delta T$  trip setpoints by  $\geq 1\%$  for each 1% by which Fa(Z) exceeds its limit, is a conservative action for protection against the consequences of severe transients with unanalyzed power distributions. The Completion Time of 72 hours is sufficient considering the small likelihood of a severe transient in this time period, and the preceding prompt reduction in THERMAL POWER in accordance with Required Action A.1.

# <u>A.4</u>

Verification that  $F_0^c(Z)$  has been restored to within its limit, by performing SR 3.2.1.1 prior to increasing THERMAL POWER above the limit imposed by Required Action A.1, ensures that core conditions during operation at higher power levels are consistent with safety analyses assumptions.

# <u>B.1</u>

If it is found that the maximum calculated value of  $F_{0}(Z)$  that can occur during normal maneuvers,  $F_{0}(Z)$ , exceeds its specified limits, there exists a potential for  $F_{0}(Z)$  to become excessively high if a normal operational transient occurs. Reducing the AFD by  $\geq 1\%$  for each 1% by which  $F_{0}(Z)$  (2) exceeds its limit within the allowed Completion Time of 2 hours, restricts the axial flux distribution such that even if a transient occurred, core peaking factors are not exceeded.

(continued)