

Industry/TSTF Standard Technical Specification Change Traveler

Revise ADV Action B to state "Restore All But One ADV to Operable Status"

Priority/Classification 1) Correct Specifications

NUREGs Affected: 1430 1431 1432 1433 1434

Description:

Revise LCO 3.7.4, ADVs, Action B to state "Restore All But One ADV to Operable Status"

Justification:

Required Action B.1 has been changed to "Restore all but one ADV line to Operable Status." The current condition addresses two or more inoperable lines, while only directing restoration of one. Required Action B.1 as drafted will require restoration of all but one, effectively exiting the Condition, leaving Condition A to address the remaining inoperable line. This change is consistent with the current Bases.

Revision History

OG Revision 0

Revision Status: Active

Next Action:

Revision Proposed by:

Revision Description:
Original Issue

Owners Group Review Information

Date Originated by OG: 27-Nov-95

Owners Group Comments
(No Comments)

Owners Group Resolution: Approved Date: 27-Nov-95

TSTF Review Information

TSTF Received Date: 27-Nov-95 Date Distributed for Review 27-Nov-95

OG Review Completed: BWOG WOG CEOG BWROG

TSTF Comments:

Accept for CEOG. Revise CEOG Action 3.7.4.B to remove brackets around "[TWO]" in the Condition and "[One]" around the Required Action.

BWOG Accepts

BWROG - Not applicable

TSTF Resolution: Approved Date: 30-Apr-96

NRC Review Information

NRC Received Date: 17-Jul-96 NRC Reviewer: R. Giardina

NRC Comments.

9/18/96 - Approved

Final Resolution: NRC Approves

Final Resolution Date: 18-Sep-96

Incorporation Into the NUREGs

4/2/98

File to BBS/LAN Date:

TSTF Informed Date:

TSTF Approved Date:

NUREG Rev Incorporated:

Affected Technical Specifications

Action 3.7.4.B

Atmospheric Dump Valves (BWOG - Atmospheric Vent Valves)

4/2/98

3.7 PLANT SYSTEMS

3.7.4 Atmospheric Vent Valves (AVVs)

LCO 3.7.4 [Two] AVVs [lines per steam generator] shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3,
MODE 4 when steam generator is relied upon for heat removal.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One required AVV [line] inoperable.	A.1 -----NOTE----- LCO 3.0.4 is not applicable. ----- Restore required AVV [line] to OPERABLE status.	[7 days]
B. Two or more required AVV [lines] inoperable.	B.1 <i>all but</i> Restore one AVV [line] to OPERABLE status.	24 hours]
C. Required Action and associated Completion Time not met.	C.1 Be in MODE 3. <u>AND</u> C.2 Be in MODE 4 without reliance upon steam generator for heat removal.	6 hours 18 hours

3.7 PLANT SYSTEMS

3.7.4 Atmospheric Dump Valves (ADV)

LCO 3.7.4 [Three] ADV lines shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3,
MODE 4 when steam generator is relied upon for heat removal.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One required ADV line inoperable.	A.1 -----NOTE----- LCO 3.0.4 is not applicable. ----- Restore required ADV line to OPERABLE status.	7 days
B. Two or more required ADV lines inoperable.	B.1 <i>(all but)</i> Restore one ADV line to OPERABLE status.	24 hours
C. Required Action and associated Completion Time not met.	C.1 Be in MODE 3. <u>AND</u> C.2 Be in MODE 4 without reliance upon steam generator for heat removal.	6 hours [18] hours

3.7 PLANT SYSTEMS

3.7.4 Atmospheric Dump Valves (ADVs)

LCO 3.7.4 [Two] ADV lines shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3,
[MODE 4 when steam generator is being relied upon for heat removal].

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One required ADV line inoperable.	A.1 -----NOTE----- LCO 3.0.4 is not applicable. ----- Restore ADV line to OPERABLE status.	7 days
B. Two or more [required] ADV lines inoperable.	B.1 <i>all but</i> Restore One ADV line to OPERABLE status.	24 hours
C. Required Action and associated Completion Time not met.	C.1 Be in MODE 3. <u>AND</u> C.2 Be in MODE 4 without reliance upon steam generator for heat removal.	6 hours [12] hours