

WOLF CREEK

NUCLEAR OPERATING CORPORATION

Kevin J. Moles
Manager Regulatory Affairs

FEB 11 2004

RA 04-0023


U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

Subject: Docket No. 50-482: January 2004 Monthly Operating Report

Gentlemen:

Attached to this letter is the January 2004, Monthly Operating Report for the Wolf Creek Generating Station. This submittal is being made in accordance with the requirements of Wolf Creek Generating Station Technical Specification 5.6.4, "Monthly Operating Reports." This submittal also follows the guidance of Generic Letter 97-02, "Revised Contents of the Monthly Operating Report." If you have any questions regarding this report, please contact me at (620) 364-4126, or Ms. Jennifer Yunk at (620) 364-4272.

Very truly yours,



Kevin J. Moles

KJM/rlg

Attachment

cc: J. N. Donohew (NRC), w/a
D. N. Graves (NRC), w/a
B. S. Mallett (NRC), w/a
Senior Resident Inspector (NRC), w/a



OPERATING DATA REPORT

Report Number: 227

DOCKET NO.: 50-482
UNIT NAME: Wolf Creek Generating Station
DATE: February 11, 2004
COMPLETED BY: J. L. Yunk
TELEPHONE: (620) 364-4272

REPORT MONTH: January 2004

| | | |
|----|--|------|
| 1. | Design Electrical Rating (MWe - Net): | 1170 |
| 2. | Maximum Dependable Capacity (MWe - Net): | 1166 |

| | | This Month | Year to Date | Cumulative |
|----|---------------------------------------|------------|--------------|----------------|
| 3. | Number of Hours Reactor Critical: | 744.00 | 744.00 | 138,520.67 |
| 4. | Number of Hours Generator On-Line: | 744.00 | 744.00 | 137,285.85 |
| 5. | Unit Reserve Shutdown Hours: | 0.00 | 0.00 | 339.80 |
| 6. | Net Electrical Energy Generated (MWH) | 883,896.00 | 883,896.00 | 155,852,267.00 |

UNIT SHUTDOWN AND POWER REDUCTIONS

DOCKET NO.: 50-482
UNIT NAME: Wolf Creek Generating Station
DATE: February 11, 2004
COMPLETED BY: J. L. Yunk
TELEPHONE: (620) 364-4272

| No. | Date | Type F: FORCED S: SCHEDULED | DURATION (Hours) | REASON (1) | METHOD OF SHUTTING DOWN THE REACTOR (2) | CORRECTIVE ACTIONS/COMMENTS |
|-----|------|-----------------------------------|---------------------|---------------|---|-----------------------------|
| NA | NA | NA | NA | NA | NA | NA |

SUMMARY: The plant operated at or near 100% power from January 1, 2004 through January 31, 2004.

(1) REASON: A: EQUIPMENT FAILURE (EXPLAIN)
B: MAINTENANCE OR TEST
C: REFUELING
D: REGULATORY RESTRICTION

E: OPERATOR TRAINING AND LICENSE EXAMINATION
F: ADMINISTRATIVE
G: OPERATIONAL ERROR (EXPLAIN)
H: OTHER (EXPLAIN)

(2) METHOD: 1. MANUAL
2. MANUAL SCRAM
3. AUTOMATIC SCRAM
4. CONTINUATION
5. OTHER