




PLAN



KEYMAP



SECTION


LEGEND:

- HYDRAULIC FILL
- STRUCTURAL FILL
- STRUCTURAL FILL WITH CONCRETE BEYOND
- RIVERBED SAND AND GRAVEL
- CLAY CONFINING UNIT
- VINCENTOWN FORMATION
- HORNERTOWN-NAVESINK AQUITARD
- LEAN CONCRETE
- COFFERDAM
- STRUCTURAL CONCRETE
- SEISMIC GAP (STYROFOAM)
- BLOW DOWN PIPING
- LIQUID "RAD" WASTE LINE
- SHEET PILE
- SERVICE WATER PIPING
- CIRCULATING WATER OUTLET PIPING
- CIRCULATING WATER INLET PIPING
- STORM SEWER PIPING
- CATCH BASIN
- MANHOLE (STORM SEWER)
- RCP
- MTL
- BUILDING WALL
- WELL R ■ MONITORING WELL SCREENED IN THE ENGINEERED FILL WITH THE COFFERDAM, 20 FEET DEEP (WELLS M, N, O, R)
- WELL S ● MONITORING WELL SCREENED IN THE SHALLOW, WATER TABLE AQUIFER OUTSIDE THE COFFERDAM, 35 FEET DEEP (WELLS S, T, U, W)
- WELL L ⊙ MONITORING WELL SCREENED IN THE VINCENTOWN FORMATION, 80 FEET DEEP (WELLS K, L, P, Q, V.)
- ■ ■ PHASE I SAMPLE LOCATION
- ■ ■ PHASE II SAMPLE LOCATION
- — — SEISMIC GAP
- - - PROPERTY BOUNDARY
- WELL O
- — — EXISTING LAND SURFACE
- — — BOREHOLE/WELL CASING
- (4.41) WATER-LEVEL ELEVATION 26 JUNE 2003 (NAVD 1988)
- ■ ■ SCREENED INTERVAL

**FOOTNOTE:**  
ENGINEERING DETAILS ARE CURRENTLY BEING REVIEWED BY PSEG NUCLEAR, LLC TO VERIFY ACCURACY OF STATION CONSTRUCTION DETAILS.

D-07

G:\PROJECT\PSEG6\Salem\NP000571.0003 - Remedial Investigation\RWP Addendum\Final v2\cadd\Fig-6-9 CROSS SECTIONS B-E.dwg, 12/ 1/2004 5:37pm



NO.	DATE	REVISION DESCRIPTION	BY	CHKD
1	9/8/03	CLIENT SUBMITTAL	MGW	BP

**ARCADIS**  
6 Terry Drive  
Suite 300, Newtown, PA 18940  
Tel: 267/685-1800 Fax: 267/685-1801

PSEG NUCLEAR, LLC  
SALEM GENERATING STATION  
ARTIFICIAL ISLAND  
HANCOCK'S BRIDGE, NEW JERSEY

DRAWN M. WASILEWSKI	DATE 9/26/03	PROJECT MANAGER P. MILONIS	DEPARTMENT MANAGER D. FULTON
FACILITY CROSS SECTION D-D'		LEAD DESIGN PROF. S. POTTER	CHECKED B. PIERCE
		PROJECT NUMBER NP000571.0003	DRAWING NUMBER 8