

February 19, 2004

Mr. Michael R. Kansler, President
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION REGARDING APPLICATION TO
EXTEND STEAM GENERATOR EXAMINATION INTERVAL, INDIAN POINT
NUCLEAR GENERATING UNIT NO. 2 (TAC NO. MC1260)

Dear Mr. Kansler:

In a letter dated October 21, 2003, Entergy Nuclear Operations, Inc. (ENO) submitted a proposed amendment to change the Technical Specifications (TSs) for Indian Point Nuclear Generating Unit No. 2 (IP2). The proposed amendment would revise TS Section 5.5.7, "Steam Generator Tube Surveillance Program," to allow a one-time extension of the frequency for examination of the tubes.

The Nuclear Regulatory Commission staff is reviewing the information provided in the October 21 submittal and has determined that additional information is needed to complete its review. The specific questions are found in the enclosed request for additional information (RAI). During a telephone call on February 17, 2004, the ENO staff indicated that a response to the RAI would be provided within 45 days.

If you should have any questions, please do not hesitate to call me.

Sincerely,

/RA/

Patrick D. Milano, Sr. Project Manager, Section 1
Project Directorate 1
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-247

Enclosure: RAI

cc w/encl: See next page

February 19, 2004

Mr. Michael R. Kansler
Senior Vice President and
Chief Operating Officer
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION REGARDING APPLICATION TO
EXTEND STEAM GENERATOR EXAMINATION INTERVAL, INDIAN POINT
NUCLEAR GENERATING UNIT NO. 2 (TAC NO. MC1260)

Dear Mr. Kansler:

In a letter dated October 21, 2003, Entergy Nuclear Operations, Inc. (ENO) submitted a proposed amendment to change the Technical Specifications (TSs) for Indian Point Nuclear Generating Unit No. 2 (IP2). The proposed amendment would revise TS Section 5.5.7, "Steam Generator Tube Surveillance Program," to allow a one-time extension of the frequency for examination of the tubes.

The Nuclear Regulatory Commission staff is reviewing the information provided in the October 21 submittal and has determined that additional information is needed to complete its review. The specific questions are found in the enclosed request for additional information (RAI). During a telephone call on February 17, 2004, the ENO staff indicated that a response to the RAI would be provided within 45 days.

If you should have any questions, please do not hesitate to call me.

Sincerely,

/RA/

Patrick D. Milano, Sr. Project Manager, Section 1
Project Directorate 1
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-247

Enclosure: RAI

Enclosure: RAI

cc w/encl: See next page

DISTRIBUTION

PUBLIC	R. Laufer	E. Murphy	OGC
PDI-1 Reading	P. Milano	S. Little	C. Bixler, RGN-I
C. Holden	L. Lund	B. McDermott, RGN-I	ACRS

Accession Number: ML040500626

OFFICE	PDI-1:PM	PDI-1:LA	EMCB-C:SC	PDI-1:SC
NAME	PMilano	SLittle	LLund	PTam for RLaufer
DATE	02/13/04	02/13/04	02/17/04	02/19/04

OFFICIAL RECORD COPY

Indian Point Nuclear Generating Unit No. 2

cc:

Mr. Gary Taylor
Chief Executive Officer
Entergy Operations, Inc.
1340 Echelon Parkway
Jackson, MS 39213

Mr. John Herron
Senior Vice President and
Chief Operating Officer
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Fred Dacimo
Vice President, Operations
Entergy Nuclear Operations, Inc.
Indian Point Energy Center
295 Broadway, Suite 2
P.O. Box 249
Buchanan, NY 10511-0249

Mr. Christopher Schwarz
General Manager, Plant Operations
Entergy Nuclear Operations, Inc.
Indian Point Energy Center
295 Broadway, Suite 2
P.O. Box 249
Buchanan, NY 10511-0249

Mr. Dan Pace
Vice President Engineering
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Randall Edington
Vice President Operations Support
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. John McCann
Director, Nuclear Safety Assurance
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Ms. Charlene Faison
Manager, Licensing
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Director of Oversight
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. James Comiotes
Director, Nuclear Safety Assurance
Entergy Nuclear Operations, Inc.
Indian Point Energy Center
295 Broadway, Suite 2
P.O. Box 249
Buchanan, NY 10511-0249

Mr. Patric Conroy
Manager, Licensing
Entergy Nuclear Operations, Inc.
Indian Point Energy Center
295 Broadway, Suite 2
P. O. Box 249
Buchanan, NY 10511-0249

Mr. John M. Fulton
Assistant General Counsel
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Senior Resident Inspector, Indian Point 2
U. S. Nuclear Regulatory Commission
295 Broadway, Suite 1
P.O. Box 38
Buchanan, NY 10511-0038

Indian Point Nuclear Generating Unit No. 2

cc:

Mr. Peter R. Smith, President
New York State Energy, Research, and
Development Authority
Corporate Plaza West
286 Washington Avenue Extension
Albany, NY 12203-6399

Mr. Paul Eddy
Electric Division
New York State Department
of Public Service
3 Empire State Plaza, 10th Floor
Albany, NY 12223

Mr. Charles Donaldson, Esquire
Assistant Attorney General
New York Department of Law
120 Broadway
New York, NY 10271

Mayor, Village of Buchanan
236 Tate Avenue
Buchanan, NY 10511

Mr. Ray Albanese
Executive Chair
Four County Nuclear Safety Committee
Westchester County Fire Training Center
4 Dana Road
Valhalla, NY 10592

Ms. Stacey Lousteau
Treasury Department
Entergy Services, Inc.
639 Loyola Avenue
Mail Stop: L-ENT-15E
New Orleans, LA 70113

Mr. William DiProfio
PWR SRC Consultant
139 Depot Road
East Kingston, NH 03827

Mr. Dan C. Poole
PWR SRC Consultant
20 Captains Cove Road
Inglis, FL 34449

Mr. William T. Russell
PWR SRC Consultant
400 Plantation Lane
Stevensville, MD 21666-3232

Alex Matthiessen
Executive Director
Riverkeeper, Inc.
25 Wing & Wing
Garrison, NY 10524

Paul Leventhal
The Nuclear Control Institute
1000 Connecticut Avenue NW
Suite 410
Washington, DC, 20036

Karl Coplan
Pace Environmental Litigation Clinic
78 No. Broadway
White Plains, NY 10603

Jim Riccio
Greenpeace
702 H Street, NW
Suite 300
Washington, DC 20001

Mr. Robert D. Snook
Assistant Attorney General
State of Connecticut
55 Elm Street
P.O. Box 120
Hartford, CT 06141-0120

Indian Point Nuclear Generating Unit No. 2

cc:

Mr. David Lochbaum
Nuclear Safety Engineer
Union of Concerned Scientists
1707 H Street NW, Suite 600
Washington, DC 20006

REQUEST FOR ADDITIONAL INFORMATION
REGARDING STEAM GENERATOR SURVEILLANCE INTERVAL
INDIAN POINT NUCLEAR GENERATING UNIT NO. 2 (IP2)

In a letter dated October 21, 2003, Entergy Nuclear Operations, Inc. (the licensee) submitted a proposed amendment to revise Technical Specifications (TSs) Section 5.5.7, "Steam Generator (SG) Tube Surveillance Program," to allow a one-time extension of the frequency for examination of the SG tubes. Specifically, the amendment would extend the examination, currently due no later than November 17, 2004, to June 17, 2006. The Nuclear Regulatory Commission (NRC) staff has the following questions regarding the information provided in the proposed amendment:

1. The licensee states that two of thirteen tubes found with anti-vibration bar (AVB) wear indications will be evaluated for stabilization prior to the next scheduled inspection. The licensee states that these two tubes had indications at all four AVB contact points and are not expected to wear to the point of causing tube to tube contact for the next four cycles. Provide a brief summary of the method used for performing this evaluation. State whether the remaining eleven tubes will also be evaluated for future stabilization? If not evaluated, discuss the reason?
2. The licensee states that as a result of the implementation of a 1.4% power uprate, the amount of wear expected over a 40-year lifetime is 2 mils (4% of the tube wall thickness), which is less than the allowable 3 mils. Provide additional clarification on this estimate since it seems to be at odds with experience to date at IP2 where thirteen tubes exhibited wear ranging between 5% (the detection threshold) and 20% of the wall thickness after just one operating cycle. Presumably, there may be undetected wear flaws which grew by as much as 5% over the first operating cycle, prior to the 1.4% power uprate.
3. Provide the expected percentage increase in wear rate expected as a result of the projected 3.26% power uprate conditions anticipated in the future, and provide a summary description of the basis for this estimate.

Enclosure