

ENCLOSURE

WATTS BAR NUCLEAR PLANT (WBN) UNIT 1
LICENSE AMENDMENT REQUEST WBN-TS-03-06

EXCERPTS FROM CALCULATION WBN-OSG4-091
MAXIMUM CONTAINMENT WATER LEVEL

TVAN CALCULATION COVERSHEET/CCRIS UPDATE

Page 1

REV'D EDMS/RIMS NO. NEB811005261				EDMS TYPE: calculations(nuclear)		EDMS ACCESSION NO (N/A for REV. 0) T71 020102 800			
Calc Title: MAXIMUM CONTAINMENT WATER LEVEL									
<u>CALC ID</u>	<u>TYPE</u>	<u>ORG</u>	<u>PLANT</u>	<u>BRANCH</u>	<u>NUMBER</u>	<u>CUR REV</u>	<u>NEW REV</u>	<u>REVISION APPLICABILITY</u>	
CURRENT	CN	NUC	WBN	NTB	WBNOSG4091	R08	R09	Entire calc <input checked="" type="checkbox"/> Selected pages <input type="checkbox"/>	
NEW	CN	NUC							
ACTION	NEW REVISION <input checked="" type="checkbox"/>		DELETE RENAME <input type="checkbox"/>		SUPERSEDE DUPLICATE <input type="checkbox"/>		CCRIS UPDATE ONLY <input type="checkbox"/> (Verifier Approval Signatures Not Required)		No CCRIS Changes <input type="checkbox"/> (For calc revision, CCRIS been reviewed and no CCRIS changes required)
<u>UNITS</u> 1		<u>SYSTEMS</u> 271			<u>UNIDS</u> N/A				
<u>DCN.EDC.N/A</u> E-50814-A			<u>APPLICABLE DESIGN DOCUMENT(S)</u> N/A					<u>CLASSIFICATION</u> E	
<u>QUALITY RELATED?</u> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	<u>SAFETY RELATED?</u> (If yes, QR = yes) Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		<u>UNVERIFIED ASSUMPTION</u> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>		<u>SPECIAL REQUIREMENTS AND/OR LIMITING CONDITIONS?</u> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>		<u>DESIGN OUTPUT ATTACHMENT?</u> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>		<u>SAR/TS AFFECTED</u> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>
<u>PREPARER ID</u> JFLUND		<u>PREPARER PHONE NO</u> 423-365-1460		<u>PREPARING ORG (BRANCH)</u> MEB		<u>VERIFICATION METHOD</u> DESIGN REVIEW		<u>NEW METHOD OF ANALYSIS</u> <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
<u>PREPARER SIGNATURE</u> J. F. Lund <i>J. F. Lund</i>				<u>DATE</u> 20 DEC 2001		<u>CHECKER SIGNATURE</u> D. W. Posey <i>D. W. Posey</i>			
<u>VERIFIER SIGNATURE</u> D. W. Posey <i>D. W. Posey</i>				<u>DATE</u> 12-20-01		<u>APPROVAL SIGNATURE</u> <i>J. Robertson for B.G. Briody</i>			
<u>STATEMENT OF PROBLEM/ABSTRACT</u>									
<u>STATEMENT OF PROBLEM</u>									
DETERMINE THE MAXIMUM CONTAINMENT WATER LEVEL THAT WILL OCCUR FOLLOWING AN ACCIDENT.									
<u>ABSTRACT</u>									
THIS CALCULATION DETERMINES THE MAXIMUM CONTAINMENT WATER LEVEL FOR THE BOUNDING CASE OF LBLOCA, SBLOCA, AND MSLB/MFLB. THE LBLOCA RESULTS IN THE MAXIMUM WATER LEVEL. A TRANSIENT WATER LEVEL INSIDE THE CRANE WALL WAS CALCULATED FOR THE LBLOCA. THE EQUILIBRIUM WATER LEVEL WAS CALCULATED FOR THE LBLOCA AND THE MSLB. THIS WAS PERFORMED USING THE METHODOLOGY DISCUSSED IN SECTION 4.0. THE RESULTS ARE SUMMARIZED IN SECTION 9.0.									
THE LEVELS ARE SUMMARIZED BELOW: LBLOCA MAXIMUM TRANSIENT CONTAINMENT WATER LEVEL: ELEVATION 720.0 FEET LBLOCA MAXIMUM EQUILIBRIUM CONTAINMENT WATER LEVEL: ELEVATION 717.2 FEET MSLB MAXIMUM EQUILIBRIUM CONTAINMENT WATER LEVEL: ELEVATION 716.0									
<u>MICROFICHE/EFICHE</u> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> <u>FICHE NUMBER(S)</u>									
<input type="checkbox"/> LOAD INTO EDMS AND DESTROY <input checked="" type="checkbox"/> LOAD INTO EDMS AND RETURN CALCULATION TO CALCULATION LIBRARY. ADDRESS: EQB 1M-WBN <input type="checkbox"/> LOAD INTO EDMS AND RETURN CALCULATION TO:									

TVAN CALCULATION RECORD OF REVISION	
CALCULATION IDENTIFIER: WBNOSG4091	
Title MAXIMUM CONTAINMENT WATER LEVEL	
Revision No.	DESCRIPTION OF REVISION
9	<p>This calculation implements Corrective Action Step 19 of PER 00-007819-000.</p> <p>The revision to this calculation evaluates the effects of potential LOCA induced line breaks in the Component Cooling and Essential Raw Cooling Water Systems on the Containment flooding analysis. This is necessary since the existing calculation did not account for the addition of water from these potential sources.</p> <ol style="list-style-type: none"> 1. Pages 1 and 1A replaced the existing coversheet. 2. Page 2E added the Revision 9 Revision Log. 3. Page 3 replaced the existing Verification page. 4. Page 5 was revised to change the Revision Log page count. 5. Pages 7 and 9 were replaced to update the Table Of Contents. 6. Page 13 7. Pages 21 and 22 were revised to consolidate the References and add References 43 through 59. 8. Page 36 was revised to add CCS and ERCW as potential sources of water. 9. Pages 87 through 96 were added to include Appendix C which evaluated the effect of potential CCS and ERCW line breaks. 10. Attachment 3 was added to include a copy of Reference 58. <p>This revision of the calculation does not affect any successor calculations.</p> <p>Pages Added: 2E (new Revision Log), 87 through 96, Attachment 3, page 1 of 1 Pages Revised: 5 Pages Replaced: 1, 1A, 3, 7, 9, 13, 21, 22, 36, Pages Deleted: None</p> <p>Total pages in Calculation: 119, including 1A, 2a, 2b, 2c, 2d, 2E, 4a, and 39.1.</p> <p>The computer files prepared for this revision are stored in the S Drive under S:\Nuc_Eng\Mechanical\Calculations.</p>

Calc Title: MAXIMUM CONTAINMENT WATER LEVEL							<u>WBN Unit 1</u>
	TYPE	PLANT	BRANCH	NUMBER	REV	prepared	J F Lund
<u>CALC ID</u>	CN	WBN	NTB	WBNOSG4091	R09	checked	D W Posey

Appendix C

Flow Resulting From CCS and ERCW Line Breaks (continued)

Two (2) Component Cooling System lines and one (1) Essential Raw Cooling Water System line inside containment are subject to LOCA impingement failure due to LOCAs which could occur in adjacent piping (Reference 59). Each line is subject to a different LOCA. If one of the subject lines breaks, the failure of the outboard containment isolation valve associated with the specific cooling water line to close could result in a flow of cooling water into containment.

The failure of one of the CCS containment isolation valves (1-FCV-070-92 or -100), or the ERCW containment isolation valve (1-FCV-067-107) to close after a LOCA induced line break in the piping associated with that valve can result in the flow of water into containment. This flow can occur because check valves are provided to protect the piping section between the inboard and outboard containment isolation valves (CIVs) from thermal overpressure conditions which can occur when the containment isolation valves are both closed (Refer to Figure C-1). The check valve piping bypasses the inboard CIV and discharges back into the associated piping inside containment. This problem was discovered during the Extent of Condition Review for PER 00-007819-000. This leakage would add to the volume of water inside the containment after a LOCA. Calculations performed in Reference 43 determined that the flow rate through any of the line breaks would be approximately 40 gallons per minute. Due to the rules of single failure criteria, it is only necessary to postulate the limiting failure of one (1) of the valves to close in the condition being evaluated. The valve associated with the broken line is assumed to be the one that fails.




FIGURE C-1
Containment Penetration Detail

Calc Title: MAXIMUM CONTAINMENT WATER LEVEL							<u>WBN Unit 1</u>
	TYPE	PLANT	BRANCH	NUMBER	REV	prepared	J F Lund
<u>CALC ID</u>	CN	WBN	NTB	WBNOSG4091	R09	checked	D W Posey

Appendix C

Flow Resulting From CCS and ERCW Line Breaks (continued)

The postulated failure of the outboard containment isolation valve would result in an unintended cooling water flow path into containment. This could affect two areas of concern; the boron concentration of the recirculation water in the containment sump, and the post LOCA flood level inside containment. The effect on boron concentration is evaluated in Reference 43.

Post LOCA Flooding Inside Containment

This calculation (WBNOSG4091) determines the maximum transient and equilibrium flood levels inside containment. Following a large break LOCA, the flood levels are as shown below.

1. The maximum transient level inside the Crane Wall, prior to establishing equilibrium conditions on each side of the Crane Wall, is 720.0 feet.
2. The maximum equilibrium level is 717.2 feet.

The 717.2 elevation is the maximum elevation specified for the raceway between the Crane Wall and Steel Containment Vessel on the Environmental Data drawing 47E235-42 (Reference 34). Flooding above this elevation could impact safety related equipment.

According to page 62 of this calculation, the maximum transient elevation inside the crane wall occurs at approximately 15 minutes after the Safety Injection Signal for a large break LOCA. After this time the maximum transient elevation will decrease due to flow out through the Crane Wall sleeves located above elevation 716.0' into the raceway and also into the reactor cavity. The flow through a CCS or ERCW line break will have negligible impact on the transient flood level during the initial 15 minute time frame following the LOCA. Conservatism in the calculation's assumptions will account for the slight difference in water flow into containment.

This calculation (WBNOSG4091) assumed the maximum postulated amount of liquid that could be dumped into containment following a LOCA. System descriptions N3-61-4001 "ICE CONDENSER SYSTEM" in subsection 3.2.19.3 (Reference 11), N3-63-4001, "SAFETY INJECTION SYSTEM" in Tables 7 and 9 (Reference 12), and N3-68-4001 "REACTOR COOLANT SYSTEM" on page 26 (Reference 11) provide normal minimum and maximum values for the fluid volumes of the Reactor Coolant System, the Safety Injection System Accumulators, Refueling Water Storage Tank, and the Ice Mass in the Ice Condenser. TABLE C-1 is based calculations performed in Reference 43, and gives a comparison of the values derived from the system descriptions with the values used in this calculation.

Calc Title: MAXIMUM CONTAINMENT WATER LEVEL							<u>WBN Unit 1</u>
	<u>TYPE</u>	<u>PLANT</u>	<u>BRANCH</u>	<u>NUMBER</u>	<u>REV</u>	<u>prepared</u>	J F Lund
<u>CALC ID</u>	CN	WBN	NTB	WBNOSG4091	R09	checked	D W Posey

Appendix C

Flow Resulting From CCS and ERCW Line Breaks (continued)

TABLE C-1

System Fluid Volumes					
Component	Volume total Per Ref. 43 gal, minimum	Volume total Per Ref. 43 gal, maximum	Volume per calc WBNOSG4091 gal	Maximum Difference gal	Minimum Difference gal
RCS	51,198	51,198	51,200	2	2
Accumulator	30,897	33,664	40,400	9,503	6,736
RWST	352,644	362,981	380,000	27,356	17,019
Ice Condenser	297,991	371,900	372,000	74,009	100
Total	732,730	819,743	843,600	110,870	23,857

As can be seen from the above table, calculation WBN-OSG4-091 provides conservative volumes for the water contributing to containment flooding. Another difference is that the flooding calculation WBN-OSG4-091 assumed the RWST completely emptied, when in actuality, approximately 28, 800 gallons of water remain in the tank. In addition, it also assumes a complete ice-melt, which may not occur during these LOCA scenarios, due to the location and size of the LOCAs.

With a flow rate of approximately 40 gpm through the check valve (Reference 43), a LOCA induced ERCW or CCS pipe break results in a flow rate of approximately 2,400 gallons per hour. Therefore, under worst case assumptions, there would be anywhere from approximately 10 to 46 hours before the actual flood level reached the equilibrium flood level in calculation WBN-OSG4-091 based on the range of values listed in TABLE C-1. This time span is based on the minimum and maximum values for the quantities of water that are specified in the system descriptions and shown in Table C-1. In actuality, the time to reach design basis equilibrium flood conditions will be longer since the types of LOCAs that would break the ERCW or CCS pipe lines are not the same size as the design basis LOCA evaluated in this calculation.

Calc Title: MAXIMUM CONTAINMENT WATER LEVEL							<u>WBN Unit 1</u>
	TYPE	PLANT	BRANCH	NUMBER	REV	prepared	J F Lund
<u>CALC ID</u>	CN	WBN	NTB	WBNOSG4091	R09	checked	D W Posey

Appendix C

Flow Resulting From CCS and ERCW Line Breaks (continued)

EVALUATION OF THE CCS LINE BREAK

Description

If the line break was in the CCS system, a dropping level in the CCS Surge Tank would indicate a potential line break. In addition, a rising water level inside containment, caused by the CCS line break, would also be identified by Operations personnel.

According to subsection 3.2.3 of Reference 44, "Each of two surge tanks is divided internally by a baffle to separate the Train A and Train B sides of the surge tanks. This internal division provides redundancy for a passive failure during recirculation following a LOCA." The A Train side of the Surge Tank is associated with the piping that supplies the components in the Reactor Building served by the CCS.

In addition, subsection 3.3.2 of Reference 44 states, "Level indication is provided for each tank in the MCR and ACR. Low and high level alarms in MCR warn of the loss of water, or inleakage of water to the CCS."

Using the water level at which the high level alarm would actuate, it is possible to determine the maximum initial amount of water in the Surge Tank that would be available to drain into the Train A header, if there was a line break inside containment. Normally when the water level in the Surge Tank reaches the low level setpoint, valve 1-LCV-70-63 would open and make-up water would be provided from the Demineralized water system. For the purposes of this calculation, it is assumed the continuing need for makeup would additionally alert the operators to the potential for a line break, and together with the status light for the containment isolation valve showing it was still open, action would be taken to isolate the break in a timely manner. Either the break would be isolated, or the CCS pumps assigned to Train A would be shut down due to low NPSH concerns if makeup water was not available.

Calc Title: MAXIMUM CONTAINMENT WATER LEVEL							<u>WBN Unit 1</u>
	<u>TYPE</u>	<u>PLANT</u>	<u>BRANCH</u>	<u>NUMBER</u>	<u>REV</u>	prepared	J F Lund
<u>CALC ID</u>	CN	WBN	NTB	WBNOSG4091	R09	checked	D W Posey

Appendix C

Flow Resulting From CCS and ERCW Line Breaks (continued)

Determination Of Time To Empty The CCS Surge Tank If Make-Up Is Not Available.

The following calculation determines the amount of water in the surge tank and the time it would take to drain the tank if there was a CCS line break inside the containment concurrent with a LOCA.




Figure C-2
CCS Surge Tank Outline

Volume of CCS Surge Tank

outside diameter =	12 ft	Ref. 45
outside diameter =	144 inches	Ref. 45
wall thickness =	5/16 inches	Ref. 45
inside diameter =	143.375 inches	
inside radius =	71.688 inches	
inside surface area =	16144.951 sq inches	
inside surface area =	112.118 sq feet	

Calc Title: MAXIMUM CONTAINMENT WATER LEVEL							<u>WBN Unit 1</u>
	<u>TYPE</u>	<u>PLANT</u>	<u>BRANCH</u>	<u>NUMBER</u>	<u>REV</u>	<u>prepared</u>	J F Lund
<u>CALC ID</u>	CN	WBN	NTB	WBNOSG4091	R09	checked	D W Posey

Appendix C

Flow Resulting From CCS and ERCW Line Breaks (continued)

volume =	112.118 cu feet/foot of height		
volume =	838.699 gallons/foot of height		
Low level alarm elevation =	769.08 feet		Ref. 46
At height above lower tap	75 inches		Ref. 46
Top of divider plate =	71.81 inches		Ref. 45
Height of water above the divider plate =	3.19 inches		
Volume above divider plate = (below low level alarm)	222.954 gallons		
Volume below divider plate =	2509.4 gallons	plus	790.5 gallons Ref. 45
Volume below divider plate =	3299.9 gallons		
High level elevation =	770.875 feet		
Height from Low to High level alarms =	1.795 feet		
Volume from Low to High level alarms =	1505.464 gallons		
Total Volume of Water to be drained from the A Train side of the Surge Tank (assuming no make-up) =	5028.318 gallons		
Flow out of break CCS line break equals	40 gpm		Ref. 43
Time to drain from high level to low level alarm =	37.64 minutes		
Time to drain remainder of water, assuming no make-up =	88.07 minutes		
Total time to drain from the high level alarm =	125.71 minutes		

Calc Title: MAXIMUM CONTAINMENT WATER LEVEL							<u>WBN Unit 1</u>
	<u>TYPE</u>	<u>PLANT</u>	<u>BRANCH</u>	<u>NUMBER</u>	<u>REV</u>	prepared	J F Lund
<u>CALC ID</u>	CN	WBN	NTB	WBNOSG4091	R09	checked	D W Posey

Appendix C

Flow Resulting From CCS and ERCW Line Breaks (continued)

If valve 1-FCV-070-0092 or 0140 failed to close, and there was a LOCA induced line break inside containment in the piping associated with the open valve, the dropping level in the CCS Surge Tank would provide timely indication that there was a break in the CCS piping pressure boundary. Operator action to isolate the leak, by closing either the containment isolation valve or a manual valve in the piping associated with the containment isolation valve, would isolate the leak well before adversely impacting the maximum containment flood level. The manual valves which could be used to isolate the line break if the containment isolation valve fails to operate are listed below:

Isolation valve 1-ISV-070-501 (1-FCV-070-92)

(Refer to Drawings 1-47W859-1 (Ref. 51), -2 (Ref. 52), and 47W464--9 (Ref. 56)

Isolation valve 1-ISV-070-516 (1-FCV-070-140)

(Drawings 1-47W859-1 (Ref. 51), -2 (Ref. 52), and 47W464-8 (Ref. 55)

Isolation valve 1-ISV-070-700 (1-FCV-070-92)

(Refer to Drawings 1-47W859-(Ref. 51), -2 (Ref. 52), and 47W464-2D (Ref. 53)

Isolation valve 1-ISV-070-789 (1-FCV-070-140)

(Refer to Drawings 1-47W859-(Ref. 51), -2 (Ref. 52), and 47W464-3D (Ref. 54), -11 (Ref. 57)

Calc Title: MAXIMUM CONTAINMENT WATER LEVEL							<u>WBN Unit 1</u>
	<u>TYPE</u>	<u>PLANT</u>	<u>BRANCH</u>	<u>NUMBER</u>	<u>REV</u>	<u>prepared</u>	J F Lund
<u>CALC ID</u>	CN	WBN	NTB	WBNOSG4091	R09	checked	D W Posey

Appendix C

Flow Resulting From CCS and ERCW Line Breaks (continued)

Evaluation of the ERCW Line Break

The ERCW line break concern is significantly different from the CCS line breaks. The difference is that the source of the ERCW is the Tennessee River, and therefore, a line break could not be identified due to a loss of inventory in the ERCW system as is the case with the CCS. In the case of the ERCW line break, the only indicators would be indication that the containment isolation valve was open, and there was a rising water level inside containment.

As discussed previously, with a flow rate of approximately 40 gpm out of the line break, the maximum calculated flood level inside containment could be exceeded within 10 to 46 hours depending on the actual volume of fluid contained in each system.

Further evaluation of the Ice Condenser System modifies the minimum time frame. The minimum time frame of 10 hours is based on an Ice Mass of 3,000,000 lbm. The current Technical Specification requirement as defined in SR 3.6.11.2 is that the total weight of stored ice is $\geq 2,403,800$ lbm. The as left ice mass after the U1C3 refueling outage was approximately 2,800,000 lbm (Reference 54). As shown on the next page, with an ice mass of 2,900,000 lbm, the minimum time frame for exceeding the maximum flood level inside containment becomes approximately 16 hours. The ice mass in the Ice Condenser is not expected to increase above 2,900,000 lbm mass. A 3,000,000 lbm, that would be the maximum value after the initial fill (or refill) of the Ice Condenser baskets. This value will not be reached by the normal servicing of the Ice Condenser during refueling outages. In addition, ice weight reduction programs that are currently being implemented (Refer to DCN D-50951-A) will further reduce the total amount of ice mass in the Ice Condenser.

The flow path(s) can be isolated as described below.

Isolation valve 1-ISV-067-523B (1-FCV-067-107)

If Containment Isolation Valve (CIV) 1-FCV-067-107 can not be closed and a line break in the associated piping inside containment needs to be isolated, valve 1-ISV-067-523B is the only valve available for isolation. This will isolate flow to both the 1B and 1D containment cooler groups and Reactor Coolant Pumps 2 and 4. Flow to these components would already have been isolated by the closure of the other associated CIVs; therefore, it is acceptable to shut this valve. Valve 1-ISV-067-523B is located at elevation 709'-6" and near column lines A2 and U (47W450-2D), and is the isolation valve for the connection to the 24" supply header.

(Refer to Drawings 1-47W845-2 (Ref. 48) and -3 (Ref. 49), 47W450-2D (Ref. 50).

APPENDIX C

Page 95

WBNOSG4091, Rev. 9
WATTS BAR NUCLEAR PLANT, UNIT 1

Flow Resulting From
CCS and ERCW Line Breaks

Prepared by J. F. Lund
Checked by D. W. Posey

INPUT DATA

	Volume each min	Volume each max		Density of water lbm/cu ft	References
Reactor Coolant System Spillage	413,000	413,000	lbm		Design Input Item D
Cold Leg Accumulators	1,005	1,095	cu ft at	100 (F)	Ref. 12, Table 7
Refueling Water Storage Tank Total Volume	370,000	380,000	gallons at	60 (F)	Ref. 12, Table 9
Refueling Water Storage Tank Unused Volume					
O. D. =	43.5		ft		Ref. 60
wt =	5/16		inches		Ref. 60
to level =	31.2		inches		
Ice Condenser (Required)	2,403,800	2,900,000	lbm		Ref. 14, Section 3.2.19.3

CALCULATION OF ALLOWABLE CCS/ERCW FLOW INTO CONTAINMENT

Component	Mass lbm min	Mass lbm max	Density lbm/cu ft	Volume each cu ft min	Volume each cu ft max	Volume each gal min	Volume each gal max	Quantity	Volume total gal min	Volume each gal max	Volume per calc gal	Maximum Difference gal	Minimum Difference gal	
Reactor Coolant System	413,000 lbm	413,000 lbm	190 (F) 60.34302332 lbm/cu ft	6,844 cu ft	6,844 cu ft	51,198 gallons	51,198 gallons	1	51,198	51,198	51,200	2	2	
Cold Leg Accumulators	62,300 lbm	67,889 lbm	60.34302332 lbm/cu ft	1,033 cu ft	1,125 cu ft	7,724 gallons	8,410 gallons	4	30,897	33,664	40,400	9,503	6,736	
Refueling Water Storage Tank Total Volume									370,000	380,000				
Refueling Water Storage Tank Unused Volume														
O. D. = 43.5 ft														
wt = 5/16 inches														
I.D. = 43.45 ft														
Height = 31.2 inches = 2.600 feet														
Volume = 3,855 cu ft									3,855	28,836	28,836			
RWST Volume Transferred at		(X) 1'						341,164	351,164	cu ft				
RWST Volume Transferred at		60 ft						2,844,673	2,928,054	lbm				
RWST Transferred at	190 F	2,844,673 lbm	2,928,054 lbm	60.34302332 lbm/cu ft	47,142 cu ft	49,523 cu ft	352,644 gallons	362,981 gallons	1	352,644	362,981	380,000	27,356	17,019
Ice Condenser (Required)		2,403,800 lbm	2,900,000 lbm	60.34302332 lbm/cu ft	39,836 cu ft	48,059 cu ft	297,991 gallons	359,503 gallons	1	297,991	359,503	372,000	74,009	12,497
									2,781,373 lbm as of Apr 1999					
									732,730	807,346	843,600	110,870	16,254	
												daily flow rate	54,720	gal/day
												days to reach equilibrium flood elevation	2.03	0.66
												hours to reach equilibrium flood elevation	48.63	15.90

Page Added by Revision 9

Calc Title: MAXIMUM CONTAINMENT WATER LEVEL							<u>WBN Unit 1</u>
	<u>TYPE</u>	<u>PLANT</u>	<u>BRANCH</u>	<u>NUMBER</u>	<u>REV</u>	<u>prepared</u>	J F Lund
<u>CALC ID</u>	CN	WBN	NTB	WBNOSG4091	R09	checked	D W Posey

Appendix C (Continued)

Flow Resulting From CCS and ERCW Line Breaks (continued)

SUMMARY

If one of the subject valves fails to close, remedial action should be taken to minimize the effects on the water level inside containment.

In the cases of the Component Cooling Systems, valve position indication lights and a dropping inventory in the CCS Surge Tank, or the requirement to frequently add make-up water to the Surge Tank would ensure remedial actions are taken well within the 16 hour time frame before the water from the line break affects the water level inside containment.

In the case of an ERCW line break the valve position indication lights and an increasing water level inside containment would be the indications that there is the possibility ERCW was getting into the post-LOCA containment water inventory. As long as the flow into containment is isolated within the 10 to 16 hour time frame, there are no adverse consequences to the containment flooding analysis flood levels.

NTB-WBN-271
WBN-271-D053

WBN 0564-091

WBN

ADMINISTRATION OF WALKDOWN DOCUMENTS

SSP-9.A
Revision 2
Page 25 of 33

APPENDIX J
Page 2 of 8

Att 1 pg 1 of 4

WALKDOWN DATA REQUEST FORM (Example)

Walkdown Identification No. <u>WBN-0564-071-ISC</u>					Page 1 of 4
Walkdown Title <u>Inside Containment Evaluation of Free Volume for RHR</u>					
<u>CONTAINMENT Sump Level (electro vs gallons)</u>					
Walkdown Initiating Document <u>WBN-0564-071</u>					References (47W470-1 41W710 41W716 41W726 47W200)
Affected Documents (Attach if Required) <u>NR</u>					
Estimated Walkdown Manhours <u>40</u>					
PWL Code <u>WJ</u>					
Walkdown Location	<u>1 RB</u>	<u>702.8'</u>	<u>0-360</u>	<u>LOWER CONTAINMENT</u>	
	Unit & Bldg	Elev.	Azimuth/Col. lines	Room/Area	
Walkdown Scope					
<ul style="list-style-type: none">• Walkdown Unit 1 Lower Containment in conjunction with the ^{see references} concrete outline drawings (47W470-1) to calculate the amount of Lower containment ^{41W716} space occupied by concrete. (Volume vs Elev)• Determine the amount of Lower Containment free space occupied by misc equipment (structural steel, supports, etc).• The above to be done for Inside Crane Wall and Outside Crane wall from floor elevation to ^{just above} the elevation of the crane wall unsealed penetrations (neglect Rx Cavity). Roughly from 702.8' to 716' to 720' (this higher elevation needed for input to 0564-091 misc level).					
Data Tolerance Requirements <u>Field Measurements ± 1/2"</u>					
<ul style="list-style-type: none">• ID all penetrations thru crane wall that are unsealed between elev 702.8 and 721.					
John Henry Sullivan Jr, 4/27/92, 3274, <u>[Signature]</u> , 4/27/92					
Data Requester (Print)		Date	Tel. No.	Supervisor Signature	Date

APPENDIX J

Page 6 of 8

WALKDOWN DOCUMENTATION FORM (Example)

WBN 0564-09

Att 1 pg. 2 of 4

Walkdown Identification No. WBN-0564-071-15CPage 2 of 4Actual Walkdown Manhours ~18Walkdown Documentation

This following is a itemized list of items found outside crane wall from az 11° to az 23° and from el. 702.78' to el. 714.0'. Piping and conduits in this area <2 1/2" and support steel were not identified.

1. 3" pipe x 9'-0 1/2" lg. (CVCS)
2. 4" pipe x 9'-1 1/2" lg. (CVCS)
3. 3" pipe x 9'-0 1/2" lg. (CCS)
4. 3" pipe x 9'-0 1/2" lg. (CCS)
5. 6" pipe x 9'-0 1/2" lg. (CCS)
6. 6" pipe x 9'-0 1/2" lg. (CCS)
7. 6" pipe x 12'-9 1/2" lg. (CCS)
8. 6" pipe x 14'-10" lg. (CCS)
9. 4" pipe x 10'-10" lg. (S.G. BLOWDOWN)
10. 4" pipe x 17'-4 1/2" lg. (S.G. BLOWDOWN)
11. 3" conduit x 3'-6" lg. (1VC-2580A)
12. 3" conduit x 11'-3" lg. (PLC-1072A)
13. Junction box - 6" x 6" x 6" (1-JB-293-392A)
14. Junction box - 12" x 14" x 6" (1-JB-293-2516)

DENNIS REIFFER

Data Taker (Print)

D. W. Reiffer

Data Taker Signature

16-1-92

Date

GEORGE M. HERRON

Data Verifier (Print)

George M. Herron

Data Verifier Signature

16-4-92

Date

APPENDIX J
Page 6 of 8

WALKDOWN DOCUMENTATION FORM (Example)

WBN-0564-091

AA 1 P53074

Walkdown Identification No. WBN-0564-071-15C | Page 3 of 4Actual Walkdown Manhours ~20Walkdown Documentation

This following is a itemized list of items found inside crane wall from az 0° to az 15° and from el. 702.78' to el. 708.78'. Piping and conduits in this area <2 1/2" were not identified.

1. 3" Pipe x 5'-6" lg. (Station Drain)
2. 3" Pipe x 10'-6" lg. (WDS)
3. 4" Pipe x 10'-6" lg. (Fire Protection)
4. 4" Pipe x 5'-0" lg. (WDS)
5. 8" Pipe x 1'-3" lg. (HVAC Support)
6. Junction box - 6" x 4" x 4" (1-JB-293-1025)
7. Junction box - 6" x 6" x 6" (1-JB-293-798)
8. Junction box - 12" x 14" x 6" (1-JB-293-585)
9. TS 3" x 3" x 6'-6" lg. (Pipe Support - ERCW)
10. TS 4" x 4" x 3'-6" lg. (Platform Support)
11. TS 4" x 4" x 6'-0" lg. (Pipe Support - ERCW)

DENNIS REIFFER
Data Taker (Print)Dennis Reiffer 16-1-92
Data Taker Signature DateGEORGE M. HERRON
Data Verifier (Print)George M. Herron 16-5-92
Data Verifier Signature Date

APPENDIX J
Page 7 of 8WBN 0564-091
Att 1 pg 4 of 4WALKDOWN DOCUMENTATION FORM (Example)
Continuation SheetWalkdown Identification No. WBN-0564-071-15C

Page 4 of 4

This following is a list of sleeves found between elevations 716.0' and 721.0' that were not sealed (RBI crane wall)

Room	Elev. (ft.)	Sleeve Size	Pipe Size	Qty	
Acc. Rm. 1	716.3	4"	1"	1	
Acc. Rm. 2	716.3	4"	1"	1	
Acc. Rm. 2	718.5	8"	EMPTY	1	/R1
Acc. Rm. 3	716.3	4"	1"	1	
Acc. Rm. 3	718.5	8"	Empty	1	
Acc. Rm. 4	716.3	4"	1"	1	
Acc. Rm. 4	717.0	4"	1 - 3/8"	1	
			tube		
Acc. Rm. 4	718.0	24"	14" (2" / 4")	1	/R1
Acc. Rm. 4	718.5	8"	2 - 3/8"	1	
			tubes		
Acc. Rm. 4	721.0	18"	2 - 3/8"	1	
			tubes		
Excess	721.0	4"	Empty	1	
Letdown Hx.					
Excess	Bot. el.	1.66' x	Empty	1	
Letdown Hx:	716.0'	1.5'			

Note: There were no openings in Cooling Rm. 1 & 2.

^{R1}
Dennis Peiffer ^{J.H. Sullivan}
Data Taker (Print)

^{R1}
^{12/3/92}
George M. Herron ¹⁶⁻⁴⁻⁹²
Data Taker Signature Date

GEORGE M. HERRON ^{R1}
Data Verifier (Print)

^{R1}
George M. Herron ^{12/3/92}
George M. Herron ¹⁶⁻¹⁰⁻⁹²
Data Verifier Signature Date

Physical Properties of Water

9187/12

Temperature of Water t	Saturation Pressure P'	Specific Volume V	Weight Density ρ	Weight
Degrees Fahrenheit	Pounds per Square Inch Absolute	Cubic Feet Per Pound	Pounds per Cubic Foot	Pounds Per Gallon
32	0.08859	0.016022	62.414	8.3436
40	0.12163	0.016019	62.426	8.3451
50	0.17796	0.016023	62.410	8.3430
60	0.25611	0.016033	62.371	8.3378
70	0.36292	0.016050	62.305	8.3290
80	0.50683	0.016072	62.220	8.3176
90	0.69813	0.016099	62.116	8.3037
100	0.94924	0.016130	61.996	8.2877
110	1.2750	0.016165	61.862	8.2698
120	1.6927	0.016204	61.7132	8.2498
130	2.2230	0.016247	61.550	8.2280
140	2.8892	0.016293	61.376	8.2048
150	3.7184	0.016343	61.188	8.1797
160	4.7414	0.016395	60.994	8.1537
170	5.9926	0.016451	60.787	8.1260
180	7.5110	0.016510	60.569	8.0969
190	9.340	0.016572	60.343	8.0667
200	11.526	0.016637	60.107	8.0351
210	14.123	0.016705	59.862	8.0024
212	14.696	0.016719	59.812	7.9957
220	17.186	0.016775	59.613	7.9690
240	24.968	0.016926	59.081	7.8979
260	35.427	0.017089	58.517	7.8226
280	49.200	0.017264	57.924	7.7433
300	67.005	0.01745	57.307	7.6608
350	134.604	0.01799	55.586	7.4308
400	247.259	0.01864	53.648	7.1717
450	422.55	0.01943	51.467	6.8801
500	680.86	0.02043	48.948	6.5433
550	1045.43	0.02176	45.956	6.1434
600	1543.2	0.02364	42.301	5.6548
650	2208.4	0.02674	37.397	4.9993
700	3094.3	0.03662	27.307	3.6505

Specific gravity of water at 60 F = 1.00

Weight per gallon is based on 7.48052 gallons per cubic foot.


All data on volume and pressure are abstracted from ASME Steam Tables (1967), with permission of publisher, The American Society of Mechanical Engineers, 345 East 47th Street, New York, N.Y. 10017.

Exat
of a
speci

Ac
An
Be
Br
B
Bu
Ca
Di
Fu
Fu
Fu
Fu
Ca
G
K
M

Relative Roughness of Pipe Materials and Friction Factors For Complete Turbulence¹⁸

WBJ-0504-091
Att 2 p 2 of 10



Data extracted from *Friction Factors for Pipe Flow* by L.F. Moody, with permission of the publisher, The American Society of Mechanical Engineers, 29 West 39th Street, New York.


Problem: Determine absolute and relative roughness, and friction factor, for fully turbulent flow in 10-inch cast iron pipe (I.D. = 10.16").
Solution: Absolute roughness (ϵ) = 0.00085.....Relative roughness (ϵ/D) = 0.001.....Friction factor at fully turbulent flow (f) = 0.0196.

WBN-0304-091
 H# 2 9930410
 "K" FACTOR TABLE—SHEET 4 of 4

Representative Resistance Coefficients (K) for Valves and Fittings
 (for formulas and friction data, see page A-26)


PLUG VALVES AND COCKS

Straight-Way



If: $\beta = 1$,
 $K_1 = 18 f_r$

3-Way



View X—X

If: $\beta = 1$,
 $K_1 = 30 f_r$

If: $\beta = 1$,
 $K_1 = 90 f_r$

If: $\beta < 1 \dots K_2 = \text{Formula 6}$

STANDARD ELBOWS

90°



$K = 30 f_r$

45°




$K = 16 f_r$

STANDARD TEES



Flow thru run..... $K = 20 f_r$
 Flow thru branch.... $K = 60 f_r$

MITRE BENDS



α	K
0°	2 f_r
15°	4 f_r
30°	8 f_r
45°	15 f_r
60°	25 f_r
75°	40 f_r
90°	60 f_r

90° PIPE BENDS AND FLANGED OR BUTT-WELDING 90° ELBOWS



r/d	K	r/d	K
1	20 f_r	10	30 f_r
2	12 f_r	12	34 f_r
3	12 f_r	14	38 f_r
4	14 f_r	16	42 f_r
6	17 f_r	18	46 f_r
8	24 f_r	20	50 f_r

The resistance coefficient, K_B , for pipe bends other than 90° may be determined as follows:

$$K_B = (n - 1) \left(0.25 \pi f_r \frac{r}{d} + 0.5 K \right) + K$$

n = number of 90° bends

K = resistance coefficient for one 90° bend (per table)

CLOSE PATTERN RETURN BENDS



$K = 50 f_r$

PIPE ENTRANCE

Inward Projecting




$K = 0.78$

r/d	K
0.00°	0.5
0.02	0.28
0.04	0.24
0.06	0.15
0.10	0.09
0.15 & up	0.04

*Sharp-edged

Flush



For K , see table

PIPE EXIT

Projecting



$K = 1.0$

Sharp-Edged



$K = 1.0$

Rounded



$K = 1.0$

Summary of Formulas

To eliminate needless duplication, formulas have been written in terms of either specific volume \bar{V} or weight density ρ , but not in terms of both, since one is the reciprocal of the other.

$$\bar{V} = \frac{1}{\rho} \quad \rho = \frac{1}{\bar{V}}$$

These equations may be substituted in any of the formulas shown in this paper whenever necessary.

● **Bernoulli's theorem:** Equation 3-1

$$Z + \frac{144 P}{\rho} + \frac{v^2}{2g} = H$$

$$Z_1 + \frac{144 P_1}{\rho_1} + \frac{v_1^2}{2g} = Z_2 + \frac{144 P_2}{\rho_2} + \frac{v_2^2}{2g} + h_L$$

● **Mean velocity of flow in pipe:** (Continuity Equation) Equation 3-2

$$v = \frac{q}{A} = 183.3 \frac{q}{d^2} = 0.408 \frac{Q}{d^2}$$

$$v = 0.286 \frac{B}{d^2} = 183.3 \frac{w\bar{V}}{d^2} = 0.0509 \frac{W\bar{V}}{d^2}$$

$$v = 0.00144 \frac{q'_A T}{\rho' d^2} = 0.00389 \frac{q'_A S_g}{\rho d^2}$$

$$V = \frac{q_m}{A} = 2.40 \frac{W\bar{V}}{a} = 3.06 \frac{W\bar{V}}{d^2}$$

$$V = 0.0865 \frac{q'_A T}{\rho' d^2} = 0.233 \frac{q'_A S_g}{\rho d^2}$$

● **Reynolds number of flow in pipe:** Equation 3-3

$$R_e = \frac{Dv\rho}{\mu} = \frac{Dv\rho}{32.2\mu'} = 123.9 \frac{dv\rho}{\mu}$$

$$R_e = 22,700 \frac{qp}{d\mu} = \frac{4739p}{R_H\mu} = 50.6 \frac{Qp}{d\mu}$$

$$R_e = 6.31 \frac{W}{d\mu} = 0.482 \frac{q'_A S_g}{d\mu} = 35.4 \frac{Bp}{d\mu}$$

$$R_e = \frac{Dv}{\nu'} = \frac{dv}{12\nu'} = 7740 \frac{dv}{\nu}$$

$$R_e = 1,419,000 \frac{q}{\nu d} = 3160 \frac{Q}{\nu d} = 394 \frac{W\bar{V}}{\nu d}$$

● **Viscosity equivalents:** Equation 3-4

$$\nu = \frac{\mu}{\rho} = \frac{\mu}{S}$$

● **Head loss and pressure drop in straight pipe:**

Pressure loss due to flow is the same in a sloping, vertical, or horizontal pipe. However, the difference in pressure due to the difference in head must be considered in pressure drop calculations; see page 1-5.

Darcy's formula:

Equation 3-5

$$h_L = f \frac{L}{D} \frac{v^2}{2g} = 0.1863 \frac{fLv^2}{d}$$

$$h_L = 6260 \frac{fLq^2}{d^5} = 0.0311 \frac{fLQ^2}{d^5}$$

$$h_L = 0.01524 \frac{fLB^2}{d^5} = 0.000483 \frac{fLW^2\bar{V}^2}{d^5}$$

$$\Delta P = 0.001294 \frac{fL\rho v^2}{d} = 0.00000359 \frac{fL\rho V^2}{d}$$

$$\Delta P = 43.5 \frac{fL\rho q^2}{d^5} = 0.000216 \frac{fL\rho Q^2}{d^5}$$

$$\Delta P = 0.0001058 \frac{fL\rho B^2}{d^5} = 0.00000336 \frac{fLW^2\bar{V}}{d^5}$$

$$\Delta P = 0.00000000726 \frac{fLT(q'_A)^2 S_g}{d^5 \rho'}$$

$$\Delta P = 0.00000001959 \frac{fL(q'_A)^2 S_g^2}{d^5 \rho}$$

For simplified compressible fluid formula, see page 3-22.

● **Head loss and pressure drop with laminar flow in straight pipe:**

For laminar flow conditions ($R_e < 2000$), the friction factor is a direct mathematical function of the Reynolds number only, and can be expressed by the formula: $f = 64/R_e$. Substituting this value of f in the Darcy formula, it can be rewritten:

$$h_L = 0.0962 \frac{\mu L v}{d^2 \rho}$$

Equation 3-6

$$h_L = 17.65 \frac{\mu L q}{d^4 \rho} = 0.0393 \frac{\mu L Q}{d^4 \rho}$$

$$h_L = 0.0275 \frac{\mu L B}{d^4 \rho} = 0.00490 \frac{\mu L W}{d^4 \rho^2}$$

$$\Delta P = 0.000668 \frac{\mu L v}{d^2} = 0.1225 \frac{\mu L q}{d^4}$$

$$\Delta P = 0.000273 \frac{\mu L Q}{d^4} = 0.000191 \frac{\mu L B}{d^4}$$

$$\Delta P = 0.0000340 \frac{\mu L W}{d^4 \rho}$$

● **Limit**
Non-
The D.
for the
Howev
cause
pressu
calcu

Com
When
V basi
When
less th
based
tion 3
When
the re
page
(for tl

● **Iso**
in 1

w =

w =

● **Sir**
for

u

u

q'

● **M**
cc
The
fluid
in th

v

v

v

Summary of Formulas — continued

AA 2 79 504 10

● Limitations of Darcy formula

Non-compressible flow; liquids:

The Darcy formula may be used without restriction for the flow of water, oil, and other liquids in pipe. However, when extreme velocities occurring in pipe cause the downstream pressure to fall to the vapor pressure of the liquid, cavitation occurs and calculated flow rates are inaccurate.

Compressible flow; gases and vapors:

When pressure drop is less than 10% of P_1 , use ρ or \bar{V} based on either inlet or outlet conditions.

When pressure drop is greater than 10% of P_1 but less than 40% of P_1 , use the average of ρ or \bar{V} based on inlet and outlet conditions, or use Equation 3-20.

When pressure drop is greater than 40% of P_1 , use the rational or empirical formulas given on this page for compressible flow, or use Equation 3-20 (for theory, see page 1-9).

● Isothermal flow of gas in pipe lines

Equation 3-7

$$w = \sqrt{\frac{144g A^2}{\bar{V}_1 \left(f \frac{L}{D} + 2 \log_e \frac{P'_1}{P'_2} \right)}} \left(\frac{(P'_1)^2 - (P'_2)^2}{P'_1} \right)$$

$$w = 0.371 \sqrt{\frac{d^5}{\bar{V}_1 \left(f \frac{L}{D} + 2 \log_e \frac{P'_1}{P'_2} \right)}} \left(\frac{(P'_1)^2 - (P'_2)^2}{P'_1} \right)$$

● Simplified compressible flow for long pipe lines

Equation 3-7a

$$w = \sqrt{\left(\frac{144g A^2}{\bar{V}_1 f \frac{L}{D}} \right)} \left(\frac{(P'_1)^2 - (P'_2)^2}{P'_1} \right)$$

$$w = 0.1072 \sqrt{\left(\frac{d^5}{\bar{V}_1 f L} \right)} \left(\frac{(P'_1)^2 - (P'_2)^2}{P'_1} \right)$$

$$q'_h = 114.2 \sqrt{\left(\frac{(P'_1)^2 - (P'_2)^2}{f L_m T S_g} \right)} d^3$$

● Maximum (sonic) velocity of compressible fluids in pipe

The maximum possible velocity of a compressible fluid in a pipe is equivalent to the speed of sound in the fluid; this is expressed as:

$$v_s = \sqrt{k g R T} \quad \text{Equation 3-8}$$

$$v_s = \sqrt{k g 144 P' \bar{V}}$$

$$v_s = 68.1 \sqrt{k P' \bar{V}}$$

● Empirical formulas for the flow of water, steam, and gas

Although the rational method (using Darcy's formula) for solving flow problems has been recommended in this paper, some engineers prefer to use empirical formulas.

Hazen and Williams formula for flow of water:

Equation 3-9

$$Q = 0.442 d^{2.63} c \left(\frac{P_1 - P_2}{L} \right)^{0.54}$$

where:

 $c = 140$ for new steel pipe $c = 130$ for new cast iron pipe $c = 110$ for riveted pipe

Babcock formula for steam flow:

Equation 3-10

$$\Delta P = 0.000000363 \left(\frac{d + 3.6}{d^6} \right) W^2 L \bar{V}$$

$$\Delta P = 0.470 \left(\frac{d + 3.6}{d^6} \right) w^2 L \bar{V}$$

Spitzglass formula for low pressure gas: (pressure less than one pound gauge)

Equation 3-11

$$q'_h = 3550 \sqrt{\frac{\Delta h_w d^5}{S_g L \left(1 + \frac{3.6}{d} + 0.03 d \right)}}$$

Flowing temperature is 60 F.

Weymouth formula for high pressure gas:

Equation 3-12

$$q'_h = 28.0 d^{2.667} \sqrt{\left(\frac{(P'_1)^2 - (P'_2)^2}{S_g L_m} \right)} \left(\frac{520}{T} \right)$$

Panhandle formula² for natural gas pipe lines 6 to 24-inch diameter and $R_e = (5 \times 10^4)$ to (14×10^4) :

Equation 3-13

$$q'_h = 36.8 E d^{2.6182} \left(\frac{(P'_1)^2 - (P'_2)^2}{L_m} \right)^{0.8294}$$

where: gas temperature = 60 F

 $S_g = 0.6$ E = flow efficiency $E = 1.00$ (100%) for brand new pipe without any bends, elbows, valves, and change of pipe diameter or elevation $E = 0.95$ for very good operating conditions $E = 0.92$ for average operating conditions $E = 0.85$ for unusually unfavorable operating conditions

Summary of Formulas — continued

● Head loss and pressure drop through valves and fittings

Head loss through valves and fittings is generally given in terms of resistance coefficient K which indicates static head loss through a valve in terms of "velocity head", or, equivalent length in pipe diameters L/D that will cause the same head loss as the valve.

From Darcy's formula, head loss through a pipe is:

$$h_L = f \frac{L}{D} \frac{v^2}{2g} \quad \text{Equation 3-5}$$

and head loss through a valve is:

$$h_L = K \frac{v^2}{2g} \quad \text{Equation 3-14}$$

$$\text{therefore: } K = f \frac{L}{D} \quad \text{Equation 3-15}$$

To eliminate needless duplication of formulas, the following are all given in terms of K . Whenever necessary, substitute $(f L/D)$ for (K) .

$$h_L = \frac{522 K Q^2}{d^5} = 0.00259 \frac{K Q^2}{d^5} \quad \text{Equation 3-14}$$

$$h_L = 0.001270 \frac{K B^2}{d^5} = 0.0000403 \frac{K W^2 \sqrt{V}}{d^5}$$

$$\Delta P = 0.0001078 K \rho v^2 = 0.000000300 K \rho V^2$$

$$\Delta P = 3.62 \frac{K \rho Q^2}{d^5} = 0.00001799 \frac{K \rho Q^2}{d^5}$$

$$\Delta P = 0.00000882 \frac{K \rho B^2}{d^5}$$

$$\Delta P = 0.000000280 \frac{K W^2 \sqrt{V}}{d^5}$$

$$\Delta P = 0.00000000605 \frac{K (q'_h)^2 T S_g}{d^5 P}$$

$$\Delta P = 0.00000001633 \frac{K (q'_h)^2 S_g^2}{d^5 \rho}$$

For compressible flow with h_L or ΔP greater than approximately 10% of inlet absolute pressure, the denominator should be multiplied by Y^2 . For values of Y , see page A-21.

● Pressure drop and flow of liquids, using flow coefficient

$$\Delta P = \left(\frac{Q}{C_v} \right)^2 \frac{\rho}{62.4} \quad \text{Equation 3-16}$$

$$Q = C_v \sqrt{\Delta P \frac{62.4}{\rho}} = 7.90 C_v \sqrt{\frac{\Delta P}{\rho}}$$

$$C_v = Q \sqrt{\frac{\rho}{\Delta P (62.4)}} = \frac{20.9 d^2}{\sqrt{f L/D}} = \frac{20.9 d^2}{\sqrt{K}}$$

$$K = \frac{891 d^4}{(C_v)^2}$$

● Resistance coefficient, K , for sudden and gradual enlargements in pipes

If, $\theta \approx 45^\circ$,

$$K = 2.6 \sin^2 \frac{\theta}{2} (1 - \beta^2) \quad \text{*Equation 3-17}$$

If, $45^\circ < \theta \leq 180^\circ$,

$$K = (1 - \beta^2)^2 \quad \text{*Equation 3-17.1}$$

● Resistance coefficient, K , for sudden and gradual contractions in pipes

If, $\theta \approx 45^\circ$,

$$K = 0.5 \sin^2 \frac{\theta}{2} (1 - \beta^2) \quad \text{*Equation 3-18}$$

If, $45^\circ < \theta \leq 180^\circ$,

$$K = 0.5 \sqrt{\sin^2 \frac{\theta}{2}} (1 - \beta^2) \quad \text{*Equation 3-18.1}$$

*Note: The values of the resistance coefficients (K) in equations 3-17, 3-17.1, 3-18, and 3-18.1 are based on the velocity in the small pipe. To determine K values in terms of the greater diameter, divide the equations by β^4 .

● Discharge of fluid through valves, fittings, and pipe; Darcy's formula

Liquid flow:

Equation 3-19

$$Q = 0.0438 d^2 \sqrt{\frac{h_L}{K}} = 0.525 d^2 \sqrt{\frac{\Delta P}{K \rho}}$$

$$Q = 19.65 d^2 \sqrt{\frac{h_L}{K}} = 236 d^2 \sqrt{\frac{\Delta P}{K \rho}}$$

$$W = 0.0438 \rho d^2 \sqrt{\frac{h_L}{K}} = 0.525 d^2 \sqrt{\frac{\Delta P \rho}{K}}$$

$$W = 157.6 \rho d^2 \sqrt{\frac{h_L}{K}} = 1891 d^2 \sqrt{\frac{\Delta P \rho}{K}}$$

Compressible flow:

Equation 3-20

$$q'_h = 40700 Y d^2 \sqrt{\frac{\Delta P P_1}{K T_1 S_g}}$$

$$q'_h = 24700 \frac{Y d^2}{S_g} \sqrt{\frac{\Delta P P_1}{K}}$$

$$q'_m = 678 Y d^2 \sqrt{\frac{\Delta P P_1}{K T_1 S_g}} = 412 \frac{Y d^2}{S_g} \sqrt{\frac{\Delta P P_1}{K}}$$

$$q' = 11.30 Y d^2 \sqrt{\frac{\Delta P P_1}{K T_1 S_g}} = 6.87 \frac{Y d^2}{S_g} \sqrt{\frac{\Delta P P_1}{K}}$$

$$W = 0.525 Y d^2 \sqrt{\frac{\Delta P}{K V_1}} \quad W = 1891 Y d^2 \sqrt{\frac{\Delta P}{K V_1}}$$

Values of Y are shown on page A-22. For K , Y , and ΔP determination, see examples on pages 4-13 and 4-14.

● Flo
(h_L
at

Liqui

q

q

Q

w

W

Com

q'_h

q'_h

q'_m

q'_m

q'

q'

u

W

● Eq
an

h_i

● Ch
re
fo

K

Sub:

Sub:

K w

Summary of Formulas — conclude

WBN 0304-091
 AH 2 PG 7 OF 10

- Flow through nozzles and orifices
 (h_L and ΔP measured across taps
 at 1 diameter and 0.5 diameter)

Liquid: Equation 3-21

$$q = AC \sqrt{2g h_L}$$

$$q = 0.0438 d_1^2 C \sqrt{h_L} = 0.525 d_1^2 C \sqrt{\frac{\Delta P}{\rho}}$$

$$Q = 19.65 d_1^2 C \sqrt{h_L} = 236 d_1^2 C \sqrt{\frac{\Delta P}{\rho}}$$

$$w = 0.0438 d_1^2 C \sqrt{h_L \rho} = 0.525 d_1^2 C \sqrt{\Delta P \rho}$$

$$W = 157.6 d_1^2 C \sqrt{h_L \rho} = 1891 d_1^2 C \sqrt{\Delta P \rho}$$

Values of C are shown on page A-20

Compressible fluids: Equation 3-22

$$q'_A = 40.700 Y d_1^2 C \sqrt{\frac{\Delta P P_1}{T_1 S_1}}$$

$$q'_A = 24.700 \frac{Y d_1^2 C}{S_1} \sqrt{\Delta P P_1}$$

$$q'_m = 678 Y d_1^2 C \sqrt{\frac{\Delta P P_1}{T_1 S_1}}$$

$$q'_m = 412 \frac{Y d_1^2 C}{S_1} \sqrt{\Delta P P_1}$$

$$q' = 11.30 Y d_1^2 C \sqrt{\frac{\Delta P P_1}{T_1 S_1}}$$

$$q' = 6.87 \frac{Y d_1^2 C}{S_1} \sqrt{\Delta P P_1}$$

$$w = 0.525 Y d_1^2 C \sqrt{\frac{\Delta P}{V_1}}$$

$$W = 1891 Y d_1^2 C \sqrt{\frac{\Delta P}{V_1}}$$

Values of C are shown on page A-20
 Values of Y are shown on page A-21

- Equivalent of head loss
 and pressure drop

Equation 3-23

$$h_L = \frac{144 \Delta P}{\rho} \quad \Delta P = \frac{h_L \rho}{144}$$

- Changes in resistance coefficient, K ,
 required to compensate
 for different pipe I. D.

Equation 3-24

$$K_a = K_b \left(\frac{d_a}{d_b} \right)^4$$

(see page A-30)

Subscript a refers to pipe in which valve will be installed.
 Subscript b refers to pipe for which the resistance coefficient
 K was established.

- Specific gravity of liquids

Any liquid: Equation 3-25

$$S = \frac{\rho \text{ (any liquid at 60 F, unless otherwise specified)}}{\rho \text{ (water at 60 F)}}$$

Oils: Equation 3-26

$$S (60 \text{ F}/60 \text{ F}) = \frac{141.5}{131.5 + \text{Deg API}}$$

Liquids lighter than water: Equation 3-27

$$S (60 \text{ F}/60 \text{ F}) = \frac{140}{130 + \text{Deg Baumé}}$$

Liquids heavier than water: Equation 3-28

$$S (60 \text{ F}/60 \text{ F}) = \frac{145}{145 - \text{Deg Baumé}}$$

- Specific gravity of gases

Equation 3-29

$$S_g = \frac{R \text{ (air)}}{R \text{ (gas)}} = \frac{53.3}{R \text{ (gas)}}$$

$$S_g = \frac{M \text{ (gas)}}{M \text{ (air)}} = \frac{M \text{ (gas)}}{29}$$

- General gas laws for perfect gases

$$p'V_a = w_a RT \quad \text{Equation 3-30}$$

$$\rho = \frac{w_a}{V_a} = \frac{p'}{RT} = \frac{14.7 p'}{RT} \quad \text{Equation 3-31}$$

$$R = \frac{1544}{M} = \frac{144 p'}{\rho T} \quad \text{Equation 3-32}$$

Equation 3-33

$$p'V_a = n_a MRT = n_a 1544 T = \frac{w_a}{M} 1544 T$$

Equation 3-34

$$\rho = \frac{w_a}{V_a} = \frac{p' M}{1544 T} = \frac{P' M}{10.72 T} = \frac{2.70 P' S_g}{T}$$

where:

$$n_a = w_a / M = \text{number of mols of a gas}$$

- Hydraulic radius*

Equation 3-35

$$R_H = \frac{\text{cross sectional flow area (sq. feet)}}{\text{wetted perimeter (feet)}}$$

Equivalent diameter relationship:

$$D = 4R_H$$


$$d = 48R_H$$

*See page 1-4 for limitations.

Application of Hydraulic Radius to Flow Problems

Example 4-25...Rectangular Duct

Given: A rectangular concrete overflow aqueduct, 25 feet high and 16.5 feet wide, has an absolute roughness (ϵ) of 0.01 foot.



Find: The discharge rate in cubic feet per second when the liquid in the reservoir has reached the maximum height indicated in the above sketch. Assume the average temperature of the water is 60 F.

Solution:

$$1. \quad h_L = \frac{v^2}{2g} (K_e + K_a) = \frac{v^2}{2g} \left(K_e + \frac{fL}{4R_H} \right)$$

$$2. \quad v = \frac{q}{A}$$

$$3. \quad q = 0.0438 d^2 \sqrt{\frac{h_L}{K_e + K_a}} \quad \dots \text{page 3-4}$$

$$q = 8.05 A \sqrt{\frac{h_L}{K_e + K_a}}$$

$$q = 8.05 A \sqrt{\frac{h_L}{K_e + f \frac{L}{4R_H}}}$$

where; K_e = resistance of entrance and exit
 K_a = resistance of aqueduct

To determine the friction factor from the Moody diagram, an equivalent diameter four times the hydraulic radius is used; refer to page 3-5.

$$R_H = \frac{\text{cross sectional flow area}}{\text{wetted perimeter}}$$

$$R_H = \frac{47390}{R_H \mu} \quad \dots \text{page 3-2}$$

4. Assuming a sharp edged entrance,
 $K = 0.5 \quad \dots \text{page A-29}$

Assuming a sharp edged exit to atmosphere,
 $K = 1.0 \quad \dots \text{page A-29}$

Then, resistance of entrance and exit,
 $K_e = 0.5 + 1.0 = 1.5$

$$5. \quad R_H = \frac{16.5 \times 25}{2(16.5 + 25)} = 4.97 \text{ ft.}$$

6. Equivalent diameter relationship:
 $D = 4R_H = 4 \times 4.97 = 19.88 \dots \text{page 3-5}$
 $d = 48R_H = 48 \times 4.97 = 239 \dots \text{page 3-5}$

7. Relative roughness, $\epsilon/D = 0.0005 \dots \text{page A-23}$

8. $f = 0.017 \dots \text{fully turbulent flow assumed; page A-23}$

$$9. \quad q = 8.05 \times 25 \times 16.5 \sqrt{\frac{200}{1.5 + \frac{0.017 \times 1000}{19.88}}}$$

$$q = 30500$$

10. Calculate R_e and check, $f = 0.017$ for $q = 30500$ cfs flow.

$$11. \quad \rho = 62.371 \quad \dots \text{page A-6}$$

$$12. \quad \mu = 1.1 \quad \dots \text{page A-3}$$

$$13. \quad R_e = \frac{473 \times 30500 \times 62.371}{4.97 \times 1.1}$$

$$R_e = 164000000 \text{ or } 1.64 \times 10^8$$

14. $f = 0.017 \dots \text{for calculated } R_e; \text{ page A-24}$

15. Since the friction factor assumed in Step 8 and that determined in Step 14 are in agreement, the discharge flow will be 30500 cfs.

16. If the assumed friction factor and the friction factor based on the calculated Reynolds number were not in reasonable agreement, the former should be adjusted and calculations repeated until reasonable agreement is reached.

CR

Exam

Given
 unif
 dian
 foot.

Fin

Solu

1.

dian
 for

2.

3.

4.

5.

6.

7.

8.


9.

Application of Hydraulic Radius to Flow Problems — continued

HA 2 799 05 10

Example 4-26...Pipe Partially Filled With Flowing Water

Given: A cast iron pipe is two-thirds full of steady, uniform flowing water (60 F). The pipe has an inside diameter of 24 inches and a slope of $\frac{3}{4}$ -inch per foot. Note the sketch that follows.



Find: The flow rate in gallons per minute.

Solution:

$$1. \quad Q = 19.65 d^2 \sqrt{\frac{h_L D}{f L}} \quad \dots \text{page 3-4}$$

Since pipe is flowing partially full an equivalent diameter based upon hydraulic radius is substituted for D in Equation 1 (see page 1-4).

$$D = 4R_H \quad \dots \text{page 3-5}$$

$$2. \quad Q = 19.65 d^2 \sqrt{\frac{h_L 4R_H}{f L}} = 39.3 d^2 \sqrt{\frac{h_L R_H}{f L}}$$

$$3. \quad R_H = \frac{\text{cross sectional flow area}}{\text{wetted perimeter}} \quad \dots \text{page 3-5}$$

$$4. \quad R_e = \frac{4739 \rho}{R_H \mu} = 1.054 \frac{Q \rho}{R_H \mu} \quad \dots \text{page 5-2}$$

5. Depth of flowing water equals:

$$\frac{2}{3} (24) = 16 \text{ in.}$$

$$6. \quad \cos \theta = \frac{1}{r} = \frac{1}{12} = 0.333$$

$$\theta = 70^\circ 32'$$

$$\alpha = 90^\circ - 70^\circ 32' = 19^\circ 28' = 19.47^\circ$$

$$7. \quad \text{Area C} = \frac{\pi d^2}{4} \left[\frac{180 + (2 \times 19.47)}{360} \right]$$

$$\text{Area C} = \frac{\pi 24^2}{4} \left(\frac{218.94}{360} \right) = 275 \text{ in}^2$$

$$8. \quad b = \sqrt{r^2 - 4^2} = \sqrt{12^2 - 16} = 11.31 \text{ in.}$$

$$9. \quad \text{Area A} = \text{Area B} = \frac{1}{2} (4b) = \frac{1}{2} (4 \times 11.31) \\ \text{Area A or B} = 22.6 \text{ in}^2$$

10. The cross sectional flow area equals:

$$A = B + C = 22.6 + 22.6 + 275 = 320.2 \text{ in}^2$$

$$A = B + C = \frac{320.2}{144} = 2.22 \text{ ft}^2$$

$$11. \quad d^2 = \frac{4Q}{\pi} = \frac{4 \times 320.2}{\pi} = 408 \\ \text{depth} = \left(\frac{\text{cross sec flow area}}{78.5} \right)^{\frac{1}{2}}$$

$$12. \quad h_L = \Delta h = \frac{0.75}{12} = 0.0625 \text{ ft per ft}$$

13. The wetted perimeter equals:

$$\pi d \left(\frac{218.94}{360} \right)$$

$$= 24 \left(\frac{218.94}{360} \right) = 45.9 \text{ in.}$$

$$\frac{45.9}{12} = 3.83 \text{ ft.}$$

$$14. \quad R_H = \frac{2.22}{3.83} = 0.580$$

$$15. \quad \text{Equivalent diameter } d = 4R_H \quad \dots \text{page 3-5} \\ d = 4(0.580) = 2.32$$

$$16. \quad \text{Relative roughness } \frac{\epsilon}{D} = 0.00036 \quad \dots \text{page A-23}$$

$$17. \quad f = 0.0155 \quad \dots \text{assuming fully turbulent flow; page A-23}$$

$$18. \quad Q = 39.3 \times 408 \sqrt{\frac{0.0625 \times 0.580}{0.0155 \times 1}} \\ Q = 24,500 \text{ gpm}$$

19. Calculate the Reynolds number to check the friction factor assumed in Step 17.

$$20. \quad \rho = 62.371 \quad \dots \text{page A-6}$$

$$21. \quad \mu = 1.1 \quad \dots \text{page A-3}$$

$$22. \quad R_e = \frac{1.054 \times 24,500 \times 62.371}{0.580 \times 1.1}$$

$$R_e = 2,520,000 \text{ or } 2.52 \times 10^6$$

$$23. \quad f = 0.0155 \quad \dots \text{page A-24}$$

24. Since the friction factor assumed in Step 17 and that determined in Step 23 are in agreement, the flow rate will be 24,500 gpm.

25. If the assumed friction factor and the friction factor based on the calculated Reynolds number were not in reasonable agreement, the former should be adjusted and calculations repeated until reasonable agreement is reached.

Nature of Flow in Pipe — Laminar and Turbulent




Figure 1-1
Laminar Flow

Actual photograph of colored filaments being carried along undisturbed by a stream of water.




Figure 1-2
Flow in Critical Zone, Between
Laminar and Transition Zones
At the critical velocity, the filaments begin to
break up, indicating flow is becoming
turbulent.




Figure 1-3
Turbulent Flow

This illustration shows the turbulence in the stream completely dispersing the colored filaments a short distance downstream from the point of injection.

A simple experiment (illustrated above) will readily show there are two entirely different types of flow in pipe. The experiment consists of injecting small streams of a colored fluid into a liquid flowing in a glass pipe and observing the behavior of these colored streams at different sections downstream from their points of injection.

If the discharge or average velocity is small, the streaks of colored fluid flow in straight lines, as shown in Figure 1-1. As the flow rate is gradually increased, these streaks will continue to flow in straight lines until a velocity is reached when the streaks will waver and suddenly break into diffused patterns, as shown in Figure 1-2. The velocity at which this occurs is called the "critical velocity". At velocities higher than "critical", the filaments are dispersed at random throughout the main body of the fluid, as shown in Figure 1-3.

The type of flow which exists at velocities lower than "critical" is known as laminar flow and, sometimes, as viscous or streamline flow. Flow of this nature is characterized by the gliding of concentric cylindrical layers past one another in orderly fashion. Velocity of the fluid is at its maximum at the pipe axis and decreases sharply to zero at the wall.

At velocities greater than "critical", the flow is turbulent. In turbulent flow, there is an irregular random motion of fluid particles in directions transverse to the direction of the main flow. The velocity distribution in turbulent flow is more uniform across the pipe diameter than in laminar flow. Even though a turbulent motion exists throughout the greater portion of the pipe diameter, there is always a thin layer of fluid at the pipe wall . . . known as the "boundary layer" or "laminar sub-layer" . . . which is moving in laminar flow.

Mean velocity of flow: The term "velocity", unless otherwise stated, refers to the mean, or average, velocity at a given cross section, as determined by the continuity equation for steady state flow:

$$v = \frac{q}{A} = \frac{w}{A\rho} = \frac{wV}{A}$$

Equation 1-1

(For nomenclature, see page preceding Chapter 1)

"Reasonable" velocities for use in design work are given on pages 3-6 and 3-16.

Reynolds number: The work of Osborne Reynolds has shown that the nature of flow in pipe . . . that is, whether it is laminar or turbulent . . . depends on the pipe diameter, the density and viscosity of the flowing fluid, and the velocity of flow. The numerical value of a dimensionless combination of these four variables, known as the Reynolds number, may be considered to be the ratio of the dynamic forces of mass flow to the shear stress due to viscosity. Reynolds number is:

$$R_e = \frac{Dv\rho}{\mu}$$

Equation 1-2

(other forms of this equation; page 3-2.)

For engineering purposes, flow in pipes is usually considered to be laminar if the Reynolds number is less than 2000, and turbulent if the Reynolds number is greater than 4000. Between these two values lies the "critical zone" where the flow . . . being laminar, turbulent, or in the process of change, depending upon many possible varying conditions . . . is unpredictable. Careful experimentation has shown that the laminar zone may be made to terminate at a Reynolds number as low as 1200 or extended as high as 40,000, but these conditions are not expected to be realized in ordinary practice.

Hydraulic radius: Occasionally a conduit of non-circular cross section is encountered. In calculating the Reynolds number for this condition, the equivalent diameter (four times the hydraulic radius) is substituted for the circular diameter. Use friction factors given on pages A-24 and A-25.

$$R_H = \frac{\text{cross sectional flow area}}{\text{wetted perimeter}}$$


This applies to any ordinary conduit (circular conduit not flowing full, oval, square or rectangular) but not to extremely narrow shapes such as annular or elongated openings, where width is small relative to length. In such cases, the hydraulic radius is approximately equal to one-half the width of the passage.

To determine quantity of flow in following formula:

$$q = 0.0438 d^2 \sqrt{\frac{h_L D}{f L}}$$

the value of d^2 is based upon an equivalent diameter of actual flow area and $4R_H$ is substituted for D .

The Bernoulli equation can be applied to the flow in any part



Barometric Pressure or
Absolute Atmospheric Pressure

Calculation WBNOSG4091
MAXIMUM CONTAINMENT WATER LEVEL
Attachment 3

From: Jordan, Gary T.
Sent: Monday, December 03, 2001 10:14 AM
To: Lund, John F.
Subject: RE: Ice Mass
John,

We weigh our ice baskets during each RFO. During each RFO, we perform a 100% as-found weighing and then service any basket below our established administrative limit on net ice weight. The baskets that we service, we re-weigh to establish an as-left net ice weight. Any basket that we don't service, we assume maintains the as-found ice weight. All of these weights are documented in the MI-61.06 data package that is maintained in the vault. I also keep all ice weights in my ICEMAN program plus I maintain an Excel spreadsheet that allows me to cut the ice bed in any number of different looks to see just what's going on at any point. The number provided to you is based upon the as-left net ice weight of all baskets (either re-weighed or assumed) and totaled by the Excel spreadsheet. That number for total as-left ice mass at the conclusion of RFO2 was 2.78E6 pounds and does not credit any ice weight maintained in 14 baskets that were unweighable in either the as-found or as-left condition. These 14 baskets could provide you with approximately another 21,000 pounds (assuming 1500/basket). Final assumed as-left net ice weight in the Ice Condenser at the conclusion of RFO2 would have been approximately 2.8E6 pounds.

If you need anything else on this, please let me know and we'll discuss.

Thanks.

Gary T. Jordan

NSSS System Engineer

System 61 - Ice Condenser

System 84 - Flood Mode Boration

EQB-1F, Watts Bar Nuclear Plant

Phone: (423) 365-1454

Pager: (Onsite) 450, then 40607

(Offsite) (800) 323-4853, then 40607

Fax: (423) 365-7845

E-mail: gtjordan@tva.gov

-----Original Message-----

From: Lund, John F.
Sent: Friday, November 30, 2001 2:57 PM
To: Jordan, Gary T.
Subject: Ice Mass

Gary,

When I discussed this subject with you earlier this year, I got information that said the ice mass was 2,781,373 lbm as of Apr 1999. Could you provide me a reference for this information?

John