

Industry/TSTF Standard Technical Specification Change Traveler

Revise SR 3.1.4.1 to correct MTC reference

Priority/Classification 1) Correct Specifications

NUREGs Affected: 1430 1431 1432 1433 1434

Description:

Revise SR 3.1.4.1 to verify MTC is within the upper limits, which may not be in the COLR.

Justification:

LCO 3.1.4 states that the maximum positive MTC limit is specified in Figure 3.1.4-1. The COLR may contain a cycle-specific positive limit. Therefore, SR 3.1.4.1, which requires verification that the MTC is within the upper limits, should not specify the location of the limit. This change is consistent with NUREG-1431.

Revision History

OG Revision 0

Revision Status: Active

Next Action:

Revision Proposed by: Calvert Cliffs

Revision Description:
Original Issue

Owners Group Review Information

Date Originated by OG: 24-Oct-96

Owners Group Comments
(No Comments)

Owners Group Resolution: Approved Date: 24-Oct-96

TSTF Review Information

TSTF Received Date: 04-Nov-96 Date Distributed for Review 20-Jan-97

OG Review Completed: BWOG WOG CEOG BWROG

TSTF Comments:

Revise Traveler to match WOG SR, "Verify MTC is within the upper limit."

WOG - Not applicable, accepts

BWOG - Not applicable, accepts

BWROG - Not applicable, accepts

TSTF Resolution: Approved Date: 06-Mar-97

NRC Review Information

NRC Received Date: 27-Mar-97 NRC Reviewer: SCHULTEN,

NRC Comments:

4/7/97 Rec'd pkg.

4/10/97 Forwarded to reviewer.

Final Resolution: NRC Approves

Final Resolution Date: 06-Oct-97

4/2/98

Incorporation Into the NUREGs

File to BBS/LAN Date:

TSTF Informed Date:

TSTF Approved Date:

NUREG Rev Incorporated:

Affected Technical Specifications

SR 3.1.4.1

MTC (Analog)

4/2/98

TSTF-172

3.1 REACTIVITY CONTROL SYSTEMS

3.1.4 Moderator Temperature Coefficient (MTC) (Analog)

LCO 3.1.4 The MTC shall be maintained within the limits specified in the COLR. The maximum positive limit shall be that specified in Figure 3.1.4-1.

APPLICABILITY: MODES 1 and 2.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. MTC not within limits.	A.1 Be in MODE 3.	6 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.1.4.1</p> <p>-----NOTE----- This Surveillance is not required to be performed prior to entry into MODE 2. -----</p> <p>Verify MTC is within the upper limits specified in the COLR.</p>	<p>Prior to entering MODE 1 after each fuel loading</p>

(continued)