
Industry/TSTF Standard Technical Specification Change Traveler

Replace the phrase "maximum allowed THERMAL POWER level" with "RTP"

Priority/Classification 2) Consistency/Standardization

NUREGs Affected: ☐ 1430 ☐ 1431 ☒ 1432 ☐ 1433 ☐ 1434

Description:

LCO 3.3.1, Required Action C requires Thermal Power to be restricted to $\leq 90\%$ of the "maximum allowed THERMAL POWER level." This phrase is undefined, and is intended to be the defined term "Rated Thermal Power," or RTP.

Justification:

Replacing the undefined phrase "maximum allowed THERMAL POWER level" with the defined phrase "RTP" eliminates possible misinterpretation of the Action and is consistent with the conventions in the NUREGs. This change is also consistent with the CEOG Digital Actions.

Revision History

OG Revision 0

Revision Status: Active

Next Action:

Revision Proposed by: Calvert Cliffs

Revision Description:
Original Issue

Owners Group Review Information

Date Originated by OG: 24-Oct-96

Owners Group Comments
(No Comments)

Owners Group Resolution: Approved Date: 24-Oct-96

TSTF Review Information

TSTF Received Date: 04-Nov-96 Date Distributed for Review 20-Jan-97

OG Review Completed: ☒ BWOG ☒ WOG ☒ CEOG ☒ BWROG

TSTF Comments:

WOG - Not applicable, accepts

BWOG - Not applicable, accepts

BWROG - Not applicable, accepts

TSTF Resolution: Approved Date: 06-Mar-97

NRC Review Information

NRC Received Date: 27-Mar-97 NRC Reviewer: SCHULTEN,

NRC Comments:

4/7/97 Rec'd pkg.

4/10/97 Forwarded to reviewer.

Final Resolution: NRC Approves

Final Resolution Date: 06-Oct-97

4/2/98

Incorporation Into the NUREGs

File to BBS/LAN Date:

TSTF Informed Date:

TSTF Approved Date:

NUREG Rev Incorporated:

Affected Technical Specifications

Action 3.3.1.C

RPS Instrumentation - Operating (Analog)

4/2/98

TSTF-179

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. One or more Functions with two RPS trip units or associated instrument channels inoperable except for Condition C (excore channel not calibrated with incore detectors).	-----NOTE----- LCO 3.0.4 is not applicable. -----	-
	B.1 Place one trip unit in bypass and place the other trip unit in trip. <u>AND</u> B.2 Restore one trip unit to OPERABLE status.	1 hour [48] hours
C. One or more Functions with one or more power range excore channels not calibrated with the incore detectors.	C.1 Perform SR 3.3.1.3. <u>OR</u>	24 hours
	C.2 Restrict THERMAL POWER to $\leq 90\%$ of the maximum allowed THERMAL POWER level. (RTP)	24 hours
D. One or more Functions with one automatic bypass removal channel inoperable.	D.1 Disable bypass channel. <u>OR</u>	1 hour
	D.2.1 Place affected trip units in bypass or trip. <u>AND</u>	1 hour (continued)