

February 24, 2004

EA-03-057

Mr. Gary Van Middlesworth  
Acting Site Vice-President  
Point Beach Nuclear Plant  
Nuclear Management Company, LLC  
6610 Nuclear Road  
Two Rivers, WI 54241-9516

SUBJECT: NOTICE OF VIOLATION (NRC INSPECTION REPORT 50-266/02-15(DRP);  
50-301/02-15(DRP))

Dear Mr. Van Middlesworth:

This will acknowledge receipt of a letter from the Nuclear Management Company, dated January 12, 2004, in response to our letter dated December 11, 2003, transmitting a Notice of Violation associated with a Yellow finding for Unit 1 and a Red finding for Unit 2. The findings involved the failure to adequately consider the design bases of the auxiliary feedwater system prior to the installation of a new-design orifice in the auxiliary feedwater pump recirculation lines. We have reviewed your corrective actions and have no further questions at this time.

Sincerely,

**/RA/**

Anton Vogel, Chief  
Reactor Projects Branch 7

Docket Nos. 50-266; 50-301  
License Nos. DPR-24; DPR-27

See Attached Distribution

DOCUMENT NAME: C:\ORPCheckout\FileNET\ML040560423.wpd

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	RIII		RIII				
NAME	MKunowski:ntp		AVegel				
DATE	02/24/04		02/24/04				

**OFFICIAL RECORD COPY**

cc: R. Kuester, President and Chief  
Executive Officer, We Generation  
J. Cowan, Executive Vice President  
Chief Nuclear Officer  
D. Cooper, Senior Vice President, Group Operations  
D. Weaver, Nuclear Asset Manager  
Plant Manager  
Regulatory Affairs Manager  
Training Manager  
J. Rogoff, Vice President, Counsel & Secretary  
K. Duveneck, Town Chairman  
Town of Two Creeks  
Chairperson  
Public Service Commission of Wisconsin  
J. Kitsembel, Electric Division  
Public Service Commission of Wisconsin  
State Liaison Officer

ADAMS Distribution:

WDR

DFT

DWS

RidsNrrDipmlipb

GEG

HBC

PGK1

DRPIII

DRSIII

PLB1

JRK1

INPO