
Industry/TSTF Standard Technical Specification Change Traveler

Delete inappropriate Condition entry statement

Priority/Classification 2) Consistency/Standardization

NUREGs Affected: 1430 1431 1432 1433 1434

Description:

The entry condition for Condition D is revised to omit the "Required Actions and associated Completion Times of Condition B not met."

Justification:

This Condition should only be applicable for Condition C not met since the Required Actions would never have to be completed for an entry due to Condition B not met. Condition B requires that the unit be placed in a MODE that will always be reached prior to completing even the first Required Action of Condition D. When Condition B is met, Condition D would no longer apply. This change is consistent with NUREG-1431 and NUREG-1432.

Revision History

OG Revision 0

Revision Status: Closed

Revision Proposed by: ANO-1

Revision Description:
Original Issue

Owners Group Review Information

Date Originated by OG: 07-Mar-97

Owners Group Comments
ANO-1-030

Owners Group Resolution: Approved Date: 22-Aug-97

TSTF Review Information

TSTF Received Date: 06-Nov-97 Date Distributed for Review 15-Dec-97

OG Review Completed: BWOG WOG CEOG BWROG

TSTF Comments:
B&W only.

TSTF Resolution: Approved Date: 05-Feb-98

NRC Review Information

NRC Received Date: 10-Mar-98 NRC Reviewer:

NRC Comments:

4/7/98 - NRC requests Bases changes to make the Bases consistent between the ISTS NUREGs. "The proposed change to STS 3.7.2 CONDITION D is acceptable; the change makes BWOG STS consistent with the WOG and CEOG STS. However, the associated Bases changes should either be deleted such that the BWOG STS is consistent with the WOG and CEOG STS, or the WOG and CEOG STS Bases should be changed to be consistent with the proposed BWOG Bases change."

Final Resolution: NRC Requests Changes: TSTF Considering Final Resolution Date: 10-Apr-98

4/26/98

TSTF Revision 1

Revision Status: Active

Next Action: NRC

Revision Proposed by: TSTF

Revision Description:

Revised in response to NRC request to not modify Bases. Bases change to BWOG 3.7.2, ACTIONS D.1 and D.2 removed.

TSTF Review Information

TSTF Received Date: 23-Apr-98

Date Distributed for Review 23-Apr-98

OG Review Completed: BWOG WOG CEOG BWROG

TSTF Comments:

(No Comments)

TSTF Resolution: Approved Date: 23-Apr-98

Incorporation Into the NUREGs

File to BBS/LAN Date:

TSTF Informed Date:

TSTF Approved Date:

NUREG Rev Incorporated:

Affected Technical Specifications

Action 3.7.2.D

MSIVs

4/26/98

MSIVs
3.7.2

3.7 PLANT SYSTEMS

3.7.2 Main Steam Isolation Valves (MSIVs)

LCO 3.7.2 Two MSIVs shall be OPERABLE.

APPLICABILITY: MODE 1,
MODES 2 and 3 except when all MSIVs are closed and
[deactivated].

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One MSIV inoperable in MODE 1.	A.1 Restore MSIV to OPERABLE status.	[8] hours
B. Required Action and associated Completion Time of Condition A not met.	B.1 Be in MODE 2.	6 hours
C. -----NOTE----- Separate Condition entry is allowed for each MSIV. ----- One or more MSIVs inoperable in MODE 2 or 3.	C.1 Close MSIV. <u>AND</u> C.2 Verify MSIV is closed.	[8] hours Once per 7 days
D. Required Action and associated Completion Time of Condition B B C not met.	D.1 Be in MODE 3. <u>AND</u> D.2 Be in MODE 4.	6 hours 12 hours