

### 3.3 INSTRUMENTATION

#### 3.3.4 Remote Shutdown System

LCO 3.3.4 The Remote Shutdown System Functions shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

#### ACTIONS

- NOTES-----
1. LCO 3.0.4 is not applicable.
  2. Separate Condition entry is allowed for each Function.
- 

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more required Functions inoperable.	A.1 Restore required Function to OPERABLE status.	30 days
B. Required Action and associated Completion Time not met.	B.1 Be in MODE 3.	6 hours
	<u>AND</u> B.2 Be in MODE 4.	12 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.3.4.1	Perform CHANNEL CHECK for each required instrumentation channel that is normally energized.	31 days
SR 3.3.4.2	Verify each required control circuit and transfer switch is capable of performing the intended function.	18 months
SR 3.3.4.3	<p>.....-NOTE-.....</p> <p>Neutron detectors are excluded from CHANNEL CALIBRATION.</p> <p>.....</p> <p>Perform CHANNEL CALIBRATION for each required instrumentation channel.</p>	18 months
SR 3.3.4.4	Perform TADOT of the reactor trip breaker open/closed indication.	18 months