

SURVEILLANCE REQUIREMENTS

-----NOTE-----
Refer to Table 3.3.6-1 to determine which SRs apply for each Containment
Ventilation Isolation Function.

SURVEILLANCE	FREQUENCY
SR 3.3.6.1 Perform CHANNEL CHECK.	12 hours
SR 3.3.6.2 Perform ACTUATION LOGIC TEST.	31 days on a STAGGERED TEST BASIS
SR 3.3.6.3 Perform MASTER RELAY TEST.	18 months
SR 3.3.6.4 Perform COT.	92 days
SR 3.3.6.5 Perform SLAVE RELAY TEST.	18 months
SR 3.3.6.6NOTE..... Verification of setpoint is not required. Perform TADOT.	18 months
SR 3.3.6.7 Perform CHANNEL CALIBRATION.	18 months

Containment Ventilation Isolation Instrumentation
3.3.6

Table 3.3.6-1 (page 1 of 1)
Containment Ventilation Isolation Instrumentation

FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS	SURVEILLANCE REQUIREMENTS	TRIP SETPOINT
1. Manual Initiation	1,2,3,4.(a)	2	SR 3.3.6.6	NA
2. Automatic Actuation Logic and Actuation Relays	1,2,3,4.(a)	2 trains	SR 3.3.6.2 SR 3.3.6.3 SR 3.3.6.5	NA
3. Containment Radiation				
a. Gaseous	1,2,3,4.(a)	1	SR 3.3.6.1 SR 3.3.6.4 SR 3.3.6.7	(b)
b. Particulate	1,2,3,4.(a)	1	SR 3.3.6.1 SR 3.3.6.4 SR 3.3.6.7	(b)
4. Safety Injection	Refer to LCO 3.3.2. "ESFAS Instrumentation," Functions 1.a-f. for all initiation functions and requirements.			

- (a) During movement of recently irradiated fuel assemblies within the containment.
(b) Trip Setpoint shall be in accordance with the methodology in the Offsite Dose Calculation Manual.