



AECL EACL

Assessment Document

**REVIEW OF DESIGN
FEATURES FOR SEVERE
ACCIDENT MANAGEMENT**

ACR-700

10810-03660-ASD-005

Revision 0

Prepared by
Rédigé par

Blahnik Charles

Reviewed by
Vérifié par

Nguyen Thinh

Approved by
Approuvé par

Jaitly Raj

Bonechi Massimo

2004/01/26
Controlled
Licensing

2004/01/26
Contrôlé
Licensing

©Atomic Energy of
Canada Limited

©Énergie Atomique du
Canada Limitée

2251 Speakman Drive
Mississauga, Ontario
Canada L5K 1B2

2251 rue Speakman
Mississauga (Ontario)
Canada L5K 1B2



Assessment Document

Review of Design Features for Severe Accident Management

ACR-700

10810-03660-ASD-005

Revision 0

2004 January

Janvier 2004

**CONTROLLED -
Licensing**

**CONTRÔLÉ -
Permis**

This document and the information contained in it is made available for licensing review. All rights reserved by Atomic Energy of Canada Limited. No part of this document may be reproduced or transmitted in any form or by any means, including photocopying and recording, without the written permission of the copyright holder, application for which should be addressed to Atomic Energy of Canada Limited. Such written permission must also be obtained before any part of this document is stored in a retrieval system of any nature.

Le présent document et l'information qu'il contient sont disponibles pour examen en vue de l'obtention des permis. Tous droits réservés par Énergie atomique du Canada limitée. Il est interdit de reproduire ou de transmettre, par quelque procédé que ce soit, y compris de photocopier ou d'enregistrer, toute partie du présent document, sans une autorisation écrite du propriétaire du copyright obtenue auprès d'Énergie atomique du Canada limitée. De plus, on doit obtenir une telle autorisation avant qu'une partie du présent document ne soit intégrée dans un système de recherche documentaire de quelque nature que ce soit.

© Atomic Energy of
Canada Limited

© Énergie atomique du
Canada limitée

2251 Speakman Drive
Mississauga, Ontario
Canada L5K 1B2

2251, rue Speakman
Mississauga (Ontario)
Canada L5K 1B2



Release and Revision History

Liste des documents et des révisions

0939B Rev. 13

Document Details / Détails sur le document

Title
Titre

Total no. of pages
N^{bre} total de pages

Review of Design Features for Severe Accident Management

CONTROLLED - Licensing / CONTRÔLÉ - Permis

Release and Revision History / Liste des documents et des révisions

Release Document		Revision Révision		Purpose of Release; Details of Rev./Amendement Objet du document; détails des rév. ou des modif.	Prepared by Rédigé par	Reviewed by Examiné par	Approved by Approuvé par
No./N ^o	Date	No./N ^o	Date				
1		D1	2003/12/09	Issued for Review and Comment.	C. Blahnik	E. Tin	M. Bonechi R. Jaitly
2		0	2004/01/28	Issued as "Approved for Use".	C. Blahnik	E. Tin T. Nguyen	M. Bonechi R. Jaitly

DCS/RMS Input / Données SCD ou SGD

Rel. Proj. Proj. conn.	Project Projet	SI	Section	Serial Série	Sheet Feuille No. N ^o	Of De	Unit No.(s) Tranche n ^o
	10810		ASD	005	1	1	

LIST OF ACRONYMS

ACR™*	Advanced CANDU Reactor
AECL	Atomic Energy of Canada Limited
ALARA	As Low As Reasonably Achievable (principle)
AM	Accident Management
CANDU®**	CANada Uranium Deuterium (reactor)
CNSC	Canadian Nuclear Safety Commission
CIS	Containment Isolation System
DBA	Design Basis Accident
DCH	Direct Containment Heating
ECCS	Emergency Core Cooling System
ECIS	Emergency Coolant Injection System (of ECCS)
EOP	Emergency Operating Procedure
EPRI	Electric Power Research Institute
HTS	Heat Transport System (same as RCS)
LAC	Local Air Cooler
LCD	Limited Core Damage (accident)
LOCA	Loss Of Coolant Accident
LR	Large Release (frequency)
LTCS	Long Term Cooling System
LWR	Light Water Reactor
MCR	Main Control Room
MSSV	Main Steam Safety Valve
NRC	Nuclear Regulatory Commission
OECD	Organization for Economic Cooperation and Development
PRA	Probabilistic Risk Assessment (same as PSA)
PSA	Probabilistic Safety Assessment
RCS	Reactor Coolant System (same as HTS)
RRS	Reactor Regulating System
RWS	Reserve Water System
SAM	Severe Accident Management
SAMG	Severe Accident Management Guidelines
SAMDA	Severe Accident Mitigation Design Alternative
SCB	Secondary Control Building
SCD	Severe Core Damage (accident)
SDS	Shutdown System
SG	Steam Generator
URS	Ultimate Rupture Strength

* ACR™ is a trademark of Atomic Energy of Canada Limited (AECL).

** CANDU® is a registered trademark of AECL.

TABLE OF CONTENTS

SECTION	PAGE
1.	INTRODUCTION..... 1-1
2.	SEVERE ACCIDENTS 2-1
3.	DESIGN PROVISIONS TO PREVENT CORE DAMAGE 3-1
3.1	SAM Boundary Conditions 3-2
3.2	Design Provisions for SAM 3-2
4.	DESIGN PROVISIONS TO RETAIN CORE WITHIN VESSELS 4-1
4.1	Retention in Fuel Channels 4-2
4.1.1	SAM Boundary Conditions 4-3
4.1.2	Design Provisions for SAM 4-4
4.2	Retention in Calandria Vessel 4-9
4.2.1	SAM Boundary Conditions 4-12
4.2.2	Design Provisions for SAM 4-13
4.3	Retention in Shield Tank 4-14
4.3.1	SAM Boundary Conditions 4-15
4.3.2	Design Provisions for SAM 4-15
5.	DESIGN PROVISIONS TO TERMINATE PROGRESS OF CORE DAMAGE 5-1
5.1	Termination in Fuel Channels 5-1
5.1.1	SAM Boundary Conditions 5-2
5.1.2	Design Provisions for SAM 5-2
5.2	Termination in Calandria Vessel 5-5
5.2.1	SAM Boundary Conditions 5-5
5.2.2	Design Provisions for SAM 5-5
5.3	Termination in Shield Tank 5-6
5.3.1	SAM Boundary Conditions 5-6
5.3.2	Design Provisions for SAM 5-7
5.4	Termination in Reactor Vault (Containment) 5-7
5.4.1	SAM Boundary Conditions 5-7
5.4.2	Design Provisions for SAM 5-8
5.5	Termination in Calandria Vault (Containment) 5-8
5.5.1	SAM Boundary Conditions 5-9
5.5.2	Design Provisions for SAM 5-9
6.	DESIGN PROVISIONS TO MAINTAIN CONTAINMENT INTEGRITY 6-1
6.1	Containment Pressurization 6-3
6.1.1	SAM Boundary Conditions 6-3
6.1.2	Design Provisions for SAM 6-4

TABLE OF CONTENTS

SECTION	PAGE
6.2	Hydrogen Control..... 6-5
6.2.1	SAM Boundary Conditions..... 6-7
6.2.2	Design Provisions for SAM 6-7
6.3	Corium-Concrete Interactions..... 6-10
7.	DESIGN PROVISIONS TO MINIMIZE OFF-SITE RELEASES 7-1
7.1	SAM Boundary Conditions..... 7-2
7.2	Design Provisions for SAM 7-2
8.	CLOSING REMARKS 8-1
9.	REFERENCES..... 9-1

FIGURES

Figure 3-1	Actions to Prevent Fuel and Pressure Tube Deformations 3-2
Figure 4-1	ACR Process Vessels 4-1
Figure 4-2	Fuel Channel Deformations (conceptual) 4-2
Figure 4-3	Main Moderator System Flow Diagram 4-6
Figure 4-4	Moderator Cover Gas System 4-7
Figure 4-5	Emergency Coolant Injection System..... 4-8
Figure 4-6	Reserve Water System Flow Diagram 4-8
Figure 4-7	Calandria and Shield Tank Assembly..... 4-9
Figure 4-8	Calandria Conditions upon Core Collapse (conceptual)..... 4-10
Figure 4-9	Boundary of Calandria Vessel during Core Disassembly (conceptual)..... 4-10
Figure 4-10	Calandria Conditions after Debris Compaction (conceptual) 4-11
Figure 4-11	Shield Tank Conditions upon Calandria Failure (conceptual)..... 4-14
Figure 4-12	Shield Tank Location in Reactor Vault..... 4-16
Figure 5-1	Flow Diagram of Long Term Cooling System..... 5-4
Figure 5-2	Shield Tank Conditions prior to Internal Flooding (conceptual)..... 5-6
Figure 5-3	Calandria Vault Conditions upon Calandria Vessel Failure (conceptual) 5-9
Figure 6-1	Active Containment Mixing..... 6-9
Figure 6-2	Passive Containment Mixing (conceptual) 6-9

TABLE OF CONTENTS

SECTION	PAGE
 CANDIDATES FOR COST/RISK BENEFIT REVIEW	
SAMDA Candidate 1	Emergency Cross-Connections of Safety Grade Systems 3-4
SAMDA Candidate 2	Calandria Head Tank – Compensation for Liquid Expulsion..... 4-4
SAMDA Candidate 3	RWS Valves – Emergency Connection to Alternate Power Supply..... 4-6
SAMDA Candidate 4	LTCS – Emergency Connections to Alternate Services 5-3
SAMDA Candidate 5	RWS – Emergency Connection for Water Recirculation..... 5-4
SAMDA Candidate 6	Reactor Vault - Floor Contour 5-8
SAMDA Candidate 7	LACs – Emergency Connections to Alternates Services 6-5
SAMDA Candidate 8	Containment Sprays 6-5
SAMDA Candidate 9	Passive Suppression of Steaming from Process Vessels..... 6-5
SAMDA Candidate 10	Hydrogen Control..... 6-8
SAMDA Candidate 11	Off-Site Release Control – Containment Venting..... 7-2

1. INTRODUCTION

Historically, the effort by the Canadian nuclear industry was aimed at the prevention of severe accidents by developing robust reactor designs and ensuring a high reliability of vital reactor systems. Severe core damage (SCD) accidents were considered of sufficiently low probability that no regulatory requirements were warranted. Limited core damage (LCD) accidents are traditionally considered in the CANDU reactor design. (SCD and LCD accident categories are briefly outlined in Section 2). The Canadian Nuclear Safety Commission (CNSC) is currently developing regulatory guidelines for advanced reactors, which extend to SCD accidents.

For new reactor designs, the US Nuclear Regulatory Commission (NRC) requires, among other things, the evaluation of design alternatives to reduce the radiological risk from a severe accident by preventing substantial core damage (i.e., preventing a severe accident) or by limiting releases from the plant in the event that substantial core damage occurs (i.e., mitigating the impacts of a severe accident), References [1] and [2]. The purpose of such evaluation is to establish whether there are any cost-effective severe accident mitigation design alternatives (SAMDAs) that should be added to the facility. The SAMDAs will be assessed for the Advanced CANDU Reactor (ACR) to confirm that its design provisions for severe accident management (SAM) are effective and efficient. Such exercise is useful for reactor design optimization and is one of the requirements for international licensing of the reactor.

Relevant reactor design features are those provided to facilitate the SAM. The senior group of experts on SAM assembled by the Organization for Economic Cooperation and Development (OECD) defines the SAM as follows (Reference [3]):

*Severe accident management consists of those actions that are taken by the plant staff during the course of an accident to **prevent core damage, terminate progress of core damage and retain the core within the vessel, maintain containment integrity, and minimize off-site releases.** Severe Accident Management also involves pre-planning and preparatory measures for SAM guidance and procedures, equipment modifications to facilitate procedure implementation, and severe accident training. This definition includes the concept that there is some overlap between what is referred to as Accident Management and Severe Accident Management.*

There are variations of the SAM definition (e.g., Reference [4]), but the substance is the same in all definitions. This report uses the OECD definition to organize the SAM topics. For each topic highlighted by bold type in the above citation, SAM-related design features of the ACR are systematically reviewed (Sections 3 through 7). The review compiles background information, broadly identifies SAM boundary conditions, examines the ACR design features (as described in References [5] and [6]) in the context of pertinent boundary conditions and identifies the candidates for a SAMDA assessment (flagged as ‘SAMDA Candidate’). It should be noted that the **SAMDA candidates are not recommendations for design modification or implementation**. They are simply SAM-related design topics for which a documented, risk-informed assessment will be needed to explain the defence in depth provided by the ACR design. As noted above, such assessment is one of the international licensing requirements.

The systematic review of SAM-related features initializes the SAMDA assessment process. The full assessment also requires quantitative information on the cost of a SAMDA and its effect on the radiological risk (provided by Level 2 probabilistic safety assessment (PSA)¹). The latter two elements are not yet available.

¹ The US terminology for PSA is Probabilistic Risk Assessment (PRA).

2. SEVERE ACCIDENTS

In CANDU reactors, a core damage results from LCD accidents and SCD accidents, which are defined in Reference [7] and explained in Reference [8]. Both these accident categories are severe accidents according to the definition in Reference [9]. Reference [3] provides a brief overview of CANDU severe accident progression as follows:

(In severe accidents), “the fuel elements are predicted to gradually slump down on the horizontal pressure tubes, which will in turn balloon or sag into contact with their concentric calandria tubes. If the surrounding calandria water (moderator) is present, the fuel cooling should be restored. If, however, calandria water is not available or is subsequently lost, the fuel channels eventually lose their mechanical strength and slump down onto the bottom of the calandria vessel. It is estimated that this process would take five to six hours, affording time and opportunity for intervention. In most Canadian CANDU reactors, the calandria vessel is surrounded by a water filled biological shield tank. If shield tank water inventory can be maintained, it is expected that the entire mass of core material will likely be retained in the calandria. If the shield tank water inventory cannot be maintained, the core material will eventually (estimated 1 day) penetrate the calandria vessel and sometime after that (approximately 50 hours) the shield tank, eventually ending up on the containment floor, which is expected to be flooded with RCS, moderator and shield cooling system water.”

The LCD accidents pertain to the first phase in the above citation, which ends with a rejection of core heat into the alternate moderator heat sink. These accidents involve widespread fuel failures and fuel/pressure tube deformations. However, in all LCD accidents, the fuel materials remain within the heat transport system (HTS)² boundaries and the reactor core maintains a distorted but coolable geometry that is approximately constant after the initial transient³. The SCD accidents pertain to the subsequent phases in the above citation. These accidents involve significant amounts of fuel debris outside of the HTS boundaries. The debris (also commonly called ‘the corium’) does not have readily definable characteristic (i.e., it can change its geometry and properties according to prevailing boundary conditions). The corium could be located in externally cooled, metal process vessels (e.g., the calandria vessel or the shield tank), or in plant volumes that cannot be externally cooled (e.g., in a concrete calandria vault, which is an alternative to the metal shield tank, or on the containment floor).

The ACR provides active as well as passive heat sinks for all water volumes surrounding the reactor core (discussed in the following sections). Although the above-cited severe accident progression applies generically, there are numerous possibilities for SAM interventions such that breaches in multiple debris-retention boundaries will be of an extremely low probability in the ACR.

² The US terminology for HTS is reactor coolant system (RCS).

³ LCD accidents also include the so called single channel events that displace a small amount of fuel (up to 12 short fuel bundles) outside of the RCS boundaries as part of the initiating event (Reference [8]). For the single channel events, this statement applies to the fuel that was not ejected by the initiating event.

3. DESIGN PROVISIONS TO PREVENT CORE DAMAGE

For accidents at decay power, a LCD accident invariably precedes a SCD accident (Section 2). Hence, the “prevention of core damage” in the OECD definition could mean a prevention of LCD accident if core damage is taken to mean appreciable deformations of core components. Alternatively, it could mean a mitigation of LCD accident if core damage is taken to mean a loss of reactor core structural integrity. In this section, the first of these two interpretations is adopted. Thus, **the prevention of core damage is the prevention of significant deformations of fuel bundles and pressure tubes** (i.e., the prevention of LCD accident). The second possible interpretation is actually a “retention of core within vessels”, where ‘vessels’ are the fuel channels (i.e., a composite of pressure and calandria tubes, where either of the tubes could be the retaining boundary). The retention is discussed in Section 4.

The prevention of fuel and pressure tube deformations is normally accomplished by the conventional accident management (AM) rather than by the severe accident management. The accident management is executed by operators in the control room right from the start of the accident. It employs engineered safety systems and their support systems according to rehearsed emergency operating procedures (EOPs). The equipment used for conventional accident management typically operates within its design envelope. Severe accident management might be used to prevent deformations if an accident is progressing slowly such that time is available to transfer from AM to SAM before the fuel and pressure tubes have deformed. During SAM, the plant technical management takes on a primary decision-making role in advising the control room operators and deploying in-plant and onsite staff in implementing severe accident management guidelines (SAMGs). The SAM can only commence after the management team has assembled (i.e., which takes some time relative to the start of the accident). SAMGs outline strategies and uses of alternative systems in ways that were not envisioned (or evaluated) in the licensing basis of the plant. Such strategies would be employed only if the EOPs were ineffective (e.g., due to additional failures of systems used by the EOPs). Otherwise, the plant technical management would follow the EOPs.

The preceding discussion illustrates the overlap between accident management and severe accident management, which is recognized by the OECD definition of SAM cited in Section 1. This overlap is most pronounced for the topic of core damage prevention.

This section does not concern itself with the systems used for normal accident management. These systems are identified in Figure 3-1 (Section 3.2) and they are well described elsewhere (e.g., Reference [6]). Stringent reliability requirements are set by the CNSC for all safety systems (i.e., unavailability $\leq 10^{-3}$ years/year for each of the two shutdown systems (SDS), the emergency core cooling system (ECCS) and the containment system, Reference [7]). A design target has been defined for the summed SCD accident frequency for all internal and external initiators (i.e., $< 10^{-5}$ per year⁴, Reference [7]). This latter frequency impacts on the reliability requirements for the remaining plant systems. All systems used for normal accident management are closely scrutinized by the deterministic analyses as well as by the PSA. The focus of this section is on other design features that could be used to prevent fuel and channel deformations during SAM.

⁴ This total frequency includes external events, except seismic (a seismic margin assessment will be performed for earthquakes).

3.1 SAM Boundary Conditions

By the time the SAM commences, the reactor has been shut down for a period of time⁵. The core damage is prevented when the coolant in the HTS removes the fuel heat (Reference [9]). At decay power levels, a sufficient condition to prevent the fuel and pressure tube deformations is keeping the inside of the pressure tubes flooded with liquid water (Reference [8]).

3.2 Design Provisions for SAM

Figure 3-1 outlines the ACR options for keeping the fuel covered by water. All these options can be accomplished by the conventional accident management provisions.




Figure 3-1 Actions to Prevent Fuel and Pressure Tube Deformations

⁵ The ACR has multiple, diverse means of quickly shutting down the reactor (Sections 6.2, 6.3 and 7.5.1 in Reference [6]). Ensuring that the reactor is the shut down is the first step of any EOP.

Reference [10] (Item I) identifies the provision of reliable HTS depressurization as one of the requirements for preventing and mitigating severe core damage. In pressure vessel reactors, the fuel at decay power could melt before a voided (or partially voided) vessel fails. A molten material could then be ejected as a high-velocity jet into the containment⁶, causing a major challenge to the containment integrity at the same time when there is a major radioactivity release into the containment. Depressurizing the vessel prevents this high-velocity melt ejection by permitting the fuel to be flooded before it melts using water sources at modest injection pressure. It should be noted that a pressurized melt ejection is not relevant to CANDU reactors. Should the HTS become voided at high pressures, a fuel channel failure is unavoidable at modest fuel temperatures⁷ (Reference [8]). This channel failure depressurizes the HTS well before the fuel could be liquefied within any of the channels. Hence, the ACR has two means of HTS depressurization to prevent fuel melting within the HTS boundaries:

- It has two independent, highly reliable, engineered systems to depressurize the HTS to below the injection pressure of the emergency coolant injection system (ECIS) using the main steam safety valves (MSSVs), which are the conventional accident management provisions (Section 6.1.2.2 in Reference [6]); and
- It has an inherent (non-engineered) “thermal fuse” (in the form of channel failure(s)) which comes into play in severe accidents if the engineered depressurization is unavailable or ineffective. The inherent channel failure accommodates timely flooding of the fuel by passive water supplies from the ECIS or the reserve water system (RWS) before any fuel could liquefy⁸.

Past analyses of light water reactors (LWRs) have identified the so-called containment bypass (e.g., an interfacing system LOCA) as a significant contributor to large off site releases. The US NRC has set the following requirements related to preventing the interfacing system LOCA (Reference [10]):

- *All systems and subsystems connected to the RCS, which extended outside the primary containment boundary, must be designed to the extent practicable to ultimate rupture strength (URS) of at least equal to full RCS pressure.*
- *The designer must determine by evaluation that, for interfacing systems or subsystems which do not meet the full RCS URS requirement, the degree and quality of isolation or reduced severity of the potential pressure challenges are sufficient to preclude an intersystem LOCA.*
- *Additional testing and control room alarm capabilities must be implemented to help reduce the probability of an intersystem LOCA.*

These are “generic” accident prevention principles, which have long been recognized in CANDU reactor designs. The ACR will demonstrate the compliance with these principles.

⁶ A high-velocity jet of the molten corium could be finely fragmented, causing the so-called Direct Containment Heating (DCH).

⁷ Fuel temperatures are well below Zr melting point.

⁸ This ‘non-engineered’ HTS pressure relief involves some limited core damage, but prevents fuel melting. It could involve a rupture of single channel (likely) or few channels (less likely) as described in Reference [8].

So far, only the features for conventional accident prevention and inherent features have been discussed. What are the SAMDAs relevant to the topic of this section (i.e., the prevention of LCD accidents by manual interventions in the long term when normal accident management is ineffective)? Design options to be considered for SAM are outlined below as SAMDA Candidate 1.

SAMDA Candidate 1 Emergency Cross-Connections of Safety Grade Systems

The emergency cross-connections outlined below would not be permanent links, but engineered provisions for “jumpers” that could be installed during a progression of severe accident.

- Emergency cross-connections of non-safety grade water systems to safety grade injection systems.

In the context of Figure 3-1, these could be provisions to connect an external (portable) water supply to the service side of long term cooling system (LTCS) heat exchangers, the secondary side of steam generators, etc.

- Emergency cross-connections of non-safety grade power supplies to safety grade power supplies.

These could be provisions to connect a portable power supply to LTC pumps, motorized valves, etc.

- Emergency cross-connections of non-safety grade gas supplies to safety grade gas supplies.

This could be a provision to connect bottled gas supply to pneumatic valves.

It should be noted that any cross-connection between safety and non-safety grade systems must be treated with extreme caution. Stringent separation requirements are in place for all safety grade systems to enhance protection against common cause events (Section 2.1.3 in Reference [6]).

Analyses of PSA results (which are a part of the PSA process) identify which post-accident cross-connections would be beneficial (in terms of avoiding fuel and pressure tube deformations) and feasible (in terms of having enough time available to implement them⁹). A focused search of ACR layouts can then be performed for possible (SAM-related) ‘jumpers’. This search makes sense only in a well advanced stage of the design process, when the layouts are close to being final. This is why the emergency cross-connections are treated only as high-level topics in this report (i.e., the PSA results are not yet available and many layout details have not yet been finalized).

⁹ Systems can be connected via jumpers only if the accident progresses slowly enough that field actions are possible.

4. DESIGN PROVISIONS TO RETAIN CORE WITHIN VESSELS

The reference ACR design (Reference [6]) has three ‘process vessels’ within which hot core materials can be retained by external cooling (Figure 4-1). In this report, **the retention is an intermediate state of accident progression during which the materials are hot but immobile**. A termination of the damage (Section 5) not only retains the core materials in a process volume, but also cools them down.

The ‘process vessels’ within which the core materials can be retained are:

- Fuel channels, which are a part of the HTS and normally contain the fuel and the light water coolant at high pressure.
- Calandria, which normally contains the heavy water moderator at low pressure.
- Shield tank, which normally contains the light water at low pressure.




Figure 4-1 ACR Process Vessels

An alternate ACR design is under consideration that would replace the steel shield tank with a concrete tank, called calandria vault in this report¹⁰. Both options for providing the shield water jacket around the calandria vessel are considered in this report. The concrete tank has characteristics of a containment compartment (i.e., it cannot be externally cooled). Therefore,

¹⁰ Both these design options for a shield water pool around the calandria vessel are employed in the existing CANDU plants. The steel shield tanks are in Bruce and Darlington reactors, while the concrete calandria vaults are in the remaining CANDU reactors.

the alternate ACR design has two ‘process vessels’ for the retention of hot core materials by external cooling.

4.1 Retention in Fuel Channels

The fuel channels are invariably depressurized by the time the fuel heats up to highly elevated temperatures¹¹. Heat rejection paths to the water volume in the calandria are established by fuel and pressure tube deformations while the fuel is solid (Figure 4-2)¹². Under these conditions, the only prerequisite for retaining the hot, solid fuel debris within the fuel channels is to maintain all the channels submerged in liquid water on the outside (Reference [8]).




Figure 4-2 Fuel Channel Deformations (conceptual)

¹¹ The HTS is either depressurized by the initiating event and subsequent automatic and/or manual system actions, or the inherent “thermal fuse” (in the form of consequential channel failure(s)) has come into play, which is described in Reference [8].

¹² Terms ‘sagged’, ‘ballooned’ and ‘slumped’ geometries are commonly used to label the conditions shown in Figure 4-2. Note that the schematic illustration does not apply uniformly in the axial direction (i.e., along the length of the channel). Spacers between pressure and calandria tubes cause local separations between the two tubes, with attendant axial conduction of heat to surfaces in contact.

4.1.1 SAM Boundary Conditions

Boundary conditions to retain deformed fuel and pressure tubes within calandria tubes are:

- a) A fast water make-up is desirable to compensate for any liquid expulsion from the calandria such that the top-most row of fuel channels always remains below the water level¹³.

AND

- b) An active heat sink is needed for the calandria water volume in order to avoid boiling¹⁴. This heat sink is provided when:

- 1) A forced circulation (pumped flow) is available to move water from the calandria through the heat exchanger.

AND

- 2) A service water flow is available on the secondary (service) side of the heat exchanger.

OR

- c) A passive heat sink (provided by steaming and liquid make up) is needed. Such heat sink is provided when:

- 1) A steam relief path is available from the calandria vessel.

AND

- 2) A water makeup path is available to the calandria vessel with sufficient capacity to compensate for steaming.

The limiting accident for make-up capacity is an in-core break with a total loss of ECC. The calandria fluid is at saturation temperature and reduced level after the HTS blowdown. Heat load to calandria commences at ~ 30 minutes (15 minutes for blowdown and 15 minutes for fuel heat up). Decay power at this time is ~ 2 % of full power (i.e., ~ 40 MW). This means a make up of ~ 18 L s⁻¹. Out of core breaks will take a long time for the moderator to reach saturation temperature. Hence, a lower make-up capacity would be needed for breaks other than in-core breaks.

AND

- 3) A liquid level measurement in the calandria is available for the operator to monitor that the water level is above the highest channel elevation and below the overflow elevation¹⁵.

AND

- 4) Means are available to monitor the status of the water source.

AND

- 5) Means are available to remotely control the supply of water into the calandria.

¹³ The liquid water is expelled when the moderator is at (or close to) the saturation temperature and the rupture disk opens. A sudden pressure change causes a swell due to steam bubbles. The swollen two-phase fluid is relieved instead of only steam. This results in a significantly reduced water level within the calandria at the end of the transient if no external liquid is added during the transient.

¹⁴ When there is no boiling, the calandria water level does not change.

¹⁵ The overflow is an indication that the supply can be adjusted/modulated in order to conserve the reserve water inventory.

4.1.2 Design Provisions for SAM

Both ACR design alternatives can facilitate the above SAM conditions as explained below.

- a) To compensate for a liquid expulsion through the relief ducts, the following design features are provided¹⁶:
- 1) The operator manually activates the RWS supply to the calandria (and/or to HTS if the calandria disks burst due to an in-core rupture) before any uncovered channels start breaking down¹⁷.
- AND/OR
- 2) The liquid inventory in the calandria head tank (Figure 4-3), which returns into the calandria vessel soon after the calandria transient, is sufficient to keep the top-most channel row submerged in liquid (see SAMDA Candidate 2).

SAMDA Candidate 2 Calandria Head Tank – Compensation for Liquid Expulsion

The tank is to “accommodate D₂O level changes in the calandria due to shrinkage and swell” (e.g., Section 5.3.1, Item f, Reference [6]). This is for normal operation. A SAM provision would accommodate a liquid expulsion following a moderator relief via the rupture disks such that all fuel channels remain submerged in liquid after the relief is completed. This is simply an issue of how much water remains in ACR calandria vessel after the initial transient and how much water can be ‘passively’ returned from the head tank. Ideally, the sum would provide enough water to keep the top-most row of channels submerged in any accident. This would, in turn, guarantee ample time for the manual water make-up from the RWS. Ongoing analyses may well show that all channels remain submerged, thereby removing this topic from the list of SAMDA candidates.

- b) Main moderator system (Figure 4-3) has ample heat removal capacity when available. The normal heat load (~ 80 MW, Table 13.2-1 of Reference [6]) is much higher than the largest post-accident heat load (~ 40 MW, Item C.2 in Section 4.1.1). A single pump and a single heat exchanger are adequate.
- Two pumps are provided, supplied with Class III power (Section 5.3.2, Reference [6]). However, these pumps would not operate with a reduced water level in the calandria vessel (the pump suction line is at high elevation in order to avoid moderator draining in case of a break in the suction line).
- Two heat exchangers are available, provided with service water supply on Class III power. These exchangers would not be effective in the absence of forced flow.
- c) The passive heat sink is provided as follows:

¹⁶ The ECC systems are not available for the moderator to act as the heat sink.

¹⁷ Based on analyses of existing CANDU reactors, adequate time (more than 15 minutes) is available for this operator action. This will be confirmed by ACR-specific analyses.

- 1) Two steam relief paths are provided:
One path is through two bleed valves of the cover gas system (Figure 4-4), which ultimately vent steam into containment¹⁸. The other path is through four rupture disks on the calandria vessel, which vent steam directly into the containment¹⁹.
- 2) Water make up (by gravity) from the reserve water tank of RWS (Figure 4-6) has sufficient flow capacity to compensate for steaming at relevant decay power levels (i.e., the capacity is well in excess of 18 kg/s by about an order of magnitude).
- 3) Liquid level is measured in the calandria head tank (Figure 4-3) as follows:
Three narrow range transmitters measure level from the top of the head tank to the centreline of the top row of channels. The instruments are not exposed to harsh environment²⁰ and are highly reliable.
A single wide-range transmitter (to measure the full range of calandria levels) is also provided, but this measurement is not essential for SAM²¹.
High and low levels are announced (Section 5.3.3.3, Reference [6]) in the main control room as well as in the secondary control building. The level signals are also used for the automatic trip²² logic (Table 7.2.1-1 and Table 7.2.2-1, Reference [6]).
- 4) Instrumentation is provided to measure pressure²³, temperature and level in the reserve water tank of RWS and the flow from the RWS to its customers (Section 9.2.7.3, Reference [6])²⁴.
- 5) Means to control the make up flow under SAM conditions are provided:
 - i) Status indications and remote controls are provided for all motorized valves in the RWS (Section 9.2.7.3, Reference [6]).
 - ii) The motorized valves are powered by the uninterruptible Class II supply (see SAMDA Candidate 3).

¹⁸ This relief path is relevant to accidents with all fuel channels intact.

¹⁹ This path will invariably open following an in-core rupture.

²⁰ This will be confirmed by assessment of operability under severe accident conditions.

²¹ The operator needs to know when to add emergency water (i.e., level dropping to the top-most channel rows) and when to stop adding water (i.e., level rising to overflow elevation).

²² The Canadian terms 'trip' is equivalent to US term 'scram'.

²³ The pressure in the RWS is the same as that in the containment (not counting the static head, which is known from level measurement). This pressure measurement might simply be the containment pressure measurement.

²⁴ The RWS instrumentation is not yet finalized. This instrumentation can be located within the reserve water pool such that it is protected from a harsh environment that is likely to exist during SAM. The important parameters to measure are the reserve water level and the flow from the tank. The level is the indicator of the water reserve status (i.e., how much water is left). The flow measurement is important to confirming that enough water is being supplied to the target process vessel. As explained in Section 5, a low water supply rate could actually be harmful under some accident circumstances (by facilitating exothermic chemical reactions of hot core materials with steam without stopping them). The flow adequacy can be deduced from water level measurements in process volumes containing the hot fuel, but a direct measurement is preferable under the stressful SAM conditions.

- iii) The valves will be environmentally qualified for post-LOCA conditions (Section 9.1, Reference [6]) and assessed for their operability under severe accident conditions.

SAMDA Candidate 3 RWS Valves – Emergency Connection to Alternate Power Supply

Connections to facilitate alternate services are already identified generically as SAMDA Candidate 1. This is a subset of the generic item. The alternate power supply connection is particularly important for the RWS valves. The RWS is a key system for mitigating a prolonged loss of all electrical power. Class II power lasts only for a limited time under these circumstances (several hours). The probability of a sustained plant “blackout” must be minute, given that the ACR has four on-site diesel generators. A cost/risk benefit assessment would be useful, because a prolonged blackout is widely perceived to be a significant contributor to the radiological risk and this alternative would lessen the impact of the blackout.




Figure 4-3 Main Moderator System Flow Diagram




Figure 4-4 Moderator Cover Gas System




Figure 4-5 Emergency Coolant Injection System




Figure 4-6 Reserve Water System Flow Diagram

4.2 Retention in Calandria Vessel

The calandria, the two end shields, and the shield tank (including its end walls and shield tank extension) constitute a multi-compartment structure (Figure 4-7). An alternate ACR design replaces the shield tank and its extension with a concrete, steel lined calandria vault. The calandria vessel (discussed below) is the same in either design.




Figure 4-7 Calandria and Shield Tank Assembly

The calandria vessel is a horizontal cylinder enclosed at each end by circular flat plates (calandria tubesheets). The calandria tubes pass horizontally through the calandria vessel and are rolled into the calandria side tubesheets at each end, thereby completing the calandria vessel boundary. The calandria vessel contains heavy water moderator. The end shields are welded on the horizontal faces of the calandria vessel and are integral parts of the calandria assembly. They are short cylindrical shells enclosed at each end by tubesheets, and spanned horizontally by lattice tubes. The end shields contain materials for biological shielding (carbon steel balls and demineralized light water).

As explained in Reference [8], hot core materials relocate into the calandria vessel while it still contains a significant pool of water. Figure 4-8 illustrates the conditions in the calandria vessel following sudden debris relocation (a core collapse). The debris entering the water pool is largely solid, but there is a lot of it and the hot materials enter the residual water pool quite rapidly (on the timescale of minutes). This type of debris relocation cannot cause a steam

explosion. Nevertheless, it would cause a major steaming surge and the corresponding pressure excursion in the calandria vessel.

Pressure and calandria tubes are broken during the core disassembly process. Following the core collapse, the calandria vessel boundary extends through the lattice tubes of the end shields to the end fitting bellows (Figure 4-9). Also, the calandria vessel internal volume becomes interconnected to the voided HTS via the feeder pipes.

When the core collapses, debris weight and heat loads are predominantly applied to the calandria shell (Figure 4-8). The calandria tubesheets would come into contact with the corium only later, if the calandria vessel were allowed to dry out. The corium would eventually compact and partially liquefy in the dry calandria vessel, causing a direct contact of hot corium materials with the calandria tubesheets (Figure 4-10).




Figure 4-8 Calandria Conditions upon Core Collapse (conceptual)




Figure 4-9 Boundary of Calandria Vessel during Core Disassembly (conceptual)




Figure 4-10 Calandria Conditions after Debris Compaction (conceptual)

Broad requisites for retaining the hot core materials (i.e., corium) within the calandria vessel are:

- a) The internal pressure in the calandria vessel is kept sufficiently low such that the vessel maintains definable boundaries following the reactor core disassembly²⁵.

AND

- b) The walls of the calandria vessel remain sufficiently cool such the wall does not fail under the combined thermal and weight loads. This is satisfied when:

- 1) Outer surface of the wall is in contact with liquid water.

AND

- 2) Heat fluxes through the vessel wall are sufficiently low that a departure from nucleate boiling is avoided on the outer wall surface. The low heat fluxes are inherent to the

²⁵

Calandria vessel boundary failures would be tolerable provided such openings do not interconnect calandria and shield tank volumes, or facilitate a spillage of liquefied corium from the calandria vessel. At issue is a gross failure of the calandria vessel, which could propagate into additional systems failures.

cylindrical calandria vessel geometry (Reference [8]) and, therefore, this requisite is automatically satisfied.

4.2.1 SAM Boundary Conditions

The following SAM boundary conditions satisfy the above requisites:

- a) The calandria overpressure protection provisions accommodate the steam surges due to the reactor core collapse into the residual water pool present in the calandria vessel.

AND

- b) An active heat sink is available for shield water in the shield tank as well as in each of the two end shields. This heat sink is provided when:

- 1) Forced circulation (pump) is available to circulate the shield water through the three volumes and the heat exchanger.

AND

- 2) Service water flow is available through the heat exchanger.

The sufficient active heat sink capacity removes the decay heat at the time when the calandria vessel dries out. Analyses for the ACR are not yet available. Analyses for the existing CANDU reactors (e.g., Reference [11]) indicate this debris dryout time will be > 10 hours. The corresponding decay heat is < 0.75 % of full power (< 15 MW).

OR

- c) A passive heat sink (provided by steaming and liquid make up) is available. This heat sink is provided when:

- 1) Steam relief paths are available from each of the three volumes surrounding the calandria vessel²⁶ which do not interfere with each other or with the liquid make up.

AND

- 2) Water makeup paths into each of the three volumes are available with sufficient flow capacities to compensate for steaming.

Most of the heat from the debris is transferred to the shield tank. The end shield load would be < 10 % of the total load²⁷. The corresponding make up rates are < 7 L s⁻¹ for the shield tank and < 0.5 L s⁻¹ for each of the end shields.

AND

- 3) Means are available for the operator to monitor that the water level in each of the three volumes is well above the corium elevation.

AND

- 4) Means are available for the operator to monitor the status of makeup water source.

AND

- 5) Means are available for the operator to remotely control the supply of water into each of the three volumes.

²⁶ The shield tank and the two end shields become individual entities with different heat loads when forced circulation is not available.

²⁷ This is an engineering judgement based on geometry considerations.

4.2.2 Design Provisions for SAM

- a) The calandria vessel is provided with large relief ducts and rupture disks, which are expected to maintain acceptable internal pressures within the calandria vessel during the core disassembly. The design intent is to ensure that the calandria integrity is maintained in SCD accidents. The worst challenge is a core collapse (schematically illustrated in Figure 4-8), which rapidly brings a large amount of hot, solid materials into contact with a residual water pool at the bottom of calandria vessel. Methodology is available to quantify the resulting steam surges (e.g., Reference [12]) and analyses are in progress to ascertain that the final design will meet this intent.
- b) The shield cooling system can remove 2 x 7.2 MW (Table 13.2-1, Reference [6]). Decay heat load would be < 15 MW (see above). Both heat exchangers in service will be able to maintain shield water temperature close to the nominal operating conditions. A single heat exchanger and a single pump will be able to maintain sub-cooled water in the shield tank as well as the calandria end shields²⁸.

This system is not environmentally qualified for post-accident conditions, so it might not be available during a SCD accident. The environmental conditions are not particularly harsh while the system operates (i.e., the system still contains the sub-cooled water even in SCD accidents). Assessments of operation at elevated water temperatures (relevant to SCD accidents) will be performed to confirm the system operability.

- c) The following provisions are made for the passive heat sink:
 - 1) The steam relief from the shield cooling system is not particularly demanding while the system operates in the passive heat sink mode (i.e., water boil-off and make-up). Bleed valves supplemented by rupture disks will undoubtedly have a sufficient steam relief capacity²⁹.
 - 2) The RWS can supply sufficient water make-up to the shield tank as well as to the calandria end shields (Figure 4-6)^{30,31}.
 - 3) The design basis (Reference [6], Section 7.4.5) requires that the system “will have sufficient displays, alarms, and controls to ensure that the shield tank and end shields have sufficient water inventory and are adequately cooled”. Provided this instrumentation is confirmed by assessment to withstand the SCD accident conditions (which are not particularly harsh, see above), this satisfies the SAM needs.
 - 4) Instruments to monitor the status of makeup water source are provided (see Item 3.4 in Section 4.1.2 for additional information).

²⁸ This will be confirmed by severe accident analyses, which are in progress.

²⁹ Ongoing assessments are evaluating the relief requirements. A steady steaming in this mode of operation is not limiting for steam relief. The relief must also accommodate steam surges associated with corium relocation into the shield tank discussed in Section 4.3.

³⁰ The end shields are internally interconnected with the shield tank, so a single supply line is sufficient.

³¹ The limiting case for the end shield make-up is not the debris cooling, but a removal of heat losses from pressure tubes (via the lattice tubes). These losses are normally 2.8 MW (Table 13.2.1 in Reference [6]) and could be slightly higher when the fuel debris is being retained in the fuel channels.

- 5) Electrically operated valves to remotely control the supply of water from the RWS into each of the three volumes of the shield cooling system are provided (see Item 3.5 in Section 4.1.2 for additional information).

4.3 Retention in Shield Tank

This topic is only relevant to the metal shield tank in the reference ACR design³². Figure 4-11 illustrates the conditions in the shield tank upon a calandria vessel failure. The corium enters the tank as slurry of molten and solid materials. The rate of corium relocation is unknown, but it is expected to be slow (Reference [8]). There is a potential for a steam explosion, although it is not inevitable that an explosion would occur. However, a strong steam surge will invariably occur due to corium quenching, the magnitude of which depends on how the corium fragments upon entering the residual water pool.




Figure 4-11 Shield Tank Conditions upon Calandria Failure (conceptual)

Broad requisites for retaining the corium in the shield tank are the same as those for retaining the corium in the calandria vessel (Section 4.2):

- a) The internal pressure in the shield tank is kept sufficiently low such that the vessel maintains definable boundaries following the reactor core disassembly³³.

AND

³² The calandria vault used in the alternate ACR design is not a 'vessel' but a 'containment compartment' which cannot be externally cooled. Therefore, the corium can only be retained in the calandria vault if the core damage is terminated in this vault (see Section 5.5).

³³ Shield tank boundary failures would be tolerable provided such openings do not cause a spillage of liquefied corium into the containment.

- b) The walls of the shield tank remain sufficiently cool such the wall does not fail under the combined thermal and weight loads. This is satisfied when the wall that is in contact with the corium is submerged in liquid water on the outside.

4.3.1 SAM Boundary Conditions

Conditions that facilitate the retention of debris in the shield tank are:

- a) The tank is not destroyed by internal pressure surges.
AND
- b) A passive heat sink (provided by steaming and liquid make up) is available on the outside of the shield tank. This heat sink is provided when:
- 1) A steam relief path is available from the reactor vault (i.e., the compartment that houses the shield tank) to the remaining containment volumes.
AND
 - 2) Process fluids discharged in preceding stages of an SCD accident have access to the reactor vault and can accumulate around the shield tank.
AND
 - 3) A water make-up path is available to increase the water level in the reactor vault as required.
Heat transfer from the shield tank would commence beyond 1 day after the start of the accident. The corresponding decay power is < 0.5 % of full power (< 10 MW) and the make up flow to compensate for steaming is < 5 L s⁻¹.
AND
 - 4) Means are available for the operator to monitor that the water level in the reactor vault.
AND
 - 5) Means are available for the operator to monitor the status of the makeup water source.
AND
 - 6) Means are available for the operator to remotely control the supply of makeup water into the reactor vault.

4.3.2 Design Provisions for SAM

- a) As for the overpressure protection of the calandria vessel (Item A in Section 4.2.2), the design intent is to provide a shield tank relief that is adequate for SCD accident conditions. In this case, the steam surge is due to corium relocating into the shield tank following a calandria vessel failure. A steam surge can be modelled for any given rate of corium relocation (Reference [8]), so the corium relocation rate is the primary source of uncertainty. The boundary conditions at failure (i.e., a significant fraction of corium in solid form within a depressurized calandria vessel, Reference [8]) favour slow relocation rates and thus relatively modest steam surges. Analyses are in progress to ascertain that the final design will provide an adequate relief of the steam surges.

- b) A passive external heat sink for the corium in the shield tank is provided:
- 1) The reactor vault is interconnected with the other containment volumes (i.e., a steam relief on the outside of the shield tank is not at issue, Figure 4-12).
 - 2) The containment design accommodates the accumulation of process fluids around the shield tank. The water level is well above the elevation of the corium in the shield tank when fluids from the HTS, the calandria vessel and the shield tank are discharged into the containment³⁴.
 - 3) A water makeup path is provided from the RWS to the containment floor (Figure 4-6) and ample time will be available to adjust the water level as part of SAM if required. The make up rate is sufficient³⁵.
 - 4) Water level measurements in the containment are provided for normal accident management. They accommodate the SAM needs. An assessment of instrument performance under SAM conditions will be performed to confirm that these level measurements would not be disabled.
 - 5) Instruments to monitor the status of makeup water source are provided (see Item C.4 in Section 4.1.2 for additional information).
 - 6) Electrically operated valves to remotely control the supply of water from the RWS into the containment (see Item C.5 in Section 4.1.2 for additional information).




Figure 4-12 Shield Tank Location in Reactor Vault

³⁴ This is based on engineering judgement that will be confirmed by severe accident analyses, which are in progress.

³⁵ This make up path is also used for establishing the sump level for the LTCS pumps, which requires higher flow capacity than that to compensate for steaming.

5. DESIGN PROVISIONS TO TERMINATE PROGRESS OF CORE DAMAGE

The subtle difference between retaining the core within a vessel (Section 4) and terminating the progress of core damage within a process volume (this section) is the temperature of core materials. The materials retained in a vessel can be hot and reactive. **The core damage is terminated when the materials are sufficiently cool to be unreactive** (excluding radiolysis reactions, which proceed even at low temperatures). In this report, the core damage is taken to be terminated when:

- All core materials are solid and cooled down such that:
 - there is no temperature-driven release of fission products from the materials; and
 - no thermal-chemical reactions between the materials and water or steam are possible³⁶.
- The cooled-down condition of the core materials can be maintained into the long term.

In practice, terminating the core damage means flooding the hot core materials with water and keeping them flooded thereafter. For shallow debris beds (i.e., solidified corium beds in the calandria vessel or the shield tank), providing an external water jacket should not be essential after the corium is flooded³⁷. However, this jacket needs to be maintained during the cool-down. Maintaining the jacket in the long term (in addition to having a water layer on the top of cooled down debris) would be a sound precautionary measure.

A water supply rate required for the flooding is higher than that required to replenish water evaporation from the flooded debris. An insufficient flooding rate (i.e., a supply that just compensates for the steaming or a lower supply) could actually be harmful, because it might cause an additional generation of hydrogen. There is no 'firm' criterion as to how large flow is needed for the flooding. An engineering judgement is that a $\geq 50\%$ margin relative to the supply rate that just replenishes the vaporization loss is sufficient.

The core damage can be terminated in any of the three process vessels discussed in Section 4 (Figure 4-1) or in the containment. For the reference ACR design, the relevant containment compartment is the reactor vault. For the alternate ACR design, the relevant containment compartment is the calandria vault.

5.1 Termination in Fuel Channels

The initial condition is that the fuel channels are voided and in one of deformed geometries schematically illustrated in Figure 4-2. The hot channel components are contained within externally cooled calandria tubes. The HTS is depressurized via an opening equivalent to a broken channel or larger, or by any break assisted by a steam generator cool down.

³⁶ This would be satisfied at fuel surface temperature at approximately the coolant saturation temperature or less and the peak local temperature (in the interior of fuel material) at about 500°C or less.

³⁷ It is expected that the cooled-down debris will be sufficiently fragmented such that the liquid water can penetrate into the debris bed.

Broad requisites for terminating the core damage are:

- a) Flood the inside of fuel channels with water.

AND

- b) Maintain the calandria tubes submerged in water (at least during the flooding).

The pressure relief of the voided channels is not at issue. The water supply rate from the reactor headers into individual channels automatically adjusts to the steam generation in the channel to achieve a quasi-steady condition of one-directional or counter-current flows of steam and water through the feeder pipes.

5.1.1 SAM Boundary Conditions

Conditions that achieve the above requisites are:

- a) Water is manually supplied into the reactor headers at a rate ≥ 1.5 times of the rate required for vaporization of decay heat at the time when the SAM action is executed. Assuming an early SAM action at 1 hour, the relevant decay heat is approximately 1.4 percent of full thermal power (approximately 28 MW). This heat load requires approximately 12.4 L s^{-1} of water to be removed by vaporization. Thus, a water supply that ensures that fuel would be flooded is $\geq 19 \text{ L s}^{-1}$.

Water in the headers is distributed to the parallel channels according to the injection pressure and the location of the HTS break. Under the least favourable re-flooding conditions, water penetrates into the voided channel by counter-current flow through feeders, driven by gravity³⁸.

AND

- b) A make-up into the calandria vessel is also provided in order to ascertain that the alternate heat sink remains available while the hot fuel is being flooded. This make-up is the same as that enumerated in Item C.2 of Section 4.1.1 (i.e., $\leq 18 \text{ L s}^{-1}$). The calandria vessel make-up is not required for an in-core break, where the break discharge maintains the calandria tubes submerged by the discharge of water from the HTS.
- c) In long term, only the flooding make-up of $\leq 13 \text{ L s}^{-1}$ is required, because the fuel debris within the channels is readily coolable.

5.1.2 Design Provisions for SAM

The ACR design can accommodate the above SAM requirement.

- a) In order to flood the debris in the HTS:
 - 1) Water can be manually supplied from the RWS (Figure 4-6).

OR

³⁸ Experiments are available to demonstrate that the channels can be flooded under these most unfavourable circumstances.

- 2) Water can be manually supplied to the HTS from the containment sumps by the LTC pumps (Figure 5-1)³⁹, presuming that an earlier failure of the LTCS (which led to the moderator acting as a heat sink) was restored by SAM actions (see SAMDA Candidate 4).
- b) In order to maintain the calandria vessel full of water during the HTS flooding process, water can be manually supplied from the RWS (Figure 4-6). The combined make-up capacity (i.e., HTS plus calandria vessel) is well in excess of the minimum SAM requirements (i.e., the make up rate is comparable to the flow provided by the LTC pumps).
- c) In order to maintain the core materials flooded within the HTS (i.e., within the channels) into the long term:
 - 1) The rugged LTC pumps⁴⁰ can maintain the channels flooded indefinitely by re-circulating water from the containment into the HTS. This again presumes that the LTCS was restored to service following an earlier failure by SAM actions.
AND
 - 2) The inventory of the reserve water tank can be replenished by an external water supply. The design provides connections to fire water and demineralized water systems for such purposes. The mission time of the RWS make-up can thus be extended for many days.
AND
 - 3) The design could provide a capability of post-accident cross-connection between the water pool on the containment floor and the demineralized water supply line to the RWS (via a portable pump) as alternate means to keep the core flooded indefinitely (see SAMDA Candidate 5).

SAMDA Candidate 4 LTCS – Emergency Connections to Alternate Services

Connections to facilitate alternate services are already identified generically as SAMDA Candidate 1. This is a subset of the generic item. The LTCS is one of the two heat sinks that could dissipate heat into the environment following a severe accident (the other heat sink is provided by local air coolers, SAMDA Candidate 7). This system is already provided with highly reliable power and service water supplies (Reference [6]), including a connection to supply external water into LTC pump circuit. Providing means to connect alternate (e.g., portable) power to the LTC pumps and water to the LTC heat exchangers would increase the reliability of this long-term heat sink in severe accidents.

³⁹ Motorized valves and pump recirculation are available to regulate the water supply rate (Figure 5-1).

⁴⁰ These pumps are environmentally qualified for LOCAs and are not subjected to a particularly harsh environment in severe accidents (only the radiation fields could be higher relative to the design basis accidents). They will be assessed for operability under environmental conditions of SCD accidents.

SAMDA Candidate 5 RWS – Emergency Connection for Water Recirculation

The already provided connections to external water supplies extend the mission time of the RWS. Also, there is a connection from the discharge of LTC pumps to the reserve water tank⁴¹. Using a ‘jumper’ and a portable pump to refill the reserve water tank with containment water would provide another means of extending this mission time (to an essentially indefinite time). This type of SAM provision involves containment penetrations (extensions) and warm radioactive water outside of the containment, so it is not straightforward. A cost/risk benefit assessment would reveal if this were a viable option.




Figure 5-1 Flow Diagram of Long Term Cooling System

⁴¹ The RWS is not required when LTCS is in service. However, the RWS could be replenished via this path to restore a reserve to be available in case of a long-term LTCS failure.

5.2 Termination in Calandria Vessel

Core debris is located in the calandria vessel. The debris might be in a residual water pool, or it might be dry and hot. The worst initial condition is when the calandria vessel is fully voided and the debris is compacted (Figure 4-10). The calandria vessel is depressurized via the four calandria rupture disks⁴². The end shields and the shield tank are full of water or partially voided⁴³.

Broad requisites for terminating the core damage within the calandria vessel are:

- a) Flood the debris within the calandria vessel with water such that it is fully submerged.

AND

- b) Maintain the calandria vessel wall externally cooled.

The pressure relief is not at issue for the flooding of debris, because the steaming rate is governed by the rate of water addition. The steaming is invariably more gradual than that following a relocation of a large mass of hot materials into a residual water pool.

5.2.1 SAM Boundary Conditions

Conditions that achieve the above requisites are:

- a) Water is manually supplied into the calandria at a rate ≥ 1.5 times the maximum steaming rate in the calandria (Item C.2 in Section 4.1.1), which amounts to $\geq 18 \text{ L s}^{-1}$.

AND

- b) The external shield water heat sink is maintained by supplying $\geq 8 \text{ L s}^{-1}$ into the shield tank (per Item C.2 in Section 4.2.1).

5.2.2 Design Provisions for SAM

- a) Two flow paths are available for the passive water supply from the RWS (i.e., through the HTS⁴⁴ and directly into the calandria vessel, Figure 4-6). In addition, the SAM can also use water supplies from the ECIS⁴⁵ and the LTCS if they can be restored during the accident progression. Each of these water sources can deliver more than sufficient flow to flood the debris within the calandria vessel and keep the debris flooded for a long time (tens of hours to days).

AND

- b) A flow path is provided from the RWS into the shield tank (Figure 4-6) with ample flow capacity.

⁴² The calandria rupture disks are invariably open during the core disassembly.

⁴³ Prudent SAM actions would be to refill the end shields and the shield tank before flooding the debris in the calandria vessel to minimize thermal stresses.

⁴⁴ The channels are invariably broken during the core disassembly.

⁴⁵ This presumes that the ECI accumulator tanks were not discharged in the earlier stages of the SCD accident.

In terms of maintaining the core materials flooded indefinitely, the RWS reserve provides time to restore the LTCS to service (SAMDA Candidate 4). A back-up provision for maintaining the core flooded in the long term might be viable (SAMDA Candidate 5).

5.3 Termination in Shield Tank

This topic is relevant only to the reference ACR design, which has the metal shield tank (the alternate design with the concrete tank is covered in Section 5.5). Core debris is located in the shield tank. The debris might be in a residual water pool, or it might be dry and hot. The worst condition in terms of terminating the damage is when the shield tank is fully voided and the debris is compacted (Figure 5-2). The shield tank is depressurized.




Figure 5-2 Shield Tank Conditions prior to Internal Flooding (conceptual)

The only requisite is to flood the debris with water such that it is fully submerged. The external shield tank cooling is passive (i.e., by fluids previously discharged or added into the containment), so no actions are required to maintain the external heat sink during the flooding.

Similar to damage termination in the calandria vessel, the steam relief from the shield tank is not at issue at this stage. The steaming is invariably more gradual than that following a relocation of a large mass of hot materials into a residual water pool.

5.3.1 SAM Boundary Conditions

In order to achieve the above single requisite, water needs to be manually supplied only into the shield tank at a rate ≥ 1.5 times the maximum steaming rate in the shield tank (Item C.2, Section 4.2.1), which amounts to $\geq 12 \text{ L s}^{-1}$.

5.3.2 Design Provisions for SAM

Three flow paths are available for the gravity water supply from the RWS into the shield tank (i.e., through HTS⁴⁴, calandria vessel⁴⁶ and/or directly into the shield tank; Figure 4-6). In addition, because all process vessels are interconnected, a water supply from the LTCS can also be used if it is restored during SAM (SAMDA Candidate 4). Each of these water sources can deliver a sufficient flow to flood the debris.

In terms of maintaining the core materials flooded into the long term, the same considerations apply as discussed in Section 5.2.2 for damage termination in the calandria vessel (i.e., the LTC system is to be restored and/or the water inventory in the reserve water tank is to be replenished).

5.4 Termination in Reactor Vault (Containment)

This section is relevant to the reference ACR design only (i.e., the design with the metal shield tank, Reference [6]). The reactor vault is an open compartment of the containment (i.e., concrete walls are only on the sides of the reactor assembly and the end faces of the reactor do not have any walls).

The containment always has a water layer on its floor following a SCD accident. This water pool keeps the core debris retained in the shield tank (Section 4.3). For the debris to relocate into the containment, some perforation of the submerged tank wall has occurred, for which no mechanisms have been identified. Alternatively, the time is long after the start of the accident such that water on the containment floor has evaporated to a level below the corium elevation in the shield tank. As discussed in Reference [8], this implies a lack of containment heat sinks in conjunction with a containment opening through which vapour escapes into the environment. Probabilities of either of these causes of debris relocating into the containment must be incredibly low. No human actions are possible at this point in accident progression to impact the subsequent outcome in terms of debris behaviour.

At issue are the corium-concrete thermal and chemical interactions. A criterion developed by Electric Power Research Institute (EPRI) is that the floor space for corium debris spreading should be $\geq 0.02 \text{ m}^2 \text{ MWth}^{-1}$ (Reference [10], based on Reference [13]) in order to avoid these interactions when the floor is flooded with water⁴⁷. The corium will be at low decay powers when it relocates from the shield tank into the reactor vault ($< 0.5 \%$ full power, Section 4.3.1), but it contains a significant amount of unoxidized Zircaloy, which can react with water to generate heat and hydrogen. Simulations are required to evaluate the thermal power of the corium upon contact with the concrete, which are in progress but the results are not yet available.

5.4.1 SAM Boundary Conditions

Slurry of molten and solid core materials has poured into the reactor vault, which contains a pool of water⁴⁸. The SAM-related design feature is to provide a sufficient floor space such that debris

⁴⁶ The calandria shell is invariably perforated when the debris is present in the shield tank.

⁴⁷ This criterion relates to the thermal power of the reactor prior to the accident (i.e. the full power).

⁴⁸ Water pool on the containment floor is a continuous volume, so that no water make-up would be required for a very long time to keep the core debris submerged.

can spread and cool down by one-sided heat transfer to water present at the top of debris bed⁴⁹. The SAM actions cannot affect the debris behaviour at this juncture, so the SAM focuses on protecting the containment integrity (Section 6). Because the reactor vault is an open structure, the steam surges due to debris quenching are absorbed by the whole containment volume. A water make-up to the containment floor is invariably provided when a heat sink for the containment atmosphere is provided (i.e., the condensed water ends up on the floor). Adding water into the containment is also a long-term option, but it would likely be from external sources (i.e., it is inconceivable that the passive water reserve would not be used up in an effort to prevent the debris penetrating into the containment). Connections to firewater and to demineralized water tank are available should a long-term make-up be needed.

5.4.2 Design Provisions for SAM

As already explained, no SAM actions related to terminating the damage in the reactor vault are possible. The reactor vault has a large floor area for debris spreading⁵⁰. However, there is a depression underneath the shield tank (Figure 4-12), which could locally inhibit the spreading (see SAMDA Candidate 5).

SAMDA Candidate 6 Reactor Vault - Floor Contour

The depression provides a floor clearance that facilitates the external cooling of the shield tank as well as facilitates access for maintenance and/or inspection. The effect of a depression on the corium coolability needs to be examined (the assessment is planned). Should the depression turn out to be a potential cause of corium-concrete interactions, it could be eliminated. However, this type of change feeds back on many post accident parameters, including the shield tank coolability. It is anticipated that a probability of the corium penetrating into the containment would be very low. Hence, cost/risk benefit assessment would help with design decisions.

5.5 Termination in Calandria Vault (Containment)

This section is relevant to the alternate ACR design only, which uses an enclosed, steel-lined concrete 'compartment' or 'tank' (i.e., the calandria vault) instead of the steel shield tank. This enclosed volume is not normally interconnected with other containment volumes.

The calandria vault will contain a rather deep pool of water when the corium relocates into it (Figure 5-3). It will be vented into the containment (via the shield cooling system relief) well before the corium enters it. The inevitable steam surge following the corium relocation into the vault could be taken advantage of in order to open additional relief paths, which could interconnect the water pools in the vault and in the containment (as schematically illustrated in Figure 5-3). In turn, this would provide a passive water pool for long term corium cooling⁵¹.

⁴⁹ Providing sufficient floor space to enhance debris spreading is a broad US NRC requirement (Reference [10], Item H).

⁵⁰ The comparison with the EPRI criterion has not yet been made. A judgement is that this criterion would be met, even if only the floor area delineated by the reactor faces and the concrete side walls were used in the denominator (i.e., if debris spreading in the axial direction is ignored).

⁵¹ This option could also provide an additional floor area for debris spreading.

Whichever way the adequate relief of steam surges is provided (which is the design intent), the issue of core-concrete interactions is the same as that discussed previously in Section 5.4. The footprints of both structures between the reactor faces are the same, so there is an adequate floor space for debris spreading. The difference is in the access of containment water pool to the debris. The water pool in the calandria vault is a separate entity from the water pool in the containment. Hence, the 'passive make-up' from the containment water pool is not available unless a path is opened during the accident progression.

5.5.1 SAM Boundary Conditions

Slurry of molten and solid core materials has poured into the reactor vault, which contains a pool of shield water. Strong steam surges need to be relieved into the containment and a sufficient floor space needs to be provided such that debris can spread and cool down by one-sided heat transfer to water present at the top of debris bed. The SAM cannot affect the debris behaviour in the short terms. A water supply into the calandria vault is needed in the long term to keep the debris under water.




Figure 5-3 Calandria Vault Conditions upon Calandria Vessel Failure (conceptual)

5.5.2 Design Provisions for SAM

The alternate design is not finalized at this time. Conceptually, the calandria vault can provide the same ability to terminate the core damage as the reactor vault. It has a similar demand on the relief of steam surges as the shield tank with an added demand on the long-term water supply to keep the debris under water. This later demand could be addressed by several options, including a make up from RWS to any of the process volumes or an interconnection with the containment water pool. These options would become SAMDA candidates if the alternate design were to be adopted.

6. DESIGN PROVISIONS TO MAINTAIN CONTAINMENT INTEGRITY

The containment is a combination of structures, isolation devices and metallic extensions of the containment envelope. It consists of reactor building, airlocks, process penetrations and electrical penetrations. The containment is designed to withstand external events such as earthquake, tornado and floods. For internal challenges, an energy suppression system (air coolers) and atmospheric control system (passive autocatalytic recombiners) are provided (Reference [6]).

Following an accident, the containment is sealed (isolated). Decay heat and any other post-accident heat sources are dissipated to the outside by the process systems (e.g., steam generators, moderator cooling system and shield cooling system) and/or the safety related systems (LTCS and LAC). Should the energy dissipation systems be unavailable, the energy is stored in the containment as sensible heat in various fluids and structures until the energy dissipation to the outside is re-established by AM or SAM. The containment pressure rises when there is a mismatch between the heat generation rate and the heat dissipation rate in the sealed volume, mainly due to the steaming of the process fluids. In LCD and SCD accidents, non-condensable gases can also be generated by thermal-chemical interactions of hot core materials, which contribute to the containment pressurization. The pressurization poses a challenge to the containment integrity.

Some of the non-condensable gases generated in LCD and SCD accidents are flammable (e.g., hydrogen and carbon monoxide if the core-concrete interactions were to be possible). Should these gases ignite, large amounts of chemical energy are rapidly released, causing pressure spikes or, in an extreme, shock waves. The accumulation of the non-condensable gases and the attendant deflagration hazard is a threat to the containment integrity, which applies even when the energy is being effectively dissipated to the outside.

Thermal-chemical interactions between corium and concrete are major sources of non-condensable gases, which would contribute to the containment pressurization as well as to the deflagration hazard. The corium-concrete interactions are widely recognized to pose a significant challenge to the containment integrity in reactor designs where such interactions are plausible. As discussed in Sections 5.4 and 5.5, this hazard is minimized in the ACR.

SCD accidents in pressure vessel reactors could cause a high-pressure core melt ejection into the containment, which could threaten the containment integrity by the so-called Direct Containment Heating (DCH). As explained in Reference [8], the DCH is physically impossible in a CANDU reactor. Hence, no provisions to mitigate it are needed.

A probabilistic design target related to the maintenance of containment integrity is in the form of cumulative large release frequency ($< 10^{-6}$ per year; Table 3, Reference [7]). Deterministic SCD analyses of the ACR (which quantify the various integrity challenges as part of Level 2 PSA) have not yet been completed (in progress). Until these latter analyses are available, design requirements pertaining to the topic of this section can only be based on engineering assessments guided by LCD and SCD accident analyses of the existing CANDU plants and the severe accident analyses performed for other reactors.

US NRC (Reference [14]) defines an overall containment performance requirement for accidents that cause core damage as follows:

For a period of approximately 24 hours following the onset of core damage, the specified containment challenge event results in no greater than the limiting containment leak rate used in evaluation of the event categories and structural stresses are maintained within acceptable limits (i.e., ASME Level C requirements or equivalent). After this period, the containment must prevent uncontrolled releases of radioactivity.

Note that this set of requirements does not include a probabilistic threshold. Applied literally, this could mean that the containment must be designed such that it does not fail for at least 1 day when all active systems that mitigate the mass and energy sources into the containment are unavailable. The passive (or essentially passive) features that do not place any significant demand on the supporting services can presumably be credited with mitigating the mass and energy sources. These features include the boundary strength and the free containment volume to accommodate steam and non-condensable gas generation plus the storage capacity of internal fluids and structures to accommodate heat generation in the sealed containment.

Since a hydrogen generation cannot be precluded in SCD accidents, hydrogen detonation must be prevented. Reference [10] sets the following requirements, again without a probabilistic context:

- *Accommodate hydrogen generation equivalent to a 100-percent metal-water reaction of the fuel cladding.*

In a PWR context, this means equivalent to all Zircaloy in the reactor. This requirement would impact on the free containment volume if the H₂ dilution were to be the only mitigation phenomenon. However, with the explicit requirement for providing an engineered hydrogen control system (see below), this requirement does not impose any practical constraint on the design.

- *Limit containment hydrogen concentration to no greater than 10 percent.*

This is to avoid detonation. Pressure peaks due to H₂ deflagration are covered by the above containment performance requirement. Note that the criteria for the avoidance of detonation have evolved (e.g., Reference [15]) and the prescribed numerical value may not be up to date.

- *Provide containment-wide hydrogen control (such as igniters or inerting) for severe accidents.*

This means that a hydrogen control system is a prerequisite, capable of producing acceptable peak pressure within the containment in any LCD or SCD accident.

The ACR is designed for international markets, including the US market (Section 1, Reference [7]). Hence, the preceding requirements apply in addition to the probabilistic criterion of the summed large release frequency.

6.1 Containment Pressurization

Design features to mitigate containment pressurization include:

- a) Containment strength (i.e., design and ultimate pressures) and its free volume.

The ideal gas law ($PV = nRT$) illustrates that for a given threshold pressure (P), the amount of gas (n) at saturation temperature (T) that can be contained is proportional to the containment free volume (V). The strength and the free volume are passive design features.

- b) Provisions to condense steam in the containment atmosphere.

Specific volume of water vapour is approximately 1000 times that of liquid water.

Condensation reduces the amount of steam (n) in the free volume (V). The condensation can be accomplished by providing a gas circulation through a heat exchanger and an external heat sink (i.e., the active feature). Steam can also be condensed by bringing subcooled water into contact with the containment atmosphere (e.g., sprays) and transferring the latent heat of vaporization into the sensible heat of liquid water (i.e., the passive feature).

- c) Provisions to stop/reduce steam addition into the containment atmosphere.

This is accomplished by providing water circulation and an external heat sink for process water volumes (i.e., the active feature) and/or by providing subcooled water volumes within the containment to store decay heat as sensible heat in the internal liquid water volumes (i.e., the passive feature).

6.1.1 SAM Boundary Conditions

The boundary conditions are difficult to state quantitatively as explained below.

- a) The containment strength (i.e., design pressure) and its free volume, which have major economic implications, are typically not set by severe accident considerations. The only semi-deterministic requirement for severe accidents is the overall performance requirement of Reference [14] (quoted on Page 6-2). However, complex analyses of rare accidents are required to establish that the choice of the parameters meets this requirement. The same complex analyses are required to establish the compliance with the probabilistic target of Reference [7].

- b) The steam condensation capacity for SAM needs to remove the integrated decay and chemical energy deposited into the containment atmosphere from the time of containment isolation to 1 day after the onset of core damage accident. Again, this broad requirement is difficult to enumerate, mainly because of the uncertainties in how much of the chemical energy is realistically generated during a SCD accident (Reference [8]).

The steam condensation provisions are typically designed to suppress the containment pressure following a rapid discharge of superheated primary coolant during a LOCA (e.g., Section 6.5.2.2, Reference [6]). The LOCA steaming rates are invariably higher than the long-term steaming rates of SCD accidents. Hence, the capability to suppress the pressure following a LOCA should cover the long-term steam condensation needs of SCD accidents.

- c) The active heat sinks for the process fluids should remove the decay heat at any time the process fluid serves as the alternate heat sink for the core. The required heat removal capacity is enumerated in Section 4. There is no specific requirement on the passive heat absorption capacity provided by the various process fluids within the containment. The heat

absorption capacity is set by other considerations, such as normal operating conditions of these fluids.

In practice, the steam condensation capacity (Item 2) and the heat absorption capacity (Item 3) are set by considerations other than SAM. The containment structure parameters (Item 1) are defined by experience, practicality and cost.

6.1.2 Design Provisions for SAM

- a) The design pressure is 250 kPa(g) (36.3 psig), the proof test pressure is 287.5 kPa(g) (41.7 psig) and the net free volume is 49500 m³ (Table 13.2.1 and Table 6.5-1, Reference [6]). The ultimate pressure capacity will be at least two times the design pressure. Analyses are not yet available to confirm that the requirements in References [7] and [14] are met.
- b) The provisions to condense steam in the containment atmosphere are as follows⁵²:
 - 1) Local Air Coolers (ASI 73110, Table 13.2.1, Reference [6]) are provided in the steam generator vault (8 LACs), the reactor-building dome (4 LACs), the moderator room (6 LACs), and at other reactor building locations (16 LACs)⁵³ (see SAMDA Candidate 7). Analyses are not yet available to enumerate their steam condensation performance in SCD accidents. However, based on experience, there is little doubt that the steaming of LCD and SCD accidents will be effectively mitigated if and when the air circulation and the heat removal by LACs are available.

The LACs will be environmentally qualified for design basis accidents. This includes harsh environments within the containment due to LOCA and steam line breaks (Reference [6]). Containment thermal-hydraulic conditions during LCD and SCD accidents would not be appreciably worse than those of limiting DBAs when LACs are operational⁵⁴. However, radiation fields will be higher in LCD and SCD accidents as compared to DBAs. The LACs will be assessed for their ability to withstand environmental conditions of severe accidents⁵⁵.
 - 2) The ACR does not have a passive provision to condense steam in the containment atmosphere (see SAMDA Candidate 8).
- c) The provisions to avoid steaming into the containment are as follows:
 - 1) Highly reliable, active post-accident heat sinks are provided for the HTS (i.e., the LTCS), the calandria vessel (the moderator cooling system and the LTCS following an in-core

⁵² The LAC heat exchangers offer some capability even without the forced flow of air, which is being assessed.

⁵³ Steam Generator Vault and Dome coolers have Class III power supply to the fans and the service water is pumped by Class III power supply.

⁵⁴ A steady steaming to reject decay heat and the short-lived steam surges due to debris quenching are less severe challenges to the LACs than the fast discharges of high-enthalpy coolant or steam.

⁵⁵ The LCD and SCD accidents release significant amounts of airborne radioactivity, much of which ends up being deposited in the LACs and their associated air ducts. It should be possible to provide adequate shielding of critical LAC components such that their function is not impaired by the deposited radioactivity.

break) and the shield water (the shield cooling system), which would stop the steaming into the containment atmosphere when available.

- 2) The passive make-up of subcooled water into the process vessels (see Sections 4 and 5) could also prevent/reduce steaming into the containment atmosphere (e.g., if water is added at a rate that would raise its temperature to saturation point and the saturated water would then be allowed to overflow into the containment). In terms of energy balance (i.e., delaying the containment failure due to steam pressurization), this passive make-up should be as effective as the sprays (see SAMDA Candidate 9).

SAMDA Candidate 7 LACs – Emergency Connections to Alternates Services

Connections to facilitate alternate services are already identified generically as SAMDA Candidate 1. This is a subset of the generic item. The LACs provide one of the two heat sinks that could dissipate heat into the environment following a severe accident (the other heat sink is provided by the LTCS, see SAMDA Candidate 4). This system is already provided with highly reliable power and service water supplies (Reference [6]). Providing means to connect alternate (e.g., portable) power to the LAC fans and water to the LAC heat exchangers would increase the reliability of this long-term heat sink in severe accidents. A cost/risk benefit assessment would show if this is a viable option.

SAMDA Candidate 8 Containment Sprays

Many operating reactors employ containment sprays as alternate means of post accident pressure suppression, combined with a suppression of airborne radioactivity. The ACR employs two independent trains of highly reliable local air coolers, which serve the same two purposes as the sprays. An obvious question is how significantly the radiological risk would be affected by adding the sprays into the design. The cost/risk benefit assessment of the sprays will answer this question as well as provide comparison to SAMDA Candidate 7.

SAMDA Candidate 9 Passive Suppression of Steaming from Process Vessels

Inlet/outlet temperature measurements are provided in the calandria, the shield tank and the end shields. These measurements are not relevant to SAM when the passive make-up is used, because the outlet (overflow) locations are different from those during normal operation. Hardened temperature measurements in post-accident water overflow paths (typically, steam relief paths) could be provided for SAM. This is not considered to be a practical alternative (the SAM actions would be more complicated). A cost/risk benefit assessment should confirm the current judgement.

6.2 Hydrogen Control

Hydrogen is generated slowly (by radiolysis) in many accidents, including design basis accidents. This hydrogen source takes days to build up flammable concentrations in containment atmosphere. Severe accidents also have this hydrogen source, in additions to hydrogen generated by chemical reactions between metals (mainly Zr) and steam at high temperatures.

The generation rates in severe accidents can be fast, because the reaction between Zr and steam is exothermic. The reaction kinetics depend to temperature, steam availability and reaction history (i.e., build-up of protective ZrO₂ layers on metal surfaces). If an accident involves a combination of high temperature, ample oxidant supply and metal surfaces without thick oxide layers, large amounts of hydrogen can be produced within tens of minutes. In CANDU reactors, these conditions broadly exist during the core disassembly stage of SCD accidents (Reference [8]).

Hydrogen accumulates in the atmosphere of the sealed containment structure. If and when elevated concentrations build up, the atmosphere becomes flammable. Burns would release energy into the atmosphere, causing rapid containment pressurization. If high concentrations build up, the mixture could detonate, thereby producing shock waves. The flammability is suppressed by a presence of steam in the containment atmosphere. A worst SCD accident condition in terms of burn/detonation potential is during, or following, a core disassembly, when large amounts of hydrogen can be generated rapidly (i.e., hydrogen concentrations can be high) and when the LACs are available to condense steam in the containment atmosphere (i.e., the inerting effect by steam is removed).

Numerous combinations and permutations of accident progression can be postulated that produce hazardous gas mixtures in the containment atmosphere. Broad requisites on post-accident hydrogen control can be stated as follows:

- As far as practical, remove H₂ from the containment atmosphere.

This requisite applies the “as low as reasonably achievable” (ALARA) principle to hydrogen control. There is no specific licensing requirement to apply the ALARA principle to hydrogen, but the worldwide trend is to employ passive hydrogen removal devices in conjunction with other hydrogen control provisions (e.g., Reference [16]).

Passive autocatalytic recombiners are well suited for this requisite, because they do not require any services to operate.

- Prevent H₂ detonation.

This is the pre-requisite of the US NRC containment performance requirement in Reference [14] (cited on page 6-2), which is not qualified by a probabilistic threshold. Preventing detonation is the reason behind the US licensing limit in Reference [10] on the maximum hydrogen concentration (cited on page 6-2). It is also the objective of the requirement in Reference [10] for a plant-wide protection using containment inerting or igniters (cited on page 6-2). The rationale is that the consequences of a detonation cannot be quantified (but are likely to be very severe); therefore, the detonation must be avoided for all accidents, including the most severe ones.

Passive removal devices may not be able to avoid hydrogen-rich mixtures in severe accidents with large and fast hydrogen generation rates because of their removal rates tend to be slow. There is no experience with containment inerting in CANDU plants⁵⁶. The igniters can prevent detonation by means of deliberate ignition, which can only cause limited plant

⁵⁶ In principle, the ACR containment could be inerted, but it would remove its advantageous feature of being able to access many containment areas at power.

damage as compared to major damage due to deterioration. There is a considerable experience in Canada with the igniters.

6.2.1 SAM Boundary Conditions

Conditions that achieve the above requisites are:

- a) Containment atmosphere is well mixed such that local pockets with high hydrogen concentrations do not exist.
AND
- b) Systems/devices are available to remove hydrogen without burns.
AND
- c) Should the above systems/devices (in conjunction with the dilution volume) be unable to prevent detonable mixtures, back-up systems/devices are available to rapidly remove hydrogen from the containment atmosphere before the detonable mixtures develop.
AND
- d) If back-up system is provided, means are also provided to determine the post-accident composition of the containment atmosphere, such that the back-up system can be activated at optimum mixture compositions in terms of minimizing the containment integrity challenge.

6.2.2 Design Provisions for SAM

- a) The containment atmosphere is thoroughly mixed to prevent local pockets of high hydrogen concentration. The LACs mix the atmosphere between the accessible and inaccessible areas of containment (Figure 6-1). Passive mixing of critical volumes is provided by the layout of the reactor building (Figure 6-2)⁵⁷.

AND

- b) Passive autocatalytic recombiners are provided, which chemically recombine the hydrogen gas with oxygen to form water vapour. The design is not yet finalized in terms of number and locations of devices in the containment (Section 7.2.4.3.4 in Reference [6]).

The recombiners developed by AECL have a high catalytic activity for hydrogen oxidation, are not deactivated by water vapour or steam, are unaffected by high radiation fields and operate over a very wide range of temperatures. In steam-rich mixtures, the catalyst self-starts at less than 2 % H₂ (i.e., well below the flammability threshold). This recombiner has undergone extensive full-scale qualification testing at containment conditions relevant to LCD accidents. Full-scale test parameters covered thermal aging, radiation aging, seismic loads and exposures to H₂/air/steam mixtures, aerosols prototypic of LCD accidents and water sprays containing prototypic chemicals used in CANDU plants. Small-scale tests also covered exposures to hydrazine, hydrochloric acid and halogens (chlorine and iodine). Additional assessments will extend into the SCD environments⁵⁸

⁵⁷ Ongoing analysis of containment mixing will also explore SCD accident conditions.

⁵⁸ Any catalyst can be "poisoned". SCD accidents release substantially larger amounts of fission products into the containment relative to LCD accidents and these fission products could affect the catalytic recombiner performance.

AND

- c) The technology and the know-how related to a rapid hydrogen-removal provision are available, but this provision has not been incorporated into the ACR design (pending the completion of assessments how effective the committed hydrogen removal provision is).

AND

- d) The ACR design provides a facility to sample the containment atmosphere (Section 7.2.4.3.4 in Reference [6]).

Hydrogen control provisions are obvious candidates for SAMDA assessment (see SAMDA Candidate 10). The design can be easily adjusted because:

- The passive autocatalytic recombiners do not place any requirements on the plant services whatsoever.
- The igniters have a minor demand for a reliable power supply and the actuation gear, which can be readily accommodated at any stage of the design⁵⁹.

The bottom line is that the ACR can and will meet any regulatory requirements on hydrogen control.

SAMDA Candidate 10 Hydrogen Control

Hydrogen control involves compromises between slow technologies using catalytic recombiners and fast ignition technologies, which have drawbacks in terms of additional (albeit limited) plant damage. The slow technologies become expensive for a mitigation of fast transients, because the number of devices is approximately proportional to the total hydrogen removal rate by these devices. Documenting the costs and the risk benefits of basic alternatives (recombiners only, igniters only and a hybrid system of both technologies) will help to explain the final design choice. The inerting option should also be assessed, as it is identified by US NRC as one of the possible solutions.

⁵⁹ The provision for sampling of the containment atmosphere, which involves containment penetrations and which is required for activation of igniters is already in the design.




Figure 6-1 Active Containment Mixing




Figure 6-2 Passive Containment Mixing (conceptual)

6.3 Corium-Concrete Interactions

A direct attack of hot core materials on the containment boundary needs to be prevented. This amounts to terminating the accident progression in the containment, should the corium penetrate that far during a SCD accident. The design provisions to terminate the core damage in the containment are covered in Sections 5.4 and 5.5

7. DESIGN PROVISIONS TO MINIMIZE OFF-SITE RELEASES

The isolated ACR containment is leak tight. The leakage rate at which the off site releases are analyzed is $\leq 0.5\%$ of the free containment volume per day at design pressure. The design target is $\leq 0.2\%$ per day at the same pressure, which amounts to $< 1.2 \text{ L s}^{-1}$ (Table 6.5-1, Reference [6]).

The EOPs, which precede the SAM, invariably call on the operator to perform the following actions:

- Confirm that the containment is isolated.
- Manually close any open penetration.
- Monitor radioactivity levels in the plant to identify any leaks in the containment envelope.

Section 6.5.2.1.3 in Reference [6] describes the containment isolation system and Section 7.2.4 in the same reference describes the containment instrumentation provided to establish, maintain and monitor the isolation. The EOPs will define the radioactivity monitoring activities.

The above activities establish a sealed containment boundary, which envelopes the heat-generating reactor core. This heat must be removed to the outside, or it results in a sustained pressurization of the sealed volume to the point of boundary failure. The containment performance requirement of the US NRC (cited in Section 6, Page 6-2) stipulates that “the containment must prevent uncontrolled releases of radioactivity” even if it were to fail (i.e., exceed the prescribed stress limits). In simple terms, this means that the containment is to be designed such that it cannot fail catastrophically (i.e., explode) by internal pressurization⁶⁰. The ACR has a steel-lined, concrete containment that would open a path to relieve the internal pressure, rather than failing catastrophically. An open path causes a major release of radioactivity during the containment depressurization; however, the breached structure remains in place to offer some mitigation capability in the long term.

The long-term mitigation capability can be ensured by providing a controlled release path to the environment if and when the containment failure is imminent. For an open containment, design provisions that minimize the off-site releases are any provisions to filter or scrub the fission products within the structure or in a controlled release path if it is provided.

Broad requisites on provisions to minimize the off-site can be categorized as follows:

1. Ensure that the structure cannot fail catastrophically.
2. Minimize the airborne radioactivity in the effluents escaping from the open structure.

⁶⁰ Design requirements in Section 6.2 are to prevent shock waves and the requirements in Section 5.4 are to prevent direct corium interactions with the containment boundary. Hence, the containment pressurization is the only challenge that requires mitigation by active systems in the long term (days or weeks).

7.1 SAM Boundary Conditions

- a) A high degree of confidence can be attained by assessing the containment design in light of available experiments on containment failures. The only possible design option to actually ensure an open structure with a significant retention capability is to provide an emergency relief path to avoid a spurious failure of the structure.
- b) Several options are available to minimize the off-site releases, depending whether or not the containment structure is vented deliberately or as a result of a structural failure.
 - 1) Filters can be employed in the vent path.
 - 2) The vent path can be routed to an existing water pool, which scrubs soluble and condensable fission products.
 - 3) Re-circulating filters/scrubbers can be employed to remove aerosols from the containment atmosphere.
 - 4) Containment sprays can be used to scrub the aerosols and soluble gases from the containment atmosphere, in addition to reducing the driving force for the long-term escape of radioactivity into the environment (by condensing steam).

7.2 Design Provisions for SAM

- a) The ACR employs a containment structure similar to “large, dry” containments of LWRs. This type of structure is widely judged not to be prone to a catastrophic explosion. No provisions are currently made for emergency venting of the structure (SAMDA Candidate 11).
- b) Provisions for a removal of radioactivity from an emergency relief path are part of SAMDA Candidate 11. The only provision for a removal of radioactivity within a breached containment is the LACs (see SAMDA Candidate 7). The LACs are very effective in removing aerosols and soluble fission product from a gas steam that passes through them⁶¹. The containment sprays are not provided (see SAMDA Candidate 8). They would also be effective for the long-term suppression of radioactivity, given that the RWS water reserve can be replenished with sub-cooled fire water and or demineralized water.

SAMDA Candidate 11 Off-Site Release Control – Containment Venting

Prerequisites of any practical design provision for extremely rare events are simplicity, ruggedness, reliability and low cost. Ideally, an existing containment penetration would be fitted with means to facilitate an emergency pressure relief into a water pool that absorbs some of the relieved energy as well as scrubs some of the radioactivity from the effluent stream. Other design alternatives (e.g., a dedicated path, different media to scrub the radioactivity, etc.) are undoubtedly feasible from the technical standpoint. A cost/risk benefit assessment is needed to explain why a provision for emergency venting is not required.

⁶¹ A conceptual dilemma with LACs as release control devices in a breached containment is that they are likely not operational if the containment has failed. Operating LACs would have prevented the pressurization by steaming, which is the most likely cause of containment failure in SCD accidents.

8. CLOSING REMARKS

The review of the ACR design provisions for severe accident management (Sections 3 through 7) has not revealed any flaws. Several topics are identified that will likely require a formal assessment of costs and risk benefits under the SAMDA assessment process of the US NRC. This report brings these topics to the attention of the designers, thereby initiating the review process.

The active heat sinks for the “vessels” (i.e., the fuel channels, the calandria vessel, the calandria end shields and the shield tank or the calandria vault) are all amply capable of dissipating the post-accident heat loads. These heat sinks are expected to be operable under severe accident environmental conditions; however, this expectation is yet to be confirmed by assessments. The active heat sinks for the vessels are “backed up” by passive heat sinks (see below). Hence, the issue of their operability in severe accidents is not a “black and white” topic.

The passive heat sinks for the process vessels (i.e., steaming plus water make-up from the RWS) are well designed for severe accidents. The supply side is simple, rugged and not vulnerable to failures of plant systems (other than a complete and prolonged loss of all electrical power supplies). The importance of the steam relief side is recognized and the assessments are in progress to ensure that the relief is adequate under severe accident conditions. The passive heat sinks would provide the SAM with more than 1 day (likely several days) of time to diagnose the accident and establish the ultimate heat sinks.

The active heat sink for the containment (i.e., the LACs) is duplicated and highly reliable. It has ample capacity for severe accident heat loads. It is expected to remain operable under severe accident conditions, subject to confirmation by assessments. Given that no passive backup for this heat sink is provided, a risk-informed assessment of alternatives will be needed to explain the adequacy of the design under severe accident conditions.

The instrumentation that can provide reliable information to the severe accident management team is critical to successful accident mitigation. The ACR instruments provide the necessary coverage as noted in the text. The design intent is to assess the instruments used for severe accident management for operability under environmental conditions of LCD and SCD accidents. As far as practical, these instruments will be hardened to withstand the severe accident conditions. Also, the measurements will be available not only in the main control room, but also in the secondary control building. This topic of instrumentation will be revisited as the results of the assessments become available.

Hydrogen control is required for all accidents. The current design uses autocatalytic recombiners, the effectiveness of which is yet to be confirmed for severe accident conditions. Options exist to satisfy any regulatory requirements. A risk-informed assessment of these options will likely be required to explain the adequacy of the design.

The ACR design is not prone to core-concrete interactions by virtue of multiple, externally cooled barriers between the fuel and the containment floor as well as due to characteristics of the compartment into which the core materials would eventually penetrate (i.e., a large area for debris spreading and plenty of water to submerge and cool the debris).

The ACR containment is expected to provide a long time of completely passive protection for any severe accident at decay power. Should it be allowed to fail in the long term (by not

providing any heat sinks), this type of containment is not prone to catastrophic failures. The failed structure would retain some capability to reduce radioactivity release into the environment. Options exist for enhancing the capabilities for minimizing the off-site releases. A risk-informed assessment of these options is likely to be required to explain the adequacy of the design for this SAM aspect.

The present report constitutes a high-level review in the early stages of design. Level 1 and 2 PSAs, which are in progress, will provide data for the risk-informed review of SAM-related design features.

9. REFERENCES

- [1] SECY-91-229, "Severe Accident Mitigation Design Alternatives for Certified Standard Designs", 31 July 1991.
- [2] NUREG-1437, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants" (Volume I, pp. 5-100).
- [3] "Implementing Severe Accident Management in Nuclear Power Plants", Senior Group of Experts on Severe Accident Management, OECD, 1996
- [4] Nuclear Energy Institute report, "Severe Accident Issue Closure Guidelines", NEI 91-04, Revision 1, December 1994.
- [5] ACR-700 Technical Description, 10810-01371-TED-001, Revision 0, June 2003..
- [6] C. Xu and C. Nie, "Safety Basis for ACR", 108-03600-AB-003, Revision 0, 2003 July.
- [7] A.J. White and C. Blahnik, "Phenomenology for Limited and Severe Core Damage Accidents in an ACR", 108-126810-LS-001, Revision 0, 2003 September.
- [8] Snell V.G. et al., "CANDU Safety Under Severe Accidents", AECL-9606, March 1988.
- [9] US NRC, "Policy, Technical, and Licensing Issues Pertaining to Evolutionary and Advanced Light-Water Reactor ALWR Designs", SECY-93-087, April 2, 1993.
- [10] Blahnik. C, Luxat J.C. and S. Nijhawan, "CANDU response to Loss of All Heat Sinks", Proc. Ninth ANS meeting on Nuclear Thermalhydraulics, San Francisco, 1993.
- [11] Rogers J.T., "Thermal and Hydraulic Behaviour of CANDU Cores Under Severe Accident Conditions- Final Report, Vol. 1 and 2, Atomic Energy Control Board INFO -0136, 1984.
- [12] "Advanced Light Water Reactor Requirements Documents: Vol III - utility Requirements for Passive Plants," EPRI 1990.
- [13] "Issues Pertaining to the Advanced Reactor (PRISM, MHTGR, AND PIUS) and CANDU 3 Designs and their Relationship to Current Regulatory Requirements", US NRC SECY-93-092, April 8, 1993.
- [14] Chan, C.K. et. al. , "State-of-the-Art Report on Flame Acceleration and Deflagration to Detonation Transition in Nuclear Reactor Safety", NEA/CSNI/R(2000)7, 2001.
- [15] Dana A. Powers to William D. Travers, "Lessons Learned from the ACRS (Advisory Committee on Reactor Safeguards) Review of the AP600 Design", March 22, 1999.