



Entergy

Entergy Operations, Inc.
1448 S.R. 333
Russellville, AR 72802
Tel 501 858 5000

2CAN020403

February 27, 2004

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

Subject: 2003 Annual Primary Coolant Activity Report
Arkansas Nuclear One – Unit 2
Docket No. 50-368
License No. NPF-6

Dear Sir or Madam:

Arkansas Nuclear One, Unit 2 (ANO-2), Technical Specification (TS) 6.9.1.5.e requires an annual submittal of the results of analyses in which primary coolant specific activity exceeded the limits of TS 3.4.8. The specific activity of the primary coolant, as required by TS 3.4.8, shall be limited to: a) less than or equal to 1.0 microcurie per gram Dose Equivalent I-131, and b) less than or equal to 100/E-bar microcuries per gram (where E-bar equals the average disintegration energy). The purpose of this letter is to provide this information for 2003.

During 2003, no primary coolant samples exceeded the specific activity limits specified in TS 3.4.8. Should you have any questions regarding this submittal, please contact Dee Hawkins at (479) 858-5889.

There are no new commitments contained in this submittal.

Sincerely,

Glenn R. Ashley
Manager, Licensing

GRA/dh

A001

2CAN020403

Page 2

cc: Dr. Bruce S. Mallett
Regional Administrator
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

NRC Senior Resident Inspector
Arkansas Nuclear One
P.O. Box 310
London, AR 72847

U. S. Nuclear Regulatory Commission
Attn: Mr. Tom Alexion
Mail Stop 0-7 D1
Washington, DC 20555-0001