

CONTAINMENT SYSTEMS

3/4.6.5 VACUUM RELIEF VALVES

LIMITING CONDITION FOR OPERATION

3.6.5 Two vacuum relief lines shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

With one vacuum relief line inoperable, restore the vacuum relief line to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.6.5 Verify each vacuum relief line OPERABLE in accordance with the Inservice Testing Program.