WET PIPE SPRINKLER SYSTEM FOR FLAMMABLE LIQUIDS DISPENSING ROOM

WET PIPE SPRINKLER SYSTEM LUBE OIL TRANSFER PUMP P87 & LUBE OIL STORAGE TANK

WET PIPE SPRINKLER SYSTEM OPS OFFICE EL 44'-0" TURB BLDG

TURBINE OIL RESERVOIR & PURIFICATION UNIT #2

TURBINE OIL RESERVOIR & PURIFICATION UNIT #1

WET PIPE SPRINKLER SYSTEM TURB. BLDG. CONDENSER NORTH

WET PIPE SPRINKLER SYS. TURB. BLDG. CONDENSER SOUTH

HYDROGEN SEAL OIL UNIT & RESERVOIR

WET PIPE SPRINKLER SYSTEM TURB. BLDG.

INTERMEDIATE FLOOR NORTH

WET PIPE SPRINKLER SYSTEM TURBINE BLDG. GROUND FLOOR NORTH

WET PIPE SPRINKLER SYS. TURBINE BLDG. GROUND FLOOR SOUTH

SPRINKLER SYSTEM HEATING BOILER RM.

SPRINKLER SYS. HEATING BOILER DAY TANK ROOMS

TECH. SUPPORT CENTER M-208 SH.4 (F-5)

AUX. TRANSFORMER 1X02

WALL SPRAY

MAIN TRANSFORMER 1X01A

MAIN TRANSFORMER 1X01B

MAIN TRANSFORMER 1X01C

TO OPS SHOP HAMANN JOB 827, DWG. 4

CS-SEE SPEC. PB-536

SOUTH SERVICE BLDG. EL. 26' DISTRIBUTION (REF.) PACE JOB #5196-90 DWG. FP-1

(NOTE: LOCATED ON SSB 1ST FLOOR NEXT TO WEST STAIRWELL EXIT)

FUTURE CZ MAINTENANCE SPRINKLER

(NOTE: LOCATED ON SSB 2ND FLOOR NEXT TO WEST STAIRWELL EXIT)

SOUTH SERVICE BLDG. EL. 40'-0" DISTRIBUTION (REF.) PACE JOB #5196-90 DWG. FP-2

NORTH SERVICE BUILDING

AUX. BLDG.

UNIT NO. 2 CONTAINMENT

UNIT NO. 1 CONTAINMENT

MAIN TRANSFORMER 2X01-C

MAIN TRANSFORMER 2X01-B

MAIN TRANSFORMER 2X01-A

MAIN TRANSFORMER 2X02

SEE NOTE 1

NOTES:

1. PRINT DOES NOT SHOW FACTORY INSTALLED OPERATING PIPING ON DELUGE VALVES AND SPRINKLER SYSTEMS. REFER TO TECH. MANUAL AS REQUIRED.

LEGEND

MAGENTA - IN SCOPE LR

BLACK - NOT IN SCOPE LR

LR-M-208 SH-2
UNIT 2
FIRE PROTECTION WATER
REV. 1 DATE:10-17-03

D043