



In-Service Inspection and Surveillance

Marc Léger

Director, Materials Engineering

Presentation to US Nuclear Regulatory Commission

Washington DC

March 04, 2004



 **AECL**
TECHNOLOGIES INC.



Outline

- **Focus on reactor coolant pressure boundary**
- **Range of application of ASME Section XI requirements**
- **Components requiring alternative approach**
- **Fuel Channel Inspections**
- **Compliance with applicable GDCs**



Application of ASME Section XI

- **All Class 1 boundary components outside reactor core and feeder pipes covered by Section XI**
 - **Scope per Section XI IWB-1000**
 - **Intervals per IWB-2000**



Application of ASME Section XI

- **Two areas where risk informed approach to Section XI is used**
 - **Reactor Coolant System Feeder Pipes**
 - **Fuel Channels**
- **Both cases take into account the CANDU specific materials and design**



Feeder Pipes

- **Design**
 - 568 feeder tubes, 2.5”-3.5” diameters, a number of welded joints on each
 - Physical clearance for inspection meets 10CFR50.55a(g)(3)
- **Preservice inspections will be in accordance with conventional ASME Section XI**
- **Section XI ISI would be per IWB-2411**



Proposed ISI of Feeder Tubes

- **AECL proposes an alternative approach using a risk-informed inspection program similar to code case N-577-1**
- **The examination program and supporting data will be included in the application for ACR-700 design certification**



Fuel Channel ISI

- **Fuel channels are designed to rules of NB-3000**
 - **Coolant pressure boundary includes only Zr-2.5%Nb pressure tube, 403 SS end fitting and closure plug**
- **No provision in ASME Section XI for fuel channel ISI**
- **Established program in use on CANDU**
- **The inspection program for ACR fuel channels will be included in the application for design certification**



Proposed ISI Program for Fuel Channels

- **Alternate approach to IWB 2400 that is intended to satisfy 10CFR50.55a(g)(4)**
 - Risk informed program based on prior operating experience in CANDU reactors
 - Reflected in CAN/CSA N285.4 Standard
 - 4th Edition in final editing



Proposed ISI Program for Fuel Channels

- **Program both addresses individual reactor fitness for service and overall surveillance of reactor fleet**
- **Sample of pressure tubes inspected on a periodic basis**
- **Inspection regimen will include tests and measurements that are beyond what would be the minimum requirements under ASME Section III piping**



Pressure Tube Inspection Requirements

- **Volumetric inspection of entire pressure tube**
 - Includes rolled joint region
- **Pressure tube diameter**
- **Pressure tube wall thickness**
- **Garther spring location**



Pressure Tube Inspection Requirements

- **Channel vertical deflection (sag)**
- **Pressure tube / calandria tube gap**
- **Channel position on bearings**
- **Hydrogen isotope concentration**
 - By sampling or NDE measurement
- **Fracture toughness and DHC velocity**
 - Requires pressure tube removal for surveillance destructive examination



Basis for Inspection

- **Channel components manufactured to high standards**
 - **Pressure tubes all subject to stringent manufacturing inspection**
 - Tubular geometry ensures good inspection
 - Each a single piece of material with no welds
 - **End fittings are all single forgings of 403 SS**
 - No known degradation mechanisms in coolant environment
 - Not subject to erosion / corrosion or SCC
 - **Channel closures**
 - No welds in pressure boundary
 - No identified degradation mechanisms



Basis for Inspection

- **Inspection is directed at detecting generic degradation**
 - Degradation that would occur in a large fraction of tubes
- **Provides assurance that pressure tubes are operating as-designed**
- **Any unexpected degradation would require increasing inspection scope**



Basis for Inspection

- **Rolled joints are mechanical seals**
 - Dimensionally checked and leak tested following assembly
 - Degradation would lead to leakage that would be detectable by the annulus gas leak detection system
 - Performance of rolled joints in CANDU plants to date has been outstanding



Surveillance Requirements

- **Measure fracture toughness and DHC velocity in removed pressure tube**
 - Applied to lead unit
- **Lead unit concept is primarily based upon irradiation effects on the pressure tube material**
 - Irradiation conditions would be very similar in every unit
 - Expect that ACR pressure tube material manufactured to the same specification by the same manufacturers would respond to irradiation in a similar way
 - Hydrogen ingress into pressure tubes (that depends somewhat on coolant chemistry conditions) is subject to inspection program for every unit



Inspection Qualification

- **AFCIS example**
 - Performance requirements defined with input from standards, internal and customer requirements
 - 35 requirements defined
 - Test program witnessed by customers and regulators



Inspection Qualification

- **Gap Measurement**
 - Requirement to measure pressure tube to calandria tube gap within +/- 1 mm of a known value
 - Demonstrated in full-scale fuel channel mock-up in which gap could be varied over the total possible range
 - AFCIS measurements compared with independently measured gap
 - Shown to be within +/- 0.4 mm



Acceptance Criteria

- **Gap measurement**
 - **CAN/CSA N285.4 Clause 12.7.2.3 requires no contact within next operating interval**
 - **Demonstrated uncertainty of gap measurement would be factored into calculation of gap at the end of the next operating interval**
 - **In any case in which gap closure was predicted, additional measures would be required to demonstrate acceptability, e.g.**
 - **Shorter interval**
 - **Further inspection**
 - **Remedial measures**



Summary

- **RCS components will follow inspection rules of ASME Section III and Section XI in accordance with 10CFR50.55a**
- **For components with CANDU specific design or materials (fuel channels and feeder pipes), inspection requirements will be established which address 10CFR50.55a(g) and risk informed practice will be proposed**
- **GDC 14 inspection objective - “so as to have an extremely low probability of abnormal leakage, of rapidly propagating failure, and of gross rupture” - will be met by the ACR inspection programs**



 **AECL**
TECHNOLOGIES INC.