

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|--|---|-----------------|
| E. Two CREVS trains inoperable during movement of irradiated fuel assemblies. | E.1 Suspend movement of irradiated fuel assemblies. | Immediately |
| F. Two CREVS trains inoperable during MODE 1, 2, 3, or 4 for reasons other than Condition B. | F.1 Enter LCO 3.0.3. | Immediately |

SURVEILLANCE REQUIREMENTS

| SURVEILLANCE | | FREQUENCY |
|--------------|--|-----------------------------|
| SR 3.7.9.1 | Operate each CREVS train for ≥ 15 minutes. | 31 days |
| SR 3.7.9.2 | Perform required CREVS filter testing in accordance with the Ventilation Filter Testing Program (VFTP). | In accordance with the VFTP |
| SR 3.7.9.3 | Verify the CREVS automatically isolates the Control Room and switches into a recirculation mode of operation on an actual or simulated actuation signal. | 18 months |
| SR 3.7.9.4 | Verify VSF-9 makeup flow rate is ≥ 300 and ≤ 366 cfm when supplying the control room with outside air. | 18 months |
| SR 3.7.9.5 | Verify 2VSF-9 makeup flow rate is ≥ 418.5 and ≤ 511.5 cfm when supplying the control room with outside air. | 18 months |