## ASME Responses to Proposed USNRC Rule Making

### As it affects the ASME Boiler and Pressure Vessel Code, Section III, Division 1 Subsection NB-3600, Subsection NC-3600 and

Subsection ND-3600 Piping Design Rules

February 23, 2004

## ASME Responses to Proposed USNRC Rule Making

Introduction

February 23, 2004

- Proposed USNRC Rulemaking:
  - Allowable Bending Stresses[(NC-3653.2(d) and ND-3653.2(d)]
  - Allowable B<sub>2</sub>' Stress Indices for Tees and Elbows [(NB-3656(b)(3), NC-3655(b)(3), and ND-3655(b)(4)]
  - Evaluation of Anchor Motions [NB-3656(b)(4),
     NC-3655-(b)(4), and ND-3655(b)(4)]

- Proposed USNRC Rulemaking (cont..)
  - Linear Elastic Response Spectrum Analysis
     [(NB-3056(b)(3), NC-3655(b)(3), and ND-3655(b)(3)]
  - Reflected Waves caused by Flow Transients [NB/NC/NB-3622]
  - Removal of Inelastic Analysis for Evaluating Reversing Dynamic Loads (NB-3228.6)

- Subject of this Presentation:
  - Strain Rate and Dynamic Strain Aging Dr. Hiroe Kobayashi
  - 2/3 vs 3/4 B<sub>2</sub>' John Minichiello
  - Level B & Level D SAM John Minichiello & Tim Adams
  - Control by the OBE Tim Adams
  - Conclusion Don Landers

Comparison of Current Code and Proposed USNRC Rule Making								
NC/ND Section	Current Code	USNRC Rule Changes						
NC/ND-3653.1	$B_1 \frac{P \max Do}{2t_N} + B_2 \left(\frac{M_A + M_B}{Z}\right) < 1.8S_h$	$B_{1} \frac{P \max Do}{2t_{N}} + B_{2} \left(\frac{M_{A} + M_{B}}{Z}\right) < 1.8S_{h} \text{ and}$ $B_{1} \frac{P \max Do}{2t_{N}} + B_{2}' \left(\frac{M_{E}'}{Z}\right) < 1.8S_{h} \qquad (1)$						
NC/ND-3653.2 (a)	$\frac{iM_c}{Z} < S_A$	$\frac{iM_c'}{Z} < S_A$						
NC/ND-3653.2 (d)	$\frac{iM_R}{Z} < 2.0S_A $ (5)	Disallowed						
NC/ND-3655.b (3)	$B_1 \frac{P_D D_O}{2t} + B_2' \frac{M_E}{Z} \le 3.0 S_M$	$B_1 \frac{P_D D_O}{2t} + B_2' \frac{M_E}{Z} \le 3.0 S_M$						
NC/ND-3655.b (4)	$C_2 \frac{M_{SAM}}{Z} < 6.0 S_M$	$C_2 \frac{M_{SAM}}{Z} < 6.0 S_M  \text{or } C_2 \frac{M_{SAM}}{Z} < 3.0 S_M  (4)$						

February 23, 2004

## ASME Responses to Proposed USNRC Rule Making

### Strain Rate Evaluation and Occurrence of Dynamic Strain Aging

### STRAIN RATE EVALUATION of TEST#37 & JAPANESE COMPONENT TESTS and OCCUERENCE of DYNAMIC STRAIN AGING

Feb. 23, 2004 at NRC Public Meeting

Japanese Seismic Team Hiro Kobayashi

February 23, 2004

One of NRC's Concerns on Revised ASME Seismic stress Criteria (Input from Dr. Wilkowski, NUREG/CR-5361,III-F-3)

Dynamic Strain Aging in carbon steel (Ratio of Yield-to-Ultimate strength raise to 0.77) at LWR operating Temp. (300-700F) at High Strain Rate (1-10/sec.)



Strain Rate Evaluation by Elasto-Plastic FEM Analysis Estimation of Yield-to-Ultimate strength Ratio for Carbon Steel Dr. Wilkowski pointed out in the page III-F-3 of NUREG /CR-5361 that:

.....Low carbon steels at 300-600F. These materials experience dynamic strain aging, also known as blue embrittlement. This causes changes in the ultimate strength, strain hardening and toughness of the material as a function of temperature and strain rate......At higher strain rates and LWR temperatures, all of the ferritic steels tested to date in the IPIRG-I & II have had slightly higher yield strengths but much lower ultimate strengths. Typically, the ultimate strengths of ferritic base metal **at 1 /sec to 10 /sec** strain rate are lower by about 15-30 percent than at quasi-static rates. Thus, the yield-to-ultimate strengths can change from 0.45 at quasi-static rate to **0.77 at the 1 to 10 sec**<sup>-1</sup> strain rate......

### ANALYSIS CONDITION FOR STRAIN RATE EVALUATION

CASE1: Test#37, RUN5

### CASE2: JAPANESE COMPONENT TEST MODEL (BEND PIPE, TEE)

### **ANALYSIS MODEL for TEST#37, RUN5**



12

**ANALYSIS RESULTS TEST#37, RUN5** 



Average strain rate: 0.32/sec. (=0.04/0.125 for 4Hz)

..0.11/sec. (=0.04/0.357 for 1.4Hz; Natural Freq.)

.....Not 2/sec (=Peak strain rate estimated by NRC for 4Hz)

February 23, 2004

#### JAPANESE COMPONENT TEST MODEL

In-plane Bending Test for Pipe Bends





[Cyclic Test]

[Dynamic Test]

February 23, 2004

#### In-plane Bending Test for Tee



Cyclic Test

**Vibration Test** 

February 23, 2004

#### **Test Summary & Calculated Strain Rate**

	Test Condition				Static Cyclic Test				Dynamic Test (Shaking Table)						
Туре	OD	t	Mat.	Int. P <sup>*1</sup> (MPa)	Exp No.	Load Displ. (mm)	Mud (kNm)	Mcode 3 (kNm)	Strain Range <sup>•₄</sup> ε(%)	Exp. No.	Res- ponse Displ. (mm)	Mud 2 (kNm)	Mcode 3 (kNm)	Res- ponse Freq. f (Hz)	Average Strain Rate <sup>*5</sup> ε/(1/2f) (1/s)
Bend	4B	S40	C/S	13.7	1	±33	32.9	12.1	4.84	1	±33	31.8	12.1	4.7	0.45
Bend	4B	S40	S/S	15.0	2	±33	34.3	13.3	3.53	2	±33	45.2	13.3	4.7	0.33
Тее	4B/4B	S40	C/S	13.7	12	±50	26.0	12.7	3.4	11	±50	24.2	12.7	3.5	0.24

.

\*1 : Sm equivalent (Hoop Stress)

\*2 : Mud was calculated from the experimentally measured moment.

\*3 : Calculated Code allowable moment by using nominal diameter, thickness and Code Sm value.

\*4 : Calculated max. strain range at crack penetration point by FEM which methodology was verified by the comparison with experiment.

\*5:



February 23, 2004

Seismic Capacity margin Rcp=Fs Fnl Fred	
Fs : Strength Factor of component	
Fs = Mud / Mcode (should be greater than 1.5)	
Fred : Redundancy Factor	
Fnl : Additional factor due to Nonlinear dynamic behavior	
Dropoptod 2 22 04	

### ANALYSIS MODEL for JAPANESE MODELS

□ In-plane Bending Model for Bend



[Test Model]

[Analysis Model]

February 23, 2004

Comparison between Failure Location and Max. Strain Location Obtained from the Analysis





Hoop Strain Distribution correspond to fictitious stress at Mud (10Sm)



□ Hoop Strain Distribution correspond to fictitious stress of 6.5Sm



□ Hoop Strain Distribution correspond to fictitious stress of 4.5Sm



#### STRAIN RATE EVALUATION (CS, BEND)

At 6.5Sm Strain range = 1.3 + 1.0 = 2.3%(0.023)Strain rate =  $0.023 \times \frac{1}{0.125} = 0.18$ /sec. at 4Hz

At 4.5SmStrain range = 
$$0.8 + 0.6 = 1.4\%(0.014)$$
Strain rate =  $0.014 \times \frac{1}{0.125} = 0.11/\text{sec.}$  at 4HzFebruary 23, 2004Presented 2-23-04

23

#### STRAIN RATE EVALUATION AT Mud

Carbon Steel Bent at Mud(Fs=3.1, fn=4.7Hz) Strain range = 4.84%(0.048)1 Strain rate =  $0.048 \times \frac{1}{0.106} = 0.45$ /sec.

Stainless Steel BENT at Mud (Fs=3.4, fn=4.7Hz) Strain range = 3.53%(0.035)Strain rate =  $0.035 \times \frac{1}{0.106} = 0.33$ /sec.

Carbon Steel Tee at Mud (Fs=1.9, fn=3.5Hz) Strain range = 3.4%(0.034)1 Strain rate =  $0.034 \times \frac{1}{0.143} = 0.24$ /sec.

February 23, 2004

#### **Test Summary & Calculated Strain Rate**

Test Condition			on		Static Cyclic Test				Dynamic Test (Shaking Table)						
Туре	OD	t	Mat.	Int. P <sup>•1</sup> (MPa)	Exp No.	Load Displ. (mm)	Mud 2 (kNm)	Mcode 3 (kNm)	Strain Range⁺⁴ ε(%)	Exp. No.	Res- ponse Displ. (mm)	Mud ⁺2 (kNm)	Mcode •3 (kNm)	Res- ponse Freq. f (Hz)	Average Strain Rate <sup>•5</sup> ε/(1/2f) (1/s)
Bend	4B	S40	C/S	13.7	1	±33	32.9	12.1	4.84	1	±33	31.8	12.1	4.7	0.45
Bend	4B	S40	S/S	15.0	2	±33	34.3	13.3	3.53	2	±33	45.2	13.3	4.7	0.33
Тее	4B/4B	S40	C/S	13.7	12	±50	26.0	12.7	3.4	11	±50	24.2	12.7	3.5	0.24

\*1 : Sm equivalent (Hoop Stress)

\*2 : Mud was calculated from the experimentally measured moment.

\*3 : Calculated Code allowable moment by using nominal diameter, thickness and Code Sm value.

\*4 : Calculated max. strain range at crack penetration point by FEM which methodology was verified by the comparison with experiment.

•5 :



February 23, 2004

Seismic Capacity margin Rcp=Fs FnI Fred

Fs : Strength Factor of component

Fs = Mud / Mcode (should be greater than 1.5)

Fred : Redundancy Factor

Fnl : Additional factor due to Nonlinear dynamic behavior

**Stress Ratio Change (Japanese STS410)** 



From CRIEPI Report T92044 (1993), "Evaluation of Dynamic Fracture Strength of Dynamic Flawed Carbon Steel Piping under High Temperature"



STS410 Carbon Steel□Japanese Material)

Model		JST	Bend	Test #37		
Freq.		4Hz 4.7Hz		1.7Hz	4Hz	
Response L	.evel	6.5Sm	Fs G.T 1.5	Run5	Run5	
Strain Rate		0.18	0.45(Max)	0.11	0.32	
Stress Datio	RT	0.70	0.71	0.69	0.70	
Stress Ratio	300C	0.66	0.70	0.64	0.68	

Stress Ratio=0.2% Offset Yield Strength/ Ultimate Tensile Strength

February 23, 2004



February 23, 2004

Presented 2-23-04

29

#### **Stress Ratio Change (A106 Grade B)**





31





33

÷

Tensile Property at 288C(550F) vs. Strain Rate for Submerged arc weld DP2-F29W (A106 Gr.B)



Presented 2-23-04

From NUREG/CR6226

Dr. Wilkowski pointed out in the page III-F-3 of NUREG /CR-5361 that:

.....Low carbon steels at 300-600F. These materials experience dynamic strain aging, also known as blue embrittlement. This causes changes in the ultimate strength, strain hardening and toughness of the material as a function of temperature and strain rate.....At higher strain rates and LWR temperatures, all of the ferritic steels tested to date in the IPIRG-I & II have had slightly higher yield. strengths but much lower ultimate strengths. Typically, the ultimate strengths of ferritic base metal at 1 /sec to 10 /sec strain rate are lower by about 15-30 percent than at quasi-static rates. Thus, the yield-to-ultimate strengths can change from 0.45at quasi-static rate to 0.77 at the 1 to 10 sec<sup>-1</sup> strain rate......

1) The evaluated strain rates of piping components such as elbow and tee tested both in USA (Test#37) and in Japan at Mud condition with sufficient margin is much lower than 1/sec that is the lowest limit of dynamic strain aging by Dr. Wilkowski.

2) Dynamic strain aging never occur in piping components in operating NPP of LWR temperature and at seismic event.

3) Dynamic strain aging issue does not disturb to set 3.0Sm and B2'=2/3B2 as the allowable primary stress intensity limit for seismic evaluation of nuclear piping systems.

### PEAK VS. AVERAGE STRAIN RATE



Combination of peak strain rate and peak strain is too much conservative.

Actually, strain becomes zero at peak strain rate and strain rate becomes zero at peak strain. So, average strain rate is reasonable for the evaluation of dynamic strain aging.

Input on strain rate from Dr. Wilkowski

Subj: RE: 2-00 minutes (w/o attachments)

Date: 3/6/2000 8:28:16 AM Central Standard Time

From: gwilkows@columbus.rr.com (Gery Wilkowski)

To: Minicjc@aol.com

Hence if the strain to maximum load is 5% and a typical piping frequency is 4 Hz, then the period of the first natural frequency (larger amplitude cycles) is 0.25 seconds, and one quarter of the period is 0.0625 seconds. Then the effective seismic strain rate would then be between 0.8/second (0.05/0.0625 seconds) and 0.4/second (effect of factor of 2 on time for multiple cycles). If the strain to reach the Mud (or Muc) limit is less than 5%, then scale these estimated strain rates back linearly. If the frequency is higher or lower, then also adjust the Februation 23c200049ly. Presented 2-23-04

#### Seismic Analysis of Piping Peer Review Group Report

#### Submitted by G. M. Wilkowski and R. J. Olson Battelle-Columbus

Low carbon steels at 300 to 600 F. These materials experience dynamic strain aging, also known as blue embrittlement. This causes changes in the ultimate strength, strain hardening and loughness of the material as a function of temperature and strain rate. For instance, the ANCO tests done on the ferrific components had yield-to-ultimate strengths of approximately 0.58 to 0.68 at room temperature. At higher strain rates and LWR temperatures, all of the ferrific steels tested to date in the NRC's International Piping Integrity Research Group programs (IPIRG-1 and IPIRG-2) have had slightly higher yield strengths, but much lower ultimate strengths. Typically, the ultimate strengths of ferrific base metals at 1 sec<sup>4</sup> to 10 sec<sup>4</sup> strain rates are lower by about 15 to 30 percent than at quasi-static rates. Thus, the yield-to-ultimate strengths can change from 0.45 at quasi-static rates to 0.77 at the 1 to 10 sec<sup>4</sup> strain rates. The change is even more significant for ferrific weld metals. Hence, ferrific steels at LWR temperatures and dynamic loading will have less strain hardening than ferrific steels at room temperature under dynamic loading.

February 23, 2004

#### Seismic Analysis of Piping Peer Review Group Report.

Submitted by G. M. Wilkowski and R. J. Olson Battelle-Columbus

#### CONCLUSIONS

From the various review meetings and written information supplied, we believe that the recent ASME seismic design code rules are in need of further validation before they are deemed acceptable. This statement is based on weaknesses in six technical areas, most of which are related to the EPRI/ANCO component tests that are the basis of the new seismic design rules. Some of these aspects may crode the safety margins that are thought to currently exist.

#### (1) Materials Considerations

The criteria are based on the tests conducted at ANCO on wrought stainless steel and low strength carbon steel pipe and components at room temperature. However, the criteria are said to be applicable to a large variety of materials (P1 to P8) at LWR temperatures. The concern here is that there may be materials where the margins experimentally determined from the limited component tests may not reach the desired levels. Materials with higher yield-to-ultimate strength ratios (i.e., lower strain hardening) or materials that may be less flaw tolerant at operating conditions may have lower margins than determined from the room temperature tests. Some specific materials that are of concern are:

Low carbon steels at 300 to 600 F. These materials experience dynamic strain aging, also known as blue embrittlement. This causes changes in the ultimate strength, strain hardening and loughness of the material as a function of temperature and strain rate. For instance, the ANCO tests done on the ferritic components had yield-to-ultimate strengths of approximately 0.58 to 0.68 at room temperature. At higher strain rates and LWR temperatures, all of the ferritic steels tested to date in the NRC's International Piping Integrity Research Group programs (IPIRG-1 and IPIRG-2) have had slightly higher yield strengths, but much lower ultimate strengths. Typically, the ultimate strengths of ferritic base metals at 1 sec' to 10 sec' strain rates are lower by about 15 to 30 percent than at quasi-static rates. Thus, the yield-to-ultimate strengths can change from 0.45 at quasistatic rates to 0.77 at the 1 to 10 sec' strain rates. The change is even more significant for ferritic weld metals. Hence, ferritic steels at LWR temperatures and dynamic loading will have less strain hardening than ferritic steels at room temperature under dynamic loading.

 Other higher strength materials that have been used in ASME-designed nuclear power plants. Some additional examples are:

- A 106 Grade C.
- cast stainless steel that has experienced thermal aging, and may be low in toughness at reactor start-up temperatures (i.e., 300 F), and
- low alloy steel (i.e., A508) used in forgings for nozzles (i.e., surge line nozzles into cold leg piping) or nice in Gyman. Swiss, future Japanese PWR's, and perhaps the future Europeun Pressured Water Reactor (EPR). SH39

February 23, 2004

## ASME Responses to Proposed USNRC Rule Making

### Background Discussion on B<sub>2</sub>'

February 23, 2004

# Background Discussion on $B_2$ '

- Correct Equations:
  - $B_2' = 0.87/h2/3$  for curved pipe and butt-welding elbows...
  - $B_{2b}$ ' = 0.27(Rm/Tt)2/3 and
  - $B_{2r}$ ' = 0.33(Rm/Tr)2/3 for ANSI B16.9 or MSS-SP-87 butt-welding tees
- ND-3655(b)(3) correct; errata issued for NB/NC
- Basis was work by Dr. Kennedy

## Background Discussion on B<sub>2</sub>'

- Dr. Kennedy discussion:
  - $F_s F_{nl} F_{red} \sim 2.0$
  - $F_{nl}F_{red}$  >1.33 for reasonable systems
  - Thus, F<sub>s</sub> ~ 1.5
  - Reduction of EPRI and JST tests shows 1.5
    - Use 3S<sub>m</sub> allowable
    - Use B<sub>2</sub>' indices:
      - Elbows, Bends, and tees:  $B_2' = 2/3 B_2$
      - Welds at location of abrupt stiffness changes:  $B_2' = 4/3 B_2$
      - Other fittings where a reduction is unavailable:  $B_2' = B_2$

# Background Discussion on B<sub>2</sub>'

- JST Static "Markl" vs dynamic tests
  - Similar cycles for similar displacement
  - Cantilever tests represent maximum follow-up
  - JST and EPRI tests were cantilever tests
  - Predominant failure fatigue;  $B_2$ ' similar to SIF

# Background Discussion on $B_2'$

- SWG-SR recommended 2/3 factor
  - Compromised to ¾ to address dynamic strain aging temperature effect (DSATE)
  - Received negatives at MC
  - JST data showed (and shows) there was little DSATE at the levels of strain in our tests, even at  $\rm M_{\rm ud}$
  - Reballoted in September 2001 with 2/3 and passed

## ASME Responses to Proposed USNRC Rule Making

### Equation 11a $(2S_a)$

February 23, 2004

## Equation 11a $(2S_a)$

- Code Equation:  $S_R = iM_R/Z \le 2S_a$ 
  - $-M_R = \underline{range}$  of SAM <u>and</u> inertia
  - Similar to Class 1 "primary plus secondary" and fatigue checks
  - No separate primary check, same as Class 1
- Based on typical OBE events and cycles

## Equation 11a $(2S_a)$

- Objectives
  - Keep usage low (Markl's equation with SF)
  - Ensure elastic cycling ( $2S_a \sim 1.5-2Sy$ )
- Similar to New Reactor Criteria:
  - $-iM_c/Z < 3S_h$
  - $-M_{c}$  = range of thermal plus amplitude of SAM, or the range of SAM

$$-2S_a \sim 3S_h$$

## Equation 11a $(2S_a)$

- ASME check includes inertia with SAM, and takes range
- If thermal is equal to S<sub>a</sub> (~1.5S<sub>h</sub>), ASME check is the same stress allowable as that used for new reactors
- Conclusion: ASME check:
  - Consistent with Class 1 check
  - Consistent with new reactor stress level
  - Reasonable stress limit

## ASME Responses to Proposed USNRC Rule Making

### SSE SAM Limit

February 23, 2004

- ASME Equation:  $C_2M_{SAM}/Z \le 6S_m$ -  $M_{SAM}$  = range of SAM moment stresses
- NRC Proposal:
  - Can use ASME, but only if the user
    - "... demonstrated that the global piping response ... does not create significant inelastic strain concentrations"
  - Otherwise, use ASME with 3S<sub>m</sub> limit

- JST inelastic work on elbows at 10.5S<sub>m</sub>
  - Combined inertia and SAM absolutely
  - Maximum strain of 1.2%
  - Actual stress level <  $3S_m$
  - Appears to meet the "...does not create significant inelastic strain concentrations...", however, this would have to be done each time!!

- ASME Limit again similar to SSE SAM limit for new reactors
  - $-SIF = C_2/2$  for dominant fitting (elbow)

$$-C_2M_{SAM}/Z = 2iM_{SAM}/Z \le 6S_m$$

$$-iM_{SAM}/Z \le 3S_m \sim 3S_h$$

- Additional Effect of the 3 S<sub>m</sub> Limit:
- Consider:
  - $-C_2$ =2i for most Components
  - $-S_m$  approximately .72  $S_A$  on Average
- Then:

$$2i\frac{M_{AM}}{Z} \le 3.0(.72S_A)$$
  
or  
$$i\frac{M_{AM}}{Z} < 1.08S_A \text{ or } \approx 1.0S_A$$

### This is Level B Limit on Secondary Stress!

- Prior to 1994 No Limit on Level D SAM's
- Implicit Limit:
  - OBE SAM's 3  $S_m$  to 1.4 SA
  - -OBE = .6SSE
  - SSE SAM's 5 S<sub>m</sub> or 1.6 to 2.3 S<sub>A</sub>
- New Rules Geared Toward Part 52 Plants

   No Explicit OBE Analysis Required
   Only SSE Analysis

- ASME Felt Some SAM Limit Required
- Explicit Limit Added to Level D – No OBE, Only SSE
- Essentially the Same Previous Implicit Limit on SSE Sam's

## ASME Responses to Proposed USNRC Rule Making

### Control Shifted to the OBE (Level B)

February 23, 2004

Comparison Level B to Level D at 500 °F (Inertial Loads)							
	SII	S <sub>M</sub>	1.8 S <sub>П</sub>	3.0 S <sub>M</sub>	$\frac{1.8S_h}{3.0S_M}$		
SA-106B	17.1	18.9	30.8	56.0	.54		
SA-376, Type 304	16.6	17.5	30.0	51.0	.58		
SA-312, Type 304	17.5	17.5	31.5	51.0	61		

•

Comparison Level B to Level D at AMB (70 °F) (Inertial Loads)							
	SII	S <sub>M</sub>	1.8 S <sub>H</sub>	3.0 S <sub>M</sub>	$\frac{1.8S_h}{3.0S_M}$		
SA-106B	17.1	20.	30.8	60	.5		
SA-376, Type 304	20.	20.	36	60	.6		
SA-312, Type 304	20.	20.	36	60	.6		

- Items that will Cause OBE to Control
  - Pressure Stress
  - Deadweight Stress
  - Damping

- Pressure Deadweight Example
  - Cold 4" Sch 40 pipe
  - A106B
  - Design Pressure: 500 psig
  - Deadweight Support at NF Spans
  - Water-filled, not Insulated
  - Straight Pipe  $B_2 = B_2' = 1.0$

$$B_{1} \frac{PDo}{2t} = .5 \frac{(500) * (4.5)}{2 * (.237)} = 2373 \text{ psi}$$

$$M_{W} = \frac{wL^{2}}{8} = \frac{(1.36) * (168)^{2}}{8} = 4800 \text{ in-lbs}$$

$$B_{2} \frac{M_{W}}{Z} = 1.0 \frac{(4800)}{(3.21)} = 1500 \text{ psi}$$

OBE capacity = 1.8 (17100) - [(2373) + (1500)] = 26,900 psiSSE capacity = 3.0 (20000) - [(2373) + (1500)] = 56,127 psi

 $\frac{OBE capacit \ y}{SSE capacit \ y} = \frac{(26900)}{(56127)} = .48 \qquad (<.5)$ 

February 23, 2004

Presented 2-23-04

•

- Ground Motion
  - OBE = 1/2 SSE
  - Reguide 1.60 Spectra
- Reinforced Concrete
   Building
- Structural Damping
  - Reguide 1.61
  - OBE: 4%, SSE 7%
- Equip Damping
  - OBE, SSE: N-411
- OBE/SSE = .6 or >



February 23, 2004

- Ground Motion
  - OBE = 1/2 SSE
  - Reguide 1.60 Spectra
- Reinforced Concrete
   Building
- Structural Damping
  - Reguide 1.61
  - OBE: 4%, SSE 7%
- Equip Damping
  - OBE, SSE: N-411
- OBE/SSE = .6 or >



- Capacity
  - Initial Margins on Capacity
    - OBE/SSE = .5 to .6
  - Pressure, Deadweight Reduce Capacity
    - OBE/SSE = .48 or <
- Demand
  - Damping Causes: OBE/SSE =.6
- Capacity .5 or <, Demand .6 or >

### OBE (Level B) will Control Primary Stress !

February 23, 2004

## ASME Responses to Proposed USNRC Rule Making

Conclusion

February 23, 2004

## Conclusion

- The ASME has Significant Concerns with the following proposed USNRC Rulemaking:
  - Allowable Bending Stresses[(NC-3653.2(d) and ND-3653.2(d)]
  - Allowable B<sub>2</sub>' Stress Indices for Tees and Elbows [(NB-3656(b)(3), NC-3655(b)(3), and ND-3655(b)(4)]
  - Evaluation of Anchor Motions [NB-3656(b)(4),
     NC-3655-(b)(4), and ND-3655(b)(4)]

### Conclusion

- The ASME has Concerns With But Would Not Oppose:
  - Linear Elastic Response Spectrum Analysis
     [(NB-3056(b)(3), NC-3655(b)(3), and ND-3655(b)(3)]
  - Reflected Waves caused by Flow Transients [NB/NC/NB-3622]

### Conclusion

- The ASME Supports the following
   proposed USNRC Rulemaking
  - Removal of Inelastic Analysis for Evaluating Reversing Dynamic Loads (NB-3228.6)

### Table 1 Testing Conditions of Pipe Fracture Experiments

		•
	Experiment 1.2-4	Experiment 1.2-6
Pipe Materials	A106 Gr.B Carbon Steel	A106 Gr.B Carbon Steel
Actual Outside Diameter	168mm (6.60inches)	168mm (6.60inches)
Actual Wall Thickness	14.0mm (0.550inches)	13.0mm (0.501inches)
Crack Length/Pipe Circumference	0.36	0.36
Crack Depth/Pipe Thickness	1.0	1.0
Test Temperature	288°C (550° F)	288°C (550°F)
Load-Line Displacement Rate	0.051 to 0.102mm/sec (0.002 to 0.004in/sec)	12.5mm/sec (0.50in/sec)
4-Point Bending Inner Span	610mm (24inches)	610mm (24inches)
4-Point Bending Outer Span	1524mm (60inches)	1524mm (60inches)
Experimental Moment at Crack Initiation	34.57kN•m (305,930in-lb)	25.31kN · m (340,050in-lb)
Maximum Experimental Moment	42.71kN m (377,965in-lb)	36.94kN·m (327,200in-lb)
Tensile Yield Strength	320MPa (46.4ksi)	320MPa (46.4ksi)
Ultimate Tensile Strength	621MPa (90.0ksi)	621MPa (90.0ksi)

· . 5\*



Moment vs. Rotation Based on Load-Line **Displacement for IPIRG Experiments 1.2-4** and 1.2-6

Fig.1