



Progress Energy

Crystal River Nuclear Plant
Docket No. 50-302
Operating License No. DPR-72

Ref: ITS 5.7.1.2

March 10, 2004
3F0304-01

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

Subject: Crystal River Unit 3 – February 2004 Monthly Operating Report

Dear Sir:

Florida Power Corporation, doing business as Progress Energy Florida, Inc., hereby submits the Crystal River Unit 3 (CR-3) February 2004 Monthly Operating Report in accordance with CR-3 Improved Technical Specification 5.7.1.2.

If you have any questions regarding this submittal, please contact Mr. Sid Powell, Supervisor, Licensing and Regulatory Programs at (352) 563-4883.

Sincerely,

A handwritten signature in black ink, appearing to read 'J. A. Franke', written over a horizontal line.

J. A. Franke
Plant General Manager

JAF/ff

Attachment

xc: Regional Administrator, Region II
Senior Resident Inspector
NRR Project Manager

JE24

**APPENDIX A
OPERATING DATA REPORT**

DOCKET NO. 50-302
UNIT NAME FLCRP-3
DATE March 1, 2004
COMPLETED BY J. E. Lane *JE Lane*
TELEPHONE (352) 795-6486 x3698

REPORTING PERIOD (Month/Year): February 2004

	MONTH	YEAR TO DATE	CUMULATIVE
1 DESIGN ELECTRICAL RATING (MWe-Net)	860		
2 MAXIMUM DEPENDABLE CAPACITY (MWe-Net)	838		
3 NUMBER OF HOURS REACTOR WAS CRITICAL	696.0	1,440.0	167511.2
4 NUMBER OF HOURS THE GENERATOR WAS ON LINE	696.0	1,440.0	165167.6
5 UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	0.0
6 NET ELECTRICAL ENERGY GENERATED (MWH)	600,830	1,242,872	129,091,873

APPENDIX B UNIT SHUTDOWNS

DOCKET NO. 50-302
 UNIT NAME FLCRP-3
 DATE March 1, 2004
 COMPLETED BY J. E. Lane
 TELEPHONE (352) 795-6486 x3698

REPORTING PERIOD: February 2004

No.	Date	Type	Duration (Hours)	Reason (1)	Method of Shutting Down (2)	Cause / Corrective Actions
		F: Forced S: Scheduled				Comments
None						

SUMMARY:

Crystal River Unit 3 operated the entire month without an outage.

(1) Reason:

- A-EQUIPMENT FAILURE (Explain)
- B-MAINTENANCE OR TEST
- C-REFUELING
- D-REGULATORY RESTRICTION
- E-OPERATOR TRAINING / LICENSE EXAMINATION
- F-ADMINISTRATIVE
- G-OPERATIONAL ERROR (Explain)
- H-OTHER (Explain)

(2) Method

- 1-MANUAL
- 2-MANUAL TRIP / SCRAM
- 3-AUTO TRIP / SCRAM
- 4-CONTINUATION
- 5-OTHER (Explain)