



444 South 16th Street Mall
Omaha NE 68102-2247

March 9, 2004
LIC-04-0020

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Reference: Docket No. 50-285

SUBJECT: February 2004 Monthly Operating Report (MOR)

Pursuant to Fort Calhoun Station (FCS) Unit No. 1 Technical Specification 5.9.1.c, Omaha Public Power District (OPPD) submits the attached MOR for February 2004. No commitments are made to the NRC in this letter.

If you have any questions, please contact Mr. Erick Matzke at (402) 533-6855.

Sincerely,

D. J. Bannister
Manager – Fort Calhoun Station

DJB/EPM/epm

Attachment

c: B. S. Mallett, NRC Regional Administrator, Region IV
A. B. Wang, NRC Project Manager
J. G. Kramer, NRC Senior Resident Inspector
INPO Records Center

FE 24

LIC-04-0020

Attachment

OPERATING DATA REPORT

DOCKET NO. 50-285
UNIT NAME Fort Calhoun Station
DATE March 2, 2004
COMPLETED BY E. P. Matzke
TELEPHONE (402) 533-6855

REPORT PERIOD: February 2004

Design Electrical Rating (MWe-Net): 478

Maximum Dependable Capacity (MWe-Net): 478

	<u>MONTH</u>	<u>YR-TO- DATE</u>	<u>CUMULATIVE</u>
Number of Hours Reactor was Critical:	696	1440	216308
Number of Hours Generator was On-line:	696	1440	214965
Unit Reserve Shutdown Hours:	0	0	0
Net Electrical Energy Generated (MWh):	341394	707053	93233156

UNIT SHUTDOWNS

No.	Date (yy/mm/dd)	Type F: Forced S: Scheduled	Duration (Hours)	Reason ¹	Method of Shutting Down Reactor ²	Cause & Corrective Action Comments

(1) Reason:

- A-Equipment Failure (Explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training/License Examination
- F-Administrative
- G-Operational Error (Explain)
- H-Other (Explain)

(2) Method:

- 1-Manual
- 2-Manual Trip/Scram
- 3-Automatic Trip/Scram
- 4-Continuation
- 5-Other (Explain)

OPERATIONS SUMMARY

Fort Calhoun Station operated at a nominal 100 percent power for the month of February 2004.