

UNITED STATES GOVERNMENT

*Memorandum*

TO : Lyall E. Johnson, Chief  
Licensing Branch

FROM : Clifford K. Beck, Chief  
Hazards Evaluation Branch

SUBJECT: CURTISS-WRIGHT CORPORATION

DATE: JUN 21 1960

We have reviewed the Curtiss-Wright application dated June 3, 1960, submitted in response to questions raised in my memoranda to you dated April 22 and May 31.

Applicant now proposes to sample and analyze the contents of chemical cleaning solution tanks each day the tanks are used. The maximum allowable U-235 concentration will be less than 0.5 g/liter. Considering the frequency of testing the solutions, we believe there is adequate protection against criticality accident. Consequently, we recommend approval of the application.

The further information on the Section 70.24 procedures serves to reinforce our previous determination (5/31/60) that these procedures are adequate and should be approved.

B-101