

In phone conversation April 14, I informed Paul Liller, Curtiss-Wright, that there was inadequate information re cooling system to permit evaluation of adequacy for either one megawatt or four megawatt operation. He said their May 1 application for amendment to authorize 4 megawatt operation would give complete description. He would ask that we consider installation and operation of new system at one megawatt pending approval of broader four megawatt request.

C. T. Edwards - 4/14/59

D-144