

JUN 12 1959

A. R. Luedecke  
General Manager

H. L. Price, Director  
Division of Licensing and Regulation

Original signed by

ISSUANCE OF AMENDMENT NO. 3 TO CURTISS-WRIGHT CORPORATION  
FACILITY LICENSE R-36, DOCKET NO. 50-39

SYMBOL: DLR:ERF

I have issued the attached amendment to the Curtiss-Wright facility license which authorizes operation at power levels up to one (1) megawatt on a continuous basis. Also attached is a copy of the related notice submitted to the Federal Register Division.

License R-36 authorized operation of the one-megawatt reactor at Quehanna, Pennsylvania with the provision that operation was limited to a maximum power level of 100 kilowatts pending installation of the forced circulation cooling system. Subsequently Curtiss-Wright was issued an amendment to its license authorizing operation at power levels up to one megawatt for test runs on the primary cooling system.

Recently we were advised that the forced circulation cooling system had been completed, and authorization was requested for continuous operation up to one megawatt. The Division of Inspection reported that the cooling system is installed and operable in substantial conformity with the application as amended. Therefore, issuance of this amendment is in order.

The JCAE and appropriate state officials are being informed of this action.

Enclosures:  
License R-36, Amendment No. 3  
Notice to Federal Register

cc: R. Lowenstein, OGC  
H. Steele

D-154

OFFICE	LRL <i>ERF</i>	LRL <i>HL</i>	<del>OGC</del>	DLR <i>HL</i>		
SURNAME	Fleury/hs	L. Johnson	<del></del>	H L Price		
DATE	6/10/59	6/11/59	<del>6/1/59</del>	6/11/59		

*Office Memorandum* • UNITED STATES GOVERNMENT

TO : A. R. Luedecke  
General Manager

FROM : *RLK* Deputy  
H. L. Price, Director  
Division of Licensing and Regulation

DATE: JUN 12 1959

SUBJECT: ISSUANCE OF AMENDMENT NO. 3 TO CURTISS-WRIGHT CORPORATION  
FACILITY LICENSE R-36, DOCKET NO. 50-39

SYMBOL: DLR:ERF

I have issued the attached amendment to the Curtiss-Wright facility license which authorizes operation at power levels up to one (1) megawatt on a continuous basis. Also attached is a copy of the related notice submitted to the Federal Register Division.

License R-36 authorized operation of the one-megawatt reactor at Quehanna, Pennsylvania with the provision that operation was limited to a maximum power level of 100 kilowatts pending installation of the forced circulation cooling system. Subsequently Curtiss-Wright was issued an amendment to its license authorizing operation at power levels up to one megawatt for test runs on the primary cooling system.

Recently we were advised that the forced circulation cooling system had been completed, and authorization was requested for continuous operation up to one megawatt. The Division of Inspection reported that the cooling system is installed and operable in substantial conformity with the application as amended. Therefore, issuance of this amendment is in order.

The JCAE and appropriate state officials are being informed of this action.

Enclosures:  
License R-36, Amendment No. 3  
Notice to Federal Register