



Tennessee Valley Authority, Post Office Box 2000, Spring City, Tennessee 37381-2000

MAR 19 2004

10 CFR 50.55a

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

Gentlemen:

In the Matter of) Docket No.50-390
Tennessee Valley Authority)

WATTS BAR NUCLEAR PLANT (WBN) UNIT 1 - AMERICAN SOCIETY OF
MECHANICAL ENGINEERS (ASME) INSERVICE INSPECTION (ISI) PROGRAM
REQUEST FOR RELIEF 1-ISI-14 AND 1-ISI-15

The purpose of this letter is to request relief from ASME
Section XI Code required examinations due to limitations which
were identified in the WBN Unit 1 Cycle 5 refueling outage.
These requests for relief are being submitted in accordance with
10 CFR 50.55a(g)(5)(iii).

TVA stated in the ASME Section XI ISI Summary Report for the
Fifth Refueling Cycle dated January 14, 2004, that two requests
for relief were required to be written for components examined
during the inspection and those requests would be submitted
under separate letter. The required examination coverage could
not be achieved due to configuration of the pressurizer nozzle-
to-vessel welds and safety injection system piping welds.

Enclosure 1 provides Request for Relief 1-ISI-14 for the
pressurizer nozzle-to-vessel welds.

Enclosure 2 provides Request for Relief 1-ISI-15 for the safety
injection system piping welds.

A047

U.S. Nuclear Regulatory Commission
Page 2

MAR 19 2004

There are no regulatory commitments being tracked from this letter. If you have any questions concerning these relief requests, please contact me at (423) 365-1824.

Sincerely,



P. L. Pace
Manager, Site Licensing
and Industry Affairs

Enclosures

cc (Enclosures):

NRC Resident Inspector
Watts Bar Nuclear Plant
1260 Nuclear Plant Road
Spring City, Tennessee 37381

Ms. Margaret H. Chernoff, Project Manager
U.S. Nuclear Regulatory Commission
MS 08G9
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852-2738

U.S. Nuclear Regulatory Commission
Region II
Sam Nunn Atlanta Federal Center
61 Forsyth St., SW, Suite 23T85
Atlanta, Georgia 30303

ENCLOSURE 1

WATTS BAR NUCLEAR PLANT (WBN) UNIT 1
AMERICAN SOCIETY OF MECHANICAL ENGINEERS (ASME)
FIRST TEN YEAR INSERVICE INSPECTION INTERVAL

REQUEST FOR RELIEF, 1-ISI-14

ENCLOSURE 1

WATTS BAR NUCLEAR PLANT (WBN) UNIT 1
AMERICAN SOCIETY OF MECHANICAL ENGINEERS (ASME)
FIRST TEN YEAR INSERVICE INSPECTION INTERVAL
REQUEST FOR RELIEF, 1-ISI-14

I. Summary:

This request for relief addresses the pressurizer nozzle full penetration welds. The design configuration of the pressurizer nozzle to vessel welds precludes a 100 percent ultrasonic examination of the required volume for the spray nozzle-to-vessel weld WP-11 and the four safety/relief nozzle-to-vessel welds WP-12, WP-13, WP-14 and WP-15. These physical examination limitations occur when the 1989 Code examination requirements are applied in areas of components constructed and fabricated to early plant physical designs.

An ultrasonic examination was performed on accessible areas to the maximum extent practical, given the physical limitations for welds WP-11, WP-12, WP-13, WP-14 and WP-15 during the Unit 1 Cycle 5 Refueling Outage. The design configuration limits ultrasonic examination to approximately 68 percent for the five welds. It was concluded that performance of an ultrasonic examination of essentially 100 percent of full penetration welds in the pressurizer nozzle to vessel welds, WP-11, WP-12, WP-13, WP-14 and WP-15, would be impractical. The performance of the ultrasonic examination of the subject welds to the maximum extent practical provides reasonable assurance of an acceptable level of quality and safety because the information and data obtained from the volume examined provides sufficient information to judge the overall integrity of the welds. The WBN Code of Record is ASME Section XI, 1989 Edition. Therefore pursuant to 10 CFR 50.55a(g)(5)(iii), it is recommended that relief be granted, for the first inspection interval.

The WBN pressurizer is of the same design as TVA's Sequoyah Nuclear Plant's (SQN) Units 1 and 2 pressurizers. SQN has experienced the similar examination coverage during inservice inspection of these nozzles. NRC approved Sequoyah Nuclear Plant's request for relief 1/2-ISI-09, (Nozzle RCW-15 which is equivalent to WBN's spray nozzle WP-11), in a safety evaluation dated February 9, 2000. SQN's relief requests 1/2-ISI-19, which is the same as WBN's safety/relief nozzles WP-12 through WP 15, was approved by NRC in a safety evaluation dated August 8, 2003.

ENCLOSURE 1

WATTS BAR NUCLEAR PLANT (WBN) UNIT 1
AMERICAN SOCIETY OF MECHANICAL ENGINEERS (ASME)
FIRST TEN YEAR INSERVICE INSPECTION INTERVAL
REQUEST FOR RELIEF, 1-ISI-14

II. Component:

Five Pressurizer Nozzle Welds - Examination Category B-D
Weld Identifiers WP-11, WP-12, WP-13, WP-14, WP-15.

Reference ISI drawing CHM-2570-C-01 (Attachment 1)

III. Code Requirement:

ASME Section XI, 1989 Edition, Table IWB-2500-1, Examination
Category B-D, Item Number B3.110, Pressurizer Nozzle-to-Vessel
Welds.

Examination requirement as defined by Figure IWB-2500-7(b).
(Attachment 2)

IV. Code Requirements From Which Relief Is Requested:

Relief is requested from performing the required volumetric
examination on essentially 100 percent of the full volume of
the pressurizer nozzle-to-vessel welds.

V. Basis for Relief:

The design configuration of the pressurizer precludes an
ultrasonic examination of the required volume for the
following nozzle-to-vessel welds: WP-11, WP-12, WP-13, WP-
14 and WP-15. The design configuration limits ultrasonic
examination to approximately 68 percent of the required
examination volume as calculated in the Examination Reports
(See Attachment 3).

VI. Alternative Examination:

In lieu of the code required 100 percent ultrasonic
examination, an ultrasonic examination was performed on
accessible areas to the maximum extent practical, given the
physical limitations of the pressurizer nozzle-to-vessel
welds. (See Attachment 3 Examination Data Reports).

VII. Justification For The Granting Of Relief:

- 1) The design configuration of the subject nozzle-to-vessel
welds precludes ultrasonic examination of essentially 100
percent of the required examination volume. In order to
examine the welds in accordance with the code

ENCLOSURE 1

WATTS BAR NUCLEAR PLANT (WBN) UNIT 1
AMERICAN SOCIETY OF MECHANICAL ENGINEERS (ASME)
FIRST TEN YEAR INSERVICE INSPECTION INTERVAL
REQUEST FOR RELIEF, 1-ISI-14

requirements, the pressurizer would require extensive design modifications. The physical arrangement of the subject nozzle welds in conjunction with the close curvature of the outside wall surfaces of the nozzle precludes effective ultrasonic examination from the nozzle side.

Scans normal to the weld from the head side were not obstructed allowing complete coverage of the weld from one side. Examination coverage from the one side provides reasonable assurance that no flaws parallel to the weld are present. In addition, approximately 76 percent of the required ultrasonic examination volume for flaws transverse to the weld was performed from the vessel head side. Total combined examination coverage of welds WP-11, WP-12, WP-13, WP-14 and WP-15 is approximately 68 percent of the code required volume.

- 2) Radiographic examination as an alternate volumetric examination method was determined to be impractical due the thickness of the component. Gaining access to the in-side surface of the pressurizer to place radiographic film would require extensive personnel protection due to high radiation and contamination levels. The pressurizer manway would have to be removed, decontamination performed, and specialized scaffolding erected to gain access. The additional code coverage gained by radiography and/or ultrasonic from the inner surface are impractical when weighed against the radiological concerns. WBN has not opened the pressurizer manway since beginning operation and does not have a history of radiological conditions inside the pressurizer. The estimated radiological conditions referenced in SQN's similar request for relief were determined to be the following:

35-40 rad/hour beta (uncorrected)
10-12 rem/hour gamma
1 rad/hour per 100 square centimeters

Maximum stay time to maintain exposure to < 1 rem is approximately 5 minutes. Special clothing, including respiratory protection, would be required for protection from the extremely high contamination levels and from the high beta dose rate. Industrial safety would also be a major concern (heat stress, confined space, and

ENCLOSURE 1

WATTS BAR NUCLEAR PLANT (WBN) UNIT 1
AMERICAN SOCIETY OF MECHANICAL ENGINEERS (ASME)
FIRST TEN YEAR INSERVICE INSPECTION INTERVAL
REQUEST FOR RELIEF, 1-ISI-14

climbing/falling hazards). Estimates are based on actual experience inside primary components such as steam generators.

- 3) Percentage sampling approach of ASME Section XI code, in combination with examinations performed on similar items provides reasonable assurance that significant degradation if present would have been detected.

It is concluded that performing an ultrasonic volumetric examination of essentially 100 percent of full penetration welds in the pressurizer nozzle-to-vessel welds WP-11, WP-12, WP-13, WP-14 and WP-15, would be impractical. In addition, it would be impractical to perform other volumetric examinations which may increase examination coverage. A maximum extent practical ultrasonic examination of the subject welds provides reasonable assurance of an acceptable level of quality and safety. It is concluded that significant degradation, if present, would have been detected during an ultrasonic examination performed to the maximum extent possible, of the subject welds. As a result, reasonable assurance of component structural integrity has been provided.

Therefore pursuant to 10CFR50.55a(g)(5)(iii), it is recommended that relief be granted, for the first inspection interval.

VIII. Implementation Schedule:

This Request for Relief is applicable to WBN's first inspection interval.

ENCLOSURE 1

WATTS BAR NUCLEAR PLANT (WBN) UNIT 1
AMERICAN SOCIETY OF MECHANICAL ENGINEERS (ASME)
FIRST TEN YEAR INSERVICE INSPECTION INTERVAL
REQUEST FOR RELIEF, 1-ISI-14

List of Attachments

- Attachment 1 Weld Location ISI drawing CHM-2570-C-01
- Attachment 2 ASME Section XI, 1989 Edition, Figure IWB-2500-7(b),
Nozzle In Shell or Head
- Attachment 3 Examination Data Reports
WP-11 - Report R0875
WP-12 - Report R0876
WP-13 - Report R0877
WP-14 - Report R0878
WP-15 - Report R0879

ENCLOSURE 1
ATTACHMENT 1

WATTS BAR NUCLEAR PLANT (WBN) UNIT 1
INSERVICE INSPECTION PROGRAM

REQUEST FOR RELIEF, 1-ISI-14

Weld Location ISI Drawing CHM-2570-C-01


REFERENCE DRAWINGS
47W465-3
VENDOR MANUAL WBN-VTM-W120-0550
FIGURES 5-1, 5-3, 5-6, 5-7G, 5-1, 5-7)

MATERIAL SPECIFICATIONS
NOZZLE SAFE ENDS
SURGE 14" SCH. 160 SA-182 OR F-316L
SPRAY 4" SCH. 160 SA-182 OR F-316L
SAFETY 6" SCH. 160 SA-182 OR F-316L
RELIEF 8" SCH. 160 SA-182 OR F-316L
NOZZLE & MANWAY FORGINGS
SA-508 CLASS 2
SHELL BARRELS
SA 533 GR. A CL. 2
UPPER & LOWER HEAD
SA-533 GR. A CL. 2


ASME CG-1 (EQUIVALENT)

REFERENCE DIMENSIONS			
TITLE	SEAM NO.	"A"	"B"
GIRTH WELDS	1		56.44"
	2		193.25"
	3		322.12"
	4		450.87"
	5		588.12"
LONGITUDINAL WELDS	6	+30°	
	7	-29°	
	8	+135°	
	9	+17°	
SURGE NOZ.	10	0°	
SPRAY NOZ.	11	0°	
RELIEF NOZ.	12	+81°	
SAFETY NOZ.	13	+146° 59'	
SAFETY NOZ.	14	-147° 7'	
SAFETY NOZ.	15	-82°	

NOTE:
1 SUPPORT BRACKETS NOT USED



FOR SKIRT SUPPORT & WELD SEE DETAIL A SHEET 4



3	PHB	CLB	SEC	ILH	2-7-80
CHANGE DRAWING FROM A SIZE TO C SIZE, DELETE DIMENSION "C" & MANWAY, ADD MATERIAL SPECIFICATIONS, REV. SKIRT NOTE					
2	PHB	PHB	CLB	FAL	1-24-80
REVISE REFERENCE DRAWINGS & TABLE BLOCK					
REV.	BY	CHECKED	SUBMITTED	APPROVED	DATE
TENNESSEE VALLEY AUTHORITY					
WATTS BAR NUCLEAR PLANT UNIT 1					
PRESSURIZER					
CHARGE REV	DATE: 12-8-80	SCALE: NOT TO SCALE			
APPROVED: JAW	APPROVED: ILH	CHG MAINTAINED: BAW	REV		
ISSUED:	CHM-2570-C-01		03		

E1A1-1


ENCLOSURE 1
ATTACHMENT 2

WATTS BAR NUCLEAR PLANT (WBN) UNIT 1
INSERVICE INSPECTION PROGRAM

REQUEST FOR RELIEF, 1-ISI-14
FIGURE IWB-2500-7(b) NOZZLE IN SHELL OR HEAD

Fig. IWB-2500-7(b)

1989 SECTION XI — DIVISION I



EXAMINATION REGION [Note (1)]

- Shell (or head) adjoining region
- Attachment weld region
- Nozzle cylinder region
- Nozzle inside corner region

EXAMINATION VOLUME [Note (2)]

- C-D-E-F
- B-C-F-G
- A-B-G-H
- M-N-O-P

NOTES:

- (1) Examination regions are identified for the purpose of differentiating the acceptance standards in IWB-3512.
- (2) Examination volumes may be determined either by direct measurements on the component or by measurements based on design drawings.

FIG. IWB-2500-7(b) NOZZLE IN SHELL OR HEAD
(Examination Zones In Flange Type Nozzles Joined by Full Penetration Butt Welds)

ENCLOSURE 1
ATTACHMENT 3

WATTS BAR NUCLEAR PLANT (WBN) UNIT 1
FIRST TEN YEAR INSERVICE INSPECTION INTERVAL
REQUEST FOR RELIEF, 1-ISI-14

EXAMINATION DATA REPORTS

WP-11 - Report R0875
WP-12 - Report R0876
WP-13 - Report R0877
WP-14 - Report R0878
WP-15 - Report R0879

TENNESSEE VALLEY AUTHORITY		EXAMINATION SUMMARY AND RESOLUTION SHEET		REPORT NUMBER: R0875	
PROJECT: WBN UNIT: 1			CYCLE 05	COMPONENT ID: WP-11	
EXAMINATION METHOD			SYSTEM: PZR [ISI DWG NO: CHM-2570-C-01		
MT <input type="checkbox"/>	PT <input type="checkbox"/>	UT <input checked="" type="checkbox"/>	VT <input type="checkbox"/>	CONFIGURATION:	
PROCEDURE: N-UT-19		REV 14	TC: N/A	VHEAD TO VNOZ	
EXAMINER: <i>Kenneth R. Smith</i>		EXAMINER: N/A		EXAMINER: N/A	EXAMINER: N/A
LEVEL: II		LEVEL: N/A		LEVEL: N/A	LEVEL: N/A
<p>Total coverage calculated to be approximately <u>83.25</u> % (2 ANGLE, 2 DIRECTION) <u>68.17% scan 1/20/03</u></p> <p><u>This report contains the ultrasonic examination data associated with weld #WP-11</u></p> <p><u>0.45 and 60 degree, 2.25 Mhz transducers were used.</u></p> <p><u>The configuration resulted in scan limitations, an additional scan was performed looking away from the nozzle to obtain additional coverage, designated scan #9(-). See attached sketch</u></p> <p><u>No reportable indications were detected.</u></p>					
RESOLUTION BY: <i>Kenneth R. Smith</i>		REVIEWED BY: <i>[Signature]</i>		ANI: <i>B. Earmigh</i>	
LEVEL: II DATE: 9-19-03		LEVEL: III DATE: 9/20/03		DATE: 9/25/03	
				Page: 1 OF 8	

**TENNESSEE VALLEY
AUTHORITY**

**DIGITAL ULTRASONIC
CALIBRATION
DATA SHEET**

REPORT NUMBER

RO875

PROJECT WBN UNIT/CYCLE 11 05
PROCEDURE: N-UT-19 REV: 14 TC: N/A

CALIBRATION DATE: 9-18-03
CALIBRATION BLOCK NO. WB-55 TEMP: 78 °F
SIMULATOR BLOCK: Rompas


TRANSDUCER
MANUFACTURER KBA
MODEL: GAMMA S/N J08204SP
SIZE: 1.0" FREQ: 2.25 MHz
SHAPE: Round # ELEMENTS: 1 # CONS: 0
CABLE TYPE RG-174 LENGTH: 6'

THERMOMETER S/N: 522352 DUE DATE: 6-16-04
COUPLANT: Ultragel II BATCH: 00225

ANGLE VERIFICATION
BLOCK TYPE: N/A S/N: N/A
NOMINAL ANGLE: 0° ACTUAL ANGLE 0°

MODE: SHEAR LONG RL

INSTRUMENT
MANUFACTURER: Krautkramer DUE DATE 5-27-04
MODEL NO.: USN-52L S/N: E30217



INSTRUMENT SETTINGS

REFLECTOR			REFERENCE SENSITIVITY	MEMORY NUMBER
SCAN DIRECT.	NTC	SDH		
AXIAL	<input type="checkbox"/>	<input checked="" type="checkbox"/>	26 dB	32
CIRC.	<input type="checkbox"/>	<input type="checkbox"/>	N/A dB	N/A
FREQ:	2.0-8.0 MHz		REJECT: =	0 %
ANGLE:	0 deg		DAMPING:	1000 ohms
DELAY:	0.039 msec		PULSER:	SINGLE *
ZERO:	1.172 msec			
VELOCITY	.2352 msec		PRR/PRF:	HIGH
RANGE:	4.0 inches		TOF:	PEAK
DISP. MODE:	FULL WAV		POWER:	BATTERY

REF. REFLECTOR: Rompas SDH GAIN: 20 dB

CALIBRATION TIMES

AMPLITUDE: 50 % METAL PATH: .728

INITIAL TIME: 22:00 FINAL TIME: 04:20

VERIFICATION TIMES 1) 00:58 2) N/A 3) N/A 4) N/A 5) N/A 6) N/A 7) N/A 8) N/A 9) N/A

*PDI QUALIFIED INSTRUMENT SETTINGS:
VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK

VERTICAL	SIGNAL 1									
	100	90	80	70	60	50	40	30	20	
	50	45	40	35	30	25	20	15	10	
ATTENUATOR	GAIN	SET	-6 dB	-12dB	SET	+12	SET	+6		
	AMP	80%	32 TO 48	16 TO 24	20%	64 TO 96	40%	64 TO 96		
			40	20		80		80		

COMMENTS: _____ WELD / ITEMS EXAMINED
WP-11
NRI


EXAMINER: Kenneth R. Smith LVL: II
EXAMINER: N/A LVL: N/A
REVIEWER: [Signature] LVL: II DATE: 9/20/03

ANII: B. Eernigh
DATE: 9/25/03
PAGE 2 OF 8

TENNESSEE VALLEY AUTHORITY	DIGITAL ULTRASONIC CALIBRATION DATA SHEET	REPORT NUMBER <u> R0875 </u>
---------------------------------------	--	--

PROJECT WBN UNIT/CYCLE 11 05
 PROCEDURE: N-UT-19 REV: 14 TC: N/A
 TRANSDUCER
 MANUFACTURER KBA
 MODEL: GAMMA S/N J15203
 SIZE: 0.5x1.0" FREQ: 2.25 MHz
 SHAPE: Rectangle # ELEMENTS: # CONS: 0
 CABLE TYPE RG-174 LENGTH: 6'
 MODE: SHEAR LONG RL

CALIBRATION DATE: 9-18-03
 CALIBRATION BLOCK NO. WB-55 TEMP: 78°F
 SIMULATOR BLOCK: Rompas
 THERMOMETER S/N: 522352 DUE DATE: 6-16-04
 COUPLANT: Ultragel II BATCH: 00225
 ANGLE VERIFICATION
 BLOCK TYPE: Rompas S/N: 791413
 NOMINAL ANGLE: 45° ACTUAL ANGLE 45°
 INSTRUMENT
 MANUFACTURER: Krautkramer DUE DATE 5-27-04
 MODEL NO.: USN-52L S/N: E30217



INSTRUMENT SETTINGS

REFLECTOR		REFERENCE SENSITIVITY	MEMORY NUMBER
SCAN DIRECT.	NTC SDH		
AXIAL	<input type="checkbox"/> <input checked="" type="checkbox"/>	34 dB	30
CIRC.	<input type="checkbox"/> <input type="checkbox"/>	N/A dB	N/A
FREQ:	<u>2.0-8.0 MHz</u>	REJECT: <u>0</u> %	
ANGLE:	<u>45 deg</u>	DAMPING: <u>1000</u> ohms	
DELAY:	<u>-0.008 msec</u>	PULSER: <u>SINGLE</u> *	
ZERO:	<u>13.871 msec</u>		
VELOCITY	<u>.1326 msec</u>	PRR/PRF: <u>HIGH</u>	
RANGE:	<u>6.0 inches</u>	TOF: <u>PEAK</u>	
DISP. MODE: <u>FULL WAV</u>		POWER: <u>BATTERY</u>	

REF. REFLECTOR: Rompas SDH GAIN: 38 dB
 AMPLITUDE: 60 % METAL PATH: 1.063
 VERIFICATION TIMES | 1) 01:48 | 2) N/A | 3) N/A | 4) N/A | 5) N/A | 6) N/A | 7) N/A | 8) N/A | 9) N/A

CALIBRATION TIMES

INITIAL TIME: 22:20 FINAL TIME: 04:25

*PDI QUALIFIED INSTRUMENT SETTINGS:
 VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2
 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK

VERTICAL	SIGNAL									
	SIGNAL 1	100	90	80	70	60	50	40	30	20
	SIGNAL 2	50	45	40	35	30	25	20	15	10
ATTENUATOR	GAIN	SET	-6 dB	-12dB	SET	+12	SET	+6		
	AMP	80%	32 TO 48	16 TO 24	20%	64 TO 96	40%	64 TO 96		
			40	20		80		80		


COMMENTS: -7db BTWN. 3/4 + 5/4 SDH's WELD / ITEMS EXAMINED: WP-11
LIMITED SCAN, SEE ATTACHED SKETCH
NRI

EXAMINER: <u>Kenneth R. Smith</u> LVL: <u>II</u>	ANI: <u>B. Earnigh</u>
EXAMINER: <u>N/A</u> LVL: <u>N/A</u>	DATE: <u>9/25/03</u>
REVIEWER: <u>[Signature]</u> LVL: <u>III</u> DATE: <u>9/26/03</u>	PAGE <u>3</u> OF <u>8</u>

TENNESSEE VALLEY AUTHORITY	DIGITAL ULTRASONIC CALIBRATION DATA SHEET	REPORT NUMBER <u> R0875 </u>
---------------------------------------	--	--

PROJECT WBN UNIT/CYCLE 11 05
 PROCEDURE: N-UT-19 REV: 14 TC: N/A
 TRANSDUCER
 MANUFACTURER KBA
 MODEL: GAMMA S/N JIS204
 SIZE: 0.5x1.0" FREQ: 2.25 MHz
 SHAPE: Rectangle # ELEMENTS: 1 # CONS: 0
 CABLE TYPE RG-174 LENGTH: 6'
 MODE: SHEAR LONG RL

CALIBRATION DATE: 9-18-03
 CALIBRATION BLOCK NO. WB-55 TEMP: 78°F
 SIMULATOR BLOCK: Rompas
 THERMOMETER S/N: 522352 DUE DATE: 6-16-04
 COUPLANT: Ultragel II BATCH: 00225
 ANGLE VERIFICATION
 BLOCK TYPE: Rompas S/N: 791413
 NOMINAL ANGLE: 60° ACTUAL ANGLE 60°
 INSTRUMENT
 MANUFACTURER: Krautkramer DUE DATE 5-27-04
 MODEL NO.: USN-52L S/N: E30217



INSTRUMENT SETTINGS

REFLECTOR		REFERENCE SENSITIVITY	MEMORY NUMBER
SCAN DIRECT.	NTC SDH		
AXIAL	<input type="checkbox"/> <input checked="" type="checkbox"/>	41 dB	31
CIRC.	<input type="checkbox"/> <input type="checkbox"/>	N/A dB	N/A
FREQ:	<u>2.0-8.0 MHz</u>	REJECT: <u>0</u> %	
ANGLE:	<u>60 deg</u>	DAMPING: <u>1000</u> ohms	
DELAY:	<u>0.00 msec</u>	PULSER: <u>SINGLE</u> *	
ZERO:	<u>16.404 msec</u>		
VELOCITY	<u>.1292 msec</u>	PRR/PRF: <u>HIGH</u>	
RANGE:	<u>8.5 inches</u>	TOF: <u>PEAK</u>	
DISP. MODE: <u>FULL WAV</u>		POWER: <u>BATTERY</u>	

REF. REFLECTOR: Rompas SDH GAIN: 44 dB
 AMPLITUDE: 60 % METAL PATH: 1.532
 VERIFICATION TIMES | 1) 02:48 2) N/A 3) N/A 4) N/A 5) N/A 6) N/A 7) N/A 8) N/A 9) N/A

CALIBRATION TIMES

INITIAL TIME: 22:45 FINAL TIME: 04:15

*PDI QUALIFIED INSTRUMENT SETTINGS:
 VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2
 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK

VERTICAL	SIGNAL									
	SIGNAL 1	100	90	80	70	60	50	40	30	20
	SIGNAL 2	50	45	40	35	30	25	20	15	10
ATTENUATOR	GAIN	SET	-6 dB	-12dB	SET	+12	SET	+6		
	AMP	80%	32 TO 48	16 TO 24	20%	64 TO 96	40%	64 TO 96		
			40	20		80		80		

COMMENTS	WELD / ITEMS EXAMINED
<u>-11 db BTWN 3/4 AND 5/4 SDH</u>	<u>WP-11</u>
<u>LIMITED SCAN, SEE ATTACHED SKETCH</u>	
<u>NRI</u>	

EXAMINER: <u>Kenneth P. Smith</u> LVL: <u>II</u>	ANII: <u>B. Earnigh</u>
EXAMINER: <u>N/A</u> LVL: <u>N/A</u>	DATE: <u>9/25/03</u>
REVIEWER: <u>[Signature]</u> LVL: <u>III</u> DATE: <u>9/20/03</u>	PAGE <u>4</u> OF <u>8</u>


TENNESSEE VALLEY AUTHORITY

MANUAL ULTRASONIC
VESSEL EXAMINATION
DATA SHEET

REPORT NUMBER

RO875

PROJECT WBN UNIT/CYCLE 1/5
SYSTEM: PZR
WELD I.D.: WP-11
CONFIG: Head TO Nozzle



PROCEDURE: N-UT-19 REV: 14 TC: N/A

W₀ REFERENCE: HEAD SIDE
WELD TOE

L₀ REFERENCE: "0" STAMP

SURFACE TEMP.: 76 °F

PYRO. SERIAL NO.: 522352

EXAMINATION DATE 9-19-03
START TIME: 00:58 END TIME: 04:00

ANGLE	SCAN SENSITIVITY
0°	MIN 32 dB
45°	40-46 dB
60°	47-53 dB

RESULTS: (SCAN NUMBER)	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19
INDICATION RECORDED (Y/N)	N/A							N/A	N	N	N	N/A							N/A

IND NO.	MAX AMP	SCAN NO.	ANG.	100% (1/2 MAX)			50%			20%			MAX			20%			50%			100% (1/2 MAX)		
				Mp1	W1	L1	Mp1	W1	L1	Mp1	W1	L1	Mp	W	L	Mp2	W2	L2	Mp2	W2	L2	Mp2	W2	L2
N/A																								


REMARKS/LIMITATIONS NRI

EXAMINER: Kenneth R. Smith LEVEL: II
EXAMINER: N/A LEVEL: N/A
REVIEWED BY: [Signature] LEVEL: III DATE: 9/20/03
AII: B. Earnings DATE: 9/25/03 PAGE 5 OF 20

TVA
Office of Nuclear Power

PROJECT: WBN SYSTEM: PZR
Unit: 1 / CYCLES WELD NO.: WP-11

REPORT NO.:
RO,875



BY: Kenneth R. Smith LEVEL: II DATE: 9-19-03 PAGE 6 OF 2

TVA

Office of Nuclear Power

PROJECT: WBNSYSTEM: Pressurizer

REPORT NO.:

Unit: 1WELD NO.: see below WP-11

R0875

Safety and Relief Coverage Calculation

Reference CHM-2570-C-06

~~WP-12~~ WP-13, WP-14, WP-18 WP-11

$$\text{Total Area} = (3.8 \times 2.5) + [(.9 \times .5)] \cdot 5 = 9.725''$$

$$0, 45 \uparrow, 45 \downarrow, 60 \uparrow, 60 \downarrow = 2.35'' \text{ Limitation}$$

$$= \frac{9.725 - 2.35}{9.725} \times 100 = 75.8\% \text{ Coverage}$$

$$45 \uparrow = [.9 \times .55] \cdot 5 = .2475'' \text{ Limitation}$$

$$\frac{9.725 - .2475}{9.725} \times 100 = 97.5\% \text{ Coverage}$$

$$60 \uparrow = [1.1 \times 1] \cdot 5 = .55'' \text{ Limitation}$$

$$\frac{9.725 - .55}{9.725} \times 100 = 94.3\% \text{ Coverage}$$

$$60 \downarrow = \frac{(1.4 \times 2.1) \cdot 5}{9.725} \times 100 = 15.1\% \text{ Coverage}$$

$$45 \downarrow = \frac{(2.5 \times 2.1) \cdot 5}{9.725} \times 100 = 27\% \text{ Coverage}$$

0 - 75.8

45 - 75.845 - 75.860 - 75.860 - 75.845 \uparrow - 97.545 \downarrow - 15.160 \uparrow - 94.360 \downarrow - 27

$$\frac{612.9}{9} = 68.1\%$$


Bi-directional Coverage

BY: [Signature]LEVEL: JHTDATE: 9/22/73PAGE 2OF 2

TVA
Office of Nuclear Power

PROJECT: WBN SYSTEM: Pressurizer
Unit: 1 WELD NO.: ~~WP-11~~ WP-11

REPORT NO.:
R0875



BY: [Signature] LEVEL: III DATE: 4/23/03 PAGE 8 OF 8

TENNESSEE VALLEY AUTHORITY		EXAMINATION SUMMARY AND RESOLUTION SHEET		REPORT NUMBER: R0876	
PROJECT: WBN UNIT: 1		CYCLE 05		COMPONENT ID: WP-12	
EXAMINATION METHOD			SYSTEM: PZR	ISI DWG NO: CHM-2570-C-01	
MT <input type="checkbox"/>	PT <input type="checkbox"/>	UT <input checked="" type="checkbox"/>	VT <input type="checkbox"/>	CONFIGURATION:	
PROCEDURE: N-UT-19		REV 14	TC: N/A	VHEAD TO NOZZLE	
EXAMINER: <i>Kenneth R. Smith</i>		EXAMINER: N/A		EXAMINER: N/A	
LEVEL: II		LEVEL: N/A		LEVEL: N/A	
<p>Total coverage calculated to be approximately <u>81.5 %</u> (Z ANGLE, Z DIRECTION) <u>68.1% sum 9/23/03</u></p> <p><u>This report contains the ultrasonic examination data associated with weld #WP-12</u></p> <p><u>0.45 and 60 degree .2.25 Mhz transducers were used.</u></p> <p><u>The configuration resulted in scan limitations, an additional scan was performed looking away from the nozzle to obtain additional coverage, designated scan#9(-). See attached sketch</u></p> <p><u>No reportable indications were detected.</u></p>					
RESOLUTION BY: <i>Kenneth R. Smith</i>		REVIEWED BY: <i>Scott Whetstone</i>		ANII: <i>B. Earning</i>	
LEVEL II DATE: 9-19-03		LEVEL: II DATE: 9/23/03		DATE: 9/25/03	
				Page: 1 OF 8	

TENNESSEE VALLEY
AUTHORITY


DIGITAL ULTRASONIC
CALIBRATION
DATA SHEET

REPORT NUMBER

R0876

PROJECT WBN UNIT/CYCLE 11 05
 PROCEDURE: N-UT-19 REV: 14 TC: N/A
 TRANSDUCER
 MANUFACTURER KBA
 MODEL: GAMMA S/N J082043P
 SIZE: 1.0" FREQ: 2.25 MHz
 SHAPE: Round # ELEMENTS: 1 # CONS: 0
 CABLE TYPE RG-174 LENGTH: 6'
 MODE: SHEAR LONG RL

CALIBRATION DATE: 9-18-03
 CALIBRATION BLOCK NO. WB-55 TEMP: 78°F
 SIMULATOR BLOCK: Rompas
 THERMOMETER S/N: 522352 DUE DATE: 6-16-04
 COUPLANT: Ultragel II BATCH: 00225
 ANGLE VERIFICATION
 BLOCK TYPE: N/A S/N: N/A
 NOMINAL ANGLE: 0° ACTUAL ANGLE 0°
 INSTRUMENT
 MANUFACTURER: Krautkramer DUE DATE 5-27-04
 MODEL NO.: USN-52L S/N: E30217



INSTRUMENT SETTINGS

REFLECTOR		REFERENCE SENSITIVITY	MEMORY NUMBER
SCAN DIRECT.	NTC	SDH	
AXIAL		26 dB	32
CIRC.		N/A dB	N/A
FREQ:	2.0-8.0 MHz		REJECT: <u>0</u> %
ANGLE:	0 deg		DAMPING: <u>1000</u> ohms
DELAY:	0.039 msec		PULSER: <u>SINGLE</u> *
ZERO:	1.172 msec		
VELOCITY	.2352 msec		PRR/PRF: <u>HIGH</u>
RANGE:	4.0 inches		TOF: <u>PEAK</u>
DISP. MODE:	FULL WAV		POWER: <u>BATTERY</u>

REF. REFLECTOR: Rompas SDH GAIN: 20 dB
 AMPLITUDE: 50 % METAL PATH: .728
 VERIFICATION TIMES 1) 00:58 2) N/A 3) N/A 4) N/A 5) N/A 6) N/A 7) N/A 8) N/A 9) N/A

CALIBRATION TIMES
 INITIAL TIME: 22:00 FINAL TIME: 04:20

*PDI QUALIFIED INSTRUMENT SETTINGS:
 VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK

VERTICAL	SIGNAL 1									
		100	90	80	70	60	50	40	30	20
ATTENUATOR	SIGNAL 2									
		50	45	40	35	30	25	20	15	10
	GAIN	SET	-6 dB	-12 dB	SET	+12	SET	+6		
	AMP	80%	32 TO 48	16 TO 24	20%	64 TO 96	40%	64 TO 96		
			40	20		80		80		

COMMENTS: _____ WELD / ITEMS EXAMINED
WP-12
NRI

EXAMINER: Kenneth R. Smith LVL: II ANII: B. Earnigh
 EXAMINER: N/A LVL: N/A DATE: 9/25/03
 REVIEWER: [Signature] LVL: II DATE: 9/20/03 PAGE 2 OF 9

TENNESSEE VALLEY
AUTHORITY


DIGITAL ULTRASONIC
CALIBRATION
DATA SHEET

REPORT NUMBER

R0876

PROJECT WBN UNIT/CYCLE 11 05
 PROCEDURE: N-UT-19 REV: 14 TC: N/A
 TRANSDUCER
 MANUFACTURER KBA
 MODEL: GAMMA S/N J15203
 SIZE: 0.5x1.0" FREQ: 2.25 MHz
 SHAPE: Rectangle # ELEMENTS: 1 # CONS: 0
 CABLE TYPE RG-174 LENGTH: 6'
 MODE: SHEAR LONG RL

CALIBRATION DATE: 9-18-03
 CALIBRATION BLOCK NO. WB-55 TEMP: 78°F
 SIMULATOR BLOCK: Rompas
 THERMOMETER S/N: 522352 DUE DATE: 6-16-04
 COUPLANT: Ultragel II BATCH: 00225
 ANGLE VERIFICATION
 BLOCK TYPE: Rompas S/N: 791413
 NOMINAL ANGLE: 45° ACTUAL ANGLE 45°
 INSTRUMENT
 MANUFACTURER: Krautkramer DUE DATE 5-27-04
 MODEL NO.: USN-52L S/N: E30217



INSTRUMENT SETTINGS

REFLECTOR			REFERENCE SENSITIVITY	MEMORY NUMBER
SCAN DIRECT.	NTC	SDH		
AXIAL	<input type="checkbox"/>	<input checked="" type="checkbox"/>	34 dB	30
CIRC.	<input type="checkbox"/>	<input type="checkbox"/>	N/A dB	N/A
FREQ:	<u>2.0-8.0 MHz</u>		REJECT: = <u>0</u> %	
ANGLE:	<u>45 deg</u>		DAMPING: <u>1000</u> ohms	
DELAY:	<u>-0.008 msec</u>		PULSER: <u>SINGLE</u> *	
ZERO:	<u>13.871 msec</u>			
VELOCITY	<u>.1326 msec</u>		PRR/PRF: <u>HIGH</u>	
RANGE:	<u>6.0 inches</u>		TOF: <u>PEAK</u>	
DISP. MODE: <u>FULL WAV</u>			POWER: <u>BATTERY</u>	

REF. REFLECTOR: Rompas SDH GAIN: 38 dB
 AMPLITUDE: 60 % METAL PATH: 1.063
 VERIFICATION TIMES 1) 01:48 2) N/A 3) N/A 4) N/A 5) N/A 6) N/A 7) N/A 8) N/A 9) N/A

CALIBRATION TIMES
 INITIAL TIME: 22:20 FINAL TIME: 04:25

*PDI QUALIFIED INSTRUMENT SETTINGS:
 VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK

VERTICAL	SIGNAL 1										
		100	90	80	70	60	50	40	30	20	
ATTENUATOR	SIGNAL 2										
		50	45	40	35	30	25	20	15	10	
	GAIN	SET	-6 dB	-12dB	SET	+12	SET	+6			
	AMP	80%	32 TO 48	16 TO 24	20%	64 TO 96	40%	64 TO 96			
			40	20		80		80			

COMMENTS: -7 db DIFF. BTWN. 3/4 AND 5/4 SDH WELD/ITEMS EXAMINED WP-12
LIMITED SCAN, SEE ATTACHED SKETCH
NRT

EXAMINER: Kenneth R. Smith LVL: II ANII: B. Carrigh
 EXAMINER: N/A LVL: N/A DATE: 9/25/03
 REVIEWER: [Signature] LVL: III DATE: 9/24/03 PAGE 3 OF 8

TENNESSEE VALLEY
AUTHORITY

DIGITAL ULTRASONIC
CALIBRATION
DATA SHEET

REPORT NUMBER

R0276

PROJECT WBN UNIT/CYCLE 11 05
PROCEDURE: N-UT-19 REV: 14 TC: N/A

CALIBRATION DATE: 9-18-03
CALIBRATION BLOCK NO. WB-55 TEMP: 78°F
SIMULATOR BLOCK: Rompas

TRANSDUCER
MANUFACTURER KBA
MODEL: GAMMA S/N J15204
SIZE: 0.5x1.0" FREQ: 2.25 MHz
SHAPE: Rectangle # ELEMENTS: 1 # CONS: 0
CABLE TYPE RG-174 LENGTH: 6'


THERMOMETER S/N: 522352 DUE DATE: 6-16-04
COUPLANT: Ultragel II BATCH: 00225
ANGLE VERIFICATION

BLOCK TYPE: Rompas S/N: 791413
NOMINAL ANGLE: 60° ACTUAL ANGLE 60°

MODE: SHEAR LONG RL

INSTRUMENT
MANUFACTURER: Krautkramer DUE DATE 5-27-04
MODEL NO.: USN-52L S/N: E30217

DAC



A
M
P
L
I
T
U
D
E

REFLECTOR			REFERENCE SENSITIVITY	MEMORY NUMBER
SCAN DIRECT.	NTC	SDH		
AXIAL	<input type="checkbox"/>	<input checked="" type="checkbox"/>	41 dB	31
CIRC.	<input type="checkbox"/>	<input type="checkbox"/>	N/A dB	N/A
FREQ:	<u>2.0-8.0 MHz</u>		REJECT: = <u>0</u> %	
ANGLE:	<u>60 deg</u>		DAMPING: <u>1000</u> ohms	
DELAY:	<u>0.00 msec</u>		PULSER: <u>SINGLE</u> *	
ZERO:	<u>16.404 msec</u>			
VELOCITY	<u>.1292 msec</u>		PRR/PRF: <u>HIGH</u>	
RANGE:	<u>8.5 inches</u>		TOF: <u>PEAK</u>	
DISP. MODE:	<u>FULL WAV</u>		POWER: <u>BATTERY</u>	

REF. REFLECTOR: Rompas SDH GAIN: 44 dB
AMPLITUDE: 60 % METAL PATH: 1.532
VERIFICATION TIMES 1) 02:48 2) N/A 3) N/A 4) N/A 5) N/A 6) N/A 7) N/A 8) N/A 9) N/A

CALIBRATION TIMES

INITIAL TIME: 22:45 FINAL TIME: 04:15

*PDI QUALIFIED INSTRUMENT SETTINGS:
VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK

VERTICAL	SIGNAL 1										
		100	90	80	70	60	50	40	30	20	
ATTENUATOR	SIGNAL 2										
		50	45	40	35	30	25	20	15	10	
	GAIN	SET	-6 dB		-12dB		SET	+12		SET	+6
	AMP	80%	32 TO 48		16 TO 24		20%	64 TO 96		40%	64 TO 96
			40	20			80			80	

COMMENTS

WELD / ITEMS EXAMINED

-11 db Brown. 3/4 AND 5/4 SDH

WP-12

LIMITED SCAN, SEE ATTACHED SKETCH

NRT

EXAMINER: Kenneth R. Smith LVL: II

ANII: B. Carmigh

EXAMINER: N/A LVL: N/A

DATE: 9/25/03

REVIEWER: [Signature] LVL: III DATE: 9/26/03

PAGE 4 OF 8

TENNESSEE VALLEY AUTHORITY				MANUAL ULTRASONIC VESSEL EXAMINATION DATA SHEET								REPORT NUMBER <i>R0876</i>												
PROJECT <u>WBN</u> UNIT/CYCLE <u>1/5</u>				W _o REFERENCE: <u>HEAD SIDE WELD TOE</u>				EXAMINATION DATE <u>9-19-03</u>																
SYSTEM: <u>PZR</u>				Lo REFERENCE: <u>"0" STAMP</u>				START TIME: <u>00:58</u> END TIME: <u>04:00</u>																
WELD I.D.: <u>WP-12</u>				SURFACE TEMP.: <u>76 °F</u>				ANGLE				SCAN SENSITIVITY												
CONFIG.: <u>TO</u> <u>FLOW</u> →				PYRO. SERIAL NO.: <u>522352</u>				0°				MIN. 32 dB												
PROCEDURE: <u>N-UT-19</u> REV: <u>14</u> TC: <u>N/A</u>								45°				40-46 dB												
								60°				47-53 dB												
RESULTS: (SCAN NUMBER)				1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19		
INDICATION RECORDED (Y/N)				N/A							N/A				N/A							N/A		
IND NO.	MAX AMP	SCAN NO.	ANG.	100% (1/2 MAX)			50%			20%			MAX			20%			50%			100% (1/2 MAX)		
				Mp1	W1	L1	Mp1	W1	L1	Mp1	W1	L1	Mp	W	L	Mp2	W2	L2	Mp2	W2	L2	Mp2	W2	L2
REMARKS/LIMITATIONS <u>NRI</u>																								
EXAMINER: <u>Kenneth P. Smith</u> LEVEL: <u>II</u>																								
EXAMINER: <u>N/A</u> LEVEL: <u>N/A</u>																								
REVIEWED BY: <u>[Signature]</u>										ANII: <u>B. Fanning</u>														
LEVEL: <u>[Signature]</u> DATE: <u>9/2/03</u>										DATE: <u>9/25/03</u> PAGE <u>5</u> OF <u>8</u>														

TVA

Office of Nuclear Power

PROJECT: WBN


SYSTEM: PZR

REPORT NO.:

Unit: 1 / CYCLE 5

WELD NO.: WP-12

R0876



DRWG. TO SCALE

BY: Kenneth R. Smith

LEVEL: II

DATE: 9-19-03

PAGE 5 OF 2

TVA
Office of Nuclear Power

PROJECT: WBN SYSTEM: Pressurizer
Unit: 1 WELD NO.: see below

REPORT NO.:
R0876

Safety and Relief Coverage Calculation

Reference CHM-2570-C-06 WP-12, WP-13, WP-14, WP-15

$$\text{Total Area} = (3.8 \times 2.5) + [(.9 \times .5)] \cdot 5 = 9.725''$$

$$0, \frac{45}{\uparrow}, \frac{45}{\downarrow}, \frac{60}{\uparrow}, \frac{60}{\downarrow} = 2.35'' \text{ Limitation}$$
$$= \frac{9.725 - 2.35}{9.725} \times 100 = 75.8\% \text{ Coverage}$$

$$45_{\uparrow} = [.9 \times .55] \cdot 5 = .2475'' \text{ Limitation}$$
$$\frac{9.725 - .2475}{9.725} \times 100 = 97.5\% \text{ Coverage}$$

$$60_{\uparrow} = [1.1 \times 1] \cdot 5 = .55'' \text{ Limitation}$$
$$\frac{9.725 - .55}{9.725} \times 100 = 94.3\% \text{ Coverage}$$

$$60_{\downarrow} = (1.4 \times 2.1) \cdot 5$$
$$\frac{\quad}{9.725} \times 100 = 15.1\% \text{ Coverage}$$

$$45_{\downarrow} = (2.5 \times 2.1) \cdot 5$$
$$\frac{\quad}{9.725} \times 100 = 27\% \text{ Coverage}$$

0 - 75.8

45 - 75.8

45 - 75.8

60 - 75.8

60 - 75.8

45_↑ - 97.5

45_↓ - 15.1

60_↑ - 94.3

60_↓ - 27

$$\frac{612.9}{9} = 68.1\%$$

Bi-directional Coverage

BY: [Signature]

LEVEL: JTT

DATE: 9/22/03

PAGE 2

OF 2

TVA
Office of Nuclear Power

PROJECT: WBN


SYSTEM: Pressurizer

REPORT NO.:

Unit: 1

WELD NO.: WP-12, WP-13, WP-14, WP-15

R0876



SCAN stops taken from TYPICAL SCAN
Field DATA Reference CHM-2570-C-06

BY: [Signature]

LEVEL: III

DATE: 9/23/03


PAGE 8 OF 8

TENNESSEE VALLEY AUTHORITY		EXAMINATION SUMMARY AND RESOLUTION SHEET		REPORT NUMBER: R0877	
PROJECT: WBN UNIT: 1		CYCLE 05		COMPONENT ID: WP-13	
EXAMINATION METHOD				SYSTEM: PZR	ISI DWG NO: CHM-2570-C-01
MT <input type="checkbox"/>	PT <input type="checkbox"/>	UT <input checked="" type="checkbox"/>	VT <input type="checkbox"/>	CONFIGURATION:	CATEGORY
PROCEDURE: N-UT-19		REV 14	TC: N/A	VHEAD TO NOZZLE	B-D
EXAMINER: <i>Kenneth R. Smith</i>		EXAMINER: N/A		EXAMINER: N/A	EXAMINER: N/A
LEVEL: II		LEVEL: N/A		LEVEL: N/A	LEVEL: N/A
<p>Total coverage calculated to be approximately <u>81.5</u> % <u>(2 ANGLE, 2 DIRECTIONS)</u> <u>68.1%</u> <u>300 9/23/03</u></p> <p><u>This report contains the ultrasonic examination data associated with weld #WP-13</u></p> <p><u>0.45 and 60 degree 2.25 Mhz transducers were used.</u></p> <p><u>The configuration resulted in scan limitations, an additional scan was performed looking away from the nozzle to obtain additional coverage, designated scan #9(-). See attached sketch</u></p> <p><u>No reportable indications were detected.</u></p>					
RESOLUTION BY: <i>Kenneth R. Smith</i>		REVIEWED BY: <i>Al Whitaker</i>		ANII: <i>B. Eamigh</i>	
LEVEL: II DATE: 9-19-03		LEVEL: II DATE: 9/23/03		DATE: 9/24/03	
				Page: 1 OF 9	

TENNESSEE VALLEY AUTHORITY	DIGITAL ULTRASONIC CALIBRATION DATA SHEET	REPORT NUMBER <u> R0877 </u>
---------------------------------------	--	--

PROJECT WBN UNIT/CYCLE 11 05
 PROCEDURE: N-UT-19 REV: 14 TC: N/A
 TRANSDUCER
 MANUFACTURER KEA
 MODEL: GAMMA S/N J08204SP
 SIZE: 1.0" FREQ: 2.25 MHz
 SHAPE: Round # ELEMENTS: 1 # CONS: 0
 CABLE TYPE RG-174 LENGTH: 6'
 MODE: SHEAR LONG RL

CALIBRATION DATE: 9-18-03
 CALIBRATION BLOCK NO. WB-55 TEMP: 78°F
 SIMULATOR BLOCK: Rompas
 THERMOMETER S/N: 522352 DUE DATE: 6-16-04
 COUPLANT: Ultragel II BATCH: 00225
 ANGLE VERIFICATION
 BLOCK TYPE: N/A S/N: N/A
 NOMINAL ANGLE: 0° ACTUAL ANGLE 0°
 INSTRUMENT
 MANUFACTURER: Krautkramer DUE DATE 5-27-04
 MODEL NO.: USN-52L S/N: E30217



INSTRUMENT SETTINGS

REFLECTOR		REFERENCE SENSITIVITY	MEMORY NUMBER
SCAN DIRECT.	NTC : SDH		
AXIAL	<input type="checkbox"/> <input checked="" type="checkbox"/>	26 dB	32
CIRC.	<input type="checkbox"/> <input type="checkbox"/>	N/A dB	N/A
FREQ:	<u>2.0-8.0 MHz</u>	REJECT: = <u>0 %</u>	
ANGLE:	<u>0 deg</u>	DAMPING: <u>1000</u> ohms	
DELAY:	<u>0.039 msec</u>	PULSER: <u>SINGLE</u> *	
ZERO:	<u>1.172 msec</u>		
VELOCITY	<u>2352 msec</u>	PRR/PRF: <u>HIGH</u>	
RANGE:	<u>4.0 inches</u>	TOF: <u>PEAK</u>	
DISP. MODE:	<u>FULL WAV</u>	POWER: <u>BATTERY</u>	

REF. REFLECTOR: Rompas SDH GAIN: 20 dB
 AMPLITUDE: 50 % METAL PATH: 0.728
 VERIFICATION TIMES 1) 00:58 2) N/A 3) N/A 4) N/A 5) N/A 6) N/A 7) N/A 8) N/A 9) N/A

CALIBRATION TIMES

INITIAL TIME: 22:00 FINAL TIME: 04:20

*PDI QUALIFIED INSTRUMENT SETTINGS:
 VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2
 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK

VERTICAL	SIGNAL 1									
	100	90	80	70	60	50	40	30	20	
	50	45	40	35	30	25	20	15	10	
ATTENUATOR	GAIN	SET	-6 dB		-12dB		SET	+12	SET	+6
	AMP	80%	32 TO 48		16 TO 24		20%	64 TO 96	40%	64 TO 96
			40	20			80		8-	

COMMENTS WELD / ITEMS EXAMINED

WP-13

NRI

EXAMINER: <u>Kenneth R. Smith</u> LVL.: <u>II</u>	ANII: <u>B. Earnigh</u>
EXAMINER: <u>N/A</u> LVL.: <u>N/A</u>	DATE: <u>9/29/03</u>
REVIEWER: <u>[Signature]</u> LVL.: <u>[Signature]</u> DATE: <u>9/22/03</u>	PAGE <u>2</u> OF <u>8</u>

TENNESSEE VALLEY
AUTHORITY

DIGITAL ULTRASONIC
CALIBRATION
DATA SHEET

REPORT NUMBER

20877

PROJECT WBN UNIT/CYCLE 11/05
PROCEDURE: N-UT-19 REV: 14 TC: N/A

CALIBRATION DATE: 9-18-03
CALIBRATION BLOCK NO. WB-55 TEMP: 78°F
SIMULATOR BLOCK: Rompas

TRANSDUCER
MANUFACTURER KBA
MODEL: GAMMA S/N J15203
SIZE: 0.5x1.0" FREQ: 2.25 MHz
SHAPE: Rectangle # ELEMENTS: 1 # CONS: 0
CABLE TYPE RG-174 LENGTH: 6'

THERMOMETER S/N: 522352 DUE DATE: 6-16-04
COUPLANT: Ultragel II BATCH: 00225
ANGLE VERIFICATION


BLOCK TYPE: Rompas S/N: 791413
NOMINAL ANGLE: 45° ACTUAL ANGLE 45°

MODE: SHEAR LONG RL

INSTRUMENT
MANUFACTURER: Krautkramer DUE DATE 5-27-04
MODEL NO.: USN-52L S/N: E30217

DAC

INSTRUMENT SETTINGS



A
M
P
L
I
T
U
D
E

DISPLAY WIDTH 6.0 inches

REFLECTOR		REFERENCE SENSITIVITY	MEMORY NUMBER
SCAN DIRECT.	NTC	SDH	
AXIAL	<input type="checkbox"/>	<input checked="" type="checkbox"/>	34 dB 30
CIRC.	<input type="checkbox"/>	<input type="checkbox"/>	N/A dB N/A
FREQ:	<u>2.0-8.0 MHz</u>		REJECT: <u>0 %</u>
ANGLE:	<u>45 deg</u>		DAMPING: <u>1000</u> ohms
DELAY:	<u>-0.008 msec</u>		PULSER: <u>SINGLE</u> *
ZERO:	<u>13.871 msec</u>		
VELOCITY:	<u>.1326 msec</u>		PRR/PRF: <u>HIGH</u>
RANGE:	<u>6.0 inches</u>		TOF: <u>PEAK</u>
DISP. MODE:	<u>FULL WAV</u>		POWER: <u>BATTERY</u>

REF. REFLECTOR: Rompas SDH GAIN: 38 dB

CALIBRATION TIMES

AMPLITUDE: 60 % METAL PATH: 1.063

INITIAL TIME: 22:20 FINAL TIME: 04:25

VERIFICATION TIMES 1) 01:48 2) N/A 3) N/A 4) N/A 5) N/A 6) N/A 7) N/A 8) N/A 9) N/A

*PDI QUALIFIED INSTRUMENT SETTINGS:

VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK

VERTICAL	SIGNAL 1	100	90	80	70	60	50	40	30	20
	SIGNAL 2	50	45	40	35	30	25	20	15	10
ATTENUATOR	GAIN SET	-6 dB	-12 dB	SET	+12	SET	+6			
	AMP 80%	32 TO 48	16 TO 24	20%	64 TO 96	40%	64 TO 96			
		40	20		80		80			

COMMENTS

WELD / ITEMS EXAMINED

-7 db BROWN. 3/4 AND 5/4 SOH'S

WP-13

LIMITED SCAN, SEE ATTACHED SKETCH

NRT

EXAMINER: Kenneth R. Smith LVL: II

ANI: B. Earnigh

EXAMINER: N/A LVL: N/A

DATE: 9/24/03

REVIEWER: [Signature] LVL: III DATE: 9/20/03

PAGE 3 OF 8

TENNESSEE VALLEY
AUTHORITY

DIGITAL ULTRASONIC
CALIBRATION
DATA SHEET


REPORT NUMBER

20877

PROJECT WBN UNIT/CYCLE 11 05
 PROCEDURE: N-UT-19 REV: 14 TC: N/A
 TRANSDUCER
 MANUFACTURER KBA
 MODEL: GAMMA S/N J15204
 SIZE: 0.5x1.0" FREQ: 2.25 MHz
 SHAPE: Rectangle # ELEMENTS: 1 # CONS: 0
 CABLE TYPE RG-174 LENGTH: _____
 MODE: SHEAR LONG RL

CALIBRATION DATE: 9-18-03
 CALIBRATION BLOCK NO. WB-55 TEMP: 78°F
 SIMULATOR BLOCK: Rompas
 THERMOMETER S/N: 522352 DUE DATE: 6-16-04
 COUPLANT: Ultragel II BATCH: 00225
 ANGLE VERIFICATION
 BLOCK TYPE: Rompas S/N: 791413
 NOMINAL ANGLE: 60° ACTUAL ANGLE 60°
 INSTRUMENT
 MANUFACTURER: Krautkramer DUE DATE 5-27-04
 MODEL NO.: USN-52L S/N: E30217

DAC



A
M
P
L
I
T
U
D
E

DISPLAY WIDTH 8.5 inches

INSTRUMENT SETTINGS

REFLECTOR		REFERENCE SENSITIVITY	MEMORY NUMBER
SCAN DIRECT.	NTC SDH		
AXIAL	<input type="checkbox"/> <input checked="" type="checkbox"/>	41 dB	31
CIRC.	<input type="checkbox"/> <input type="checkbox"/>	N/A dB	N/A
FREQ:	<u>2.0-8.0 MHz</u>	REJECT: = <u>0</u> %	
ANGLE:	<u>60 deg</u>	DAMPING: <u>1000</u> ohms	
DELAY:	<u>0.00 msec</u>	PULSER: <u>SINGLE</u> *	
ZERO:	<u>16.004 msec</u>		
VELOCITY:	<u>1292 msec</u>	PRR/PRF: <u>HIGH</u>	
RANGE:	<u>8.50 inches</u>	TOF: <u>PEAK</u>	
DISP. MODE:	<u>FULL WAVE</u>	POWER: <u>BATTERY</u>	

REF. REFLECTOR: Rompas SDH GAIN: 44 dB
 AMPLITUDE: 60 % METAL PATH: 1.532
 VERIFICATION TIMES 1) 02:48 2) N/A 3) N/A 4) N/A 5) N/A 6) N/A 7) N/A 8) N/A 9) N/A

CALIBRATION TIMES

INITIAL TIME: 22:45 FINAL TIME: 04:15

*PDI QUALIFIED INSTRUMENT SETTINGS:

VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK

VERTICAL	SIGNAL 1		100	90	80	70	60	50	40	30	20
		SIGNAL 2		50	45	40	35	30	25	20	15
ATTENUATOR	GAIN	SET	-6 dB	-12dB	SET	+12	SET	+6			
	AMP	80%	32 TO 48	16 TO 24	20%	64 TO 96	40%	64 TO 96			
			40	20		80		80			

COMMENTS

WELD / ITEMS EXAMINED

-11 db BTWN. 3/4 AND 5/4 SDH'S WP-13

LIMITED SCAN, SEE ATTACHED SKETCH

NRI

EXAMINER: Kenneth R. Smith LVL: II

ANII: B. Earnigh

EXAMINER: N/A LVL: N/A

DATE: 9/24/03


REVIEWER: [Signature] LVL: III DATE: 9/22/03

PAGE 4 OF 9

TVA
Office of Nuclear Power

PROJECT: WBN SYSTEM: PZR
Unit: 1 / CYCLE 5 WELD NO.: WP-13

REPORT NO.:
R0877



DRWG. TO SCALE

BY: Kenneth R. Smith LEVEL: II DATE: 9-19-03 PAGE 6 OF 2

TVA

Office of Nuclear Power

PROJECT: WBNSYSTEM: Pressurizer

REPORT NO.:

Unit: 1WELD NO.: see below

R0877

Safety and Relief Coverage Calculation

WP-12, WP-13, WP-14, WP-15

Reference CHM-2570-C-06

$$\text{Total Area} = (3.8 \times 2.5) + [(.9 \times .5)] \cdot 5 = 9.725''$$

$$0, 45 \downarrow, 45 \uparrow, 60 \downarrow, 60 \uparrow = 2.35'' \text{ Limitation}$$

$$= \frac{9.725 - 2.35}{9.725} \times 100 = 75.8\% \text{ Coverage}$$

$$45 \uparrow = [.9 \times .55] \cdot 5 = .2475'' \text{ Limitation}$$

$$\frac{9.725 - .2475}{9.725} \times 100 = 97.5\% \text{ Coverage}$$

$$60 \uparrow = [1.1 \times 1] \cdot 7.5 = .55'' \text{ Limitation}$$

$$\frac{9.725 - .55}{9.725} \times 100 = 94.3\% \text{ Coverage}$$

$$60 \downarrow = \frac{(1.4 \times 2.1) \cdot 5}{9.725} \times 100 = 15.1\% \text{ Coverage}$$

$$45 \downarrow = \frac{(2.5 \times 2.1) \cdot 5}{9.725} \times 100 = 27\% \text{ Coverage}$$

0 - 75.8

45 - 75.845 - 75.860 - 75.860 - 75.845 \uparrow - 97.545 \downarrow - 15.160 \uparrow - 94.360 \downarrow - 27

$$612.9/9 = 68.1\%$$

B-directional Coverage

BY: [Signature]LEVEL: JHTDATE: 9/22/03PAGE 7OF 20

TVA

Office of Nuclear Power

PROJECT: WRN


SYSTEM: Pressurizer

REPORT NO.:

Unit: 1

WELD NO.: WP-12, WP-13, WP-14, WP-15

R0877



SCAN stops taken from Field Data TYPICAL SCAN
 Reference CHM-2570-C-06

BY: [Signature]

LEVEL: III

DATE: 9/23/03

PAGE 1 OF 1

TENNESSEE VALLEY AUTHORITY	EXAMINATION SUMMARY AND RESOLUTION SHEET	REPORT NUMBER: R0878
-------------------------------	--	--------------------------------

PROJECT: WEN UNIT: 1	CYCLE 05	COMPONENT ID: WP-14
----------------------	----------	---------------------

EXAMINATION METHOD		SYSTEM: PZR	ISI DWG NO: CHM-2570-C-01
--------------------	--	-------------	---------------------------

MT <input type="checkbox"/>	PT <input type="checkbox"/>	UT <input checked="" type="checkbox"/>	VT <input type="checkbox"/>	CONFIGURATION:	CATEGORY
-----------------------------	-----------------------------	--	-----------------------------	----------------	----------

PROCEDURE: N-UT-19	REV 14	TC: N/A	VHEAD TO VNOZ	B-D
--------------------	--------	---------	---------------	-----

EXAMINER: <i>Kenneth R. Smith</i>	EXAMINER: N/A	EXAMINER: N/A	EXAMINER: N/A
--------------------------------------	------------------	------------------	------------------

LEVEL: II	LEVEL: N/A	LEVEL: N/A	LEVEL: N/A
-----------	------------	------------	------------

Total coverage calculated to be approximately 81.5 % (2 ANGLES, 2 DIRECTION)
69.1 % see 9/23/03

This report contains the data associated with the ultrasonic examination of weld #WP-14

0.45 and 60 degree, 2.25 Mhz transducers were used.

The configuration resulted in scan limitations, an additional scan was performed looking away from the nozzle to obtain additional coverage, designated scan #9(-). See attached sketch

No reportable indications were detected.

RESOLUTION BY: <i>Kenneth R. Smith</i>	REVIEWED BY: <i>[Signature]</i>	ANII: <i>B. E. E. E.</i>
LEVEL II DATE: 9-19-03	LEVEL: II DATE: 9/20/03	DATE: 9/25/03
		Page: 1 OF 1

TENNESSEE VALLEY
AUTHORITY

DIGITAL ULTRASONIC
CALIBRATION
DATA SHEET

REPORT NUMBER

R0378

PROJECT WBN UNIT/CYCLE 11 05
PROCEDURE: N-UT-19 REV: 14 TC: N/A

CALIBRATION DATE: 9-18-03
CALIBRATION BLOCK NO. WB-55 TEMP: 78°F
SIMULATOR BLOCK: Rompas

TRANSDUCER
MANUFACTURER KBA
MODEL: GAMMA S/N J08204SP
SIZE: 1.0" FREQ: 2.25 MHz
SHAPE: Round # ELEMENTS: 1 # CONS: 0
CABLE TYPE RG-174 LENGTH: 6'


THERMOMETER S/N: 522352 DUE DATE: 6-16-04
COUPLANT: Ultragel II BATCH: 00225
ANGLE VERIFICATION

BLOCK TYPE: N/A S/N: N/A
NOMINAL ANGLE: 0° ACTUAL ANGLE 0°

MODE: SHEAR LONG RL

INSTRUMENT
MANUFACTURER: Krautkramer DUE DATE 5-27-04
MODEL NO.: USN-52L S/N: E30217

DAC



DISPLAY WIDTH 4.0 inches

INSTRUMENT SETTINGS				
REFLECTOR			REFERENCE SENSITIVITY	MEMORY NUMBER
SCAN DIRECT.	NTC	SDH		
AXIAL	<input type="checkbox"/>	<input checked="" type="checkbox"/>	26 dB	32
CIRC.			N/A dB	N/A
FREQ:	<u>2.0-8.0 MHz</u>		REJECT: = <u>0 %</u>	
ANGLE:	<u>0.0 deg</u>		DAMPING: <u>1000</u> ohms	
DELAY:	<u>0.039 msec</u>		PULSER: <u>SINGLE</u> *	
ZERO:	<u>1.172 msec</u>			
VELOCITY	<u>.2352 msec</u>		PRR/PRF: <u>HIGH</u>	
RANGE:	<u>4.0 inches</u>		TOF: <u>PEAK</u>	
DISP. MODE: <u>FULL WAV</u>			POWER: <u>BATTERY</u>	

REF. REFLECTOR: Rompas SDH GAIN: 20 dB
AMPLITUDE: 50 % METAL PATH: .728

CALIBRATION TIMES
INITIAL TIME: 22:00 FINAL TIME: 04:20

VERIFICATION TIMES 1) 00:58 2) N/A 3) N/A 4) N/A 5) N/A 6) N/A 7) N/A 8) N/A 9) N/A

*PDI QUALIFIED INSTRUMENT SETTINGS:

VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK

VERTICAL	SIGNAL 1										
	100	90	80	70	60	50	40	30	20		
	50	45	40	35	30	25	20	15	10		
ATTENUATOR	GAIN	SET	-6 dB	-12dB		SET	+12	SET	+6		
	AMP	80%	32 TO 48	16 TO 24	20%	64 TO 96	40%	64 TO 96			
		40	20		80		80				

COMMENTS

WELD / ITEMS EXAMINED

WP-14

NRI

EXAMINER: Kenneth R. Smith LVL: II

ANII: B. Earrigh

EXAMINER: N/A LVL: N/A

DATE: 9/25/03

REVIEWER: [Signature] LVL: III DATE: 9/22/03

PAGE 2 OF 8

TENNESSEE VALLEY
AUTHORITY


DIGITAL ULTRASONIC
CALIBRATION
DATA SHEET

REPORT NUMBER

R0878

PROJECT WBN UNIT/CYCLE 1/05
 PROCEDURE: N-UT-19 REV: 14 TC: N/A
 TRANSDUCER
 MANUFACTURER KBA
 MODEL: GAMMA S/N J15203
 SIZE: 0.5x1.0" FREQ: 2.25 MHz
 SHAPE: Rectangle # ELEMENTS: 1 # CONS: 0
 CABLE TYPE RG-174 LENGTH: 6'
 MODE: SHEAR LONG RL

CALIBRATION DATE: 9-18-03
 CALIBRATION BLOCK NO. WB-55 TEMP: 78°F
 SIMULATOR BLOCK: Rompas
 THERMOMETER S/N: 522352 DUE DATE: 6-16-04
 COUPLANT: Ultragel II BATCH: 00225
 ANGLE VERIFICATION
 BLOCK TYPE: Rompas S/N: 791413
 NOMINAL ANGLE: 45° ACTUAL ANGLE 45°
 INSTRUMENT
 MANUFACTURER: Krautkramer DUE DATE 5-27-04
 MODEL NO.: USN-52L S/N: E30217



INSTRUMENT SETTINGS

REFLECTOR			REFERENCE SENSITIVITY	MEMORY NUMBER
SCANDIRECT.	NTC	SDH		
AXIAL	<input type="checkbox"/>	<input checked="" type="checkbox"/>	34 dB	30
CIRC.	<input type="checkbox"/>		N/A dB	N/A
FREQ:	<u>2.0-8.0 MHz</u>		REJECT: = <u>0</u> %	
ANGLE:	<u>45 deg</u>		DAMPING: <u>1000</u> ohms	
DELAY:	<u>-0.008 msec</u>		PULSER: <u>SINGLE</u>	
ZERO:	<u>13.871 msec</u>		PRR/PRF: <u>HIGH</u>	
VELOCITY	<u>.1326 msec</u>		TOF: <u>PEAK</u>	
RANGE:	<u>6.0 inches</u>		POWER: <u>BATTERY</u>	
DISP. MODE:	<u>FULL WAV</u>			

REF. REFLECTOR: Rompas SDH GAIN: 38 dB
 AMPLITUDE: 60 % METAL PATH: 1.063
 VERIFICATION TIMES 1) 01:48 2) N/A 3) N/A 4) N/A 5) N/A 6) N/A 7) N/A 8) N/A 9) N/A

CALIBRATION TIMES
 INITIAL TIME: 22:20 FINAL TIME: 04:25

*PDI QUALIFIED INSTRUMENT SETTINGS:
 VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK

VERTICAL	SIGNAL 1									
		100	90	80	70	60	50	40	30	20
ATTENUATOR	SIGNAL 2									
		50	45	40	35	30	25	20	15	10
	GAIN	SET	-6 dB	-12dB	SET	+12	SET	+6		
	AMP	80%	32 TO 48	16 TO 24	20%	64 TO 96	40%	64 TO 96		
			40	20		80		80		

COMMENTS: -7 db BTWN. 3/4 AND 5/4 SDH'S WELD / ITEMS EXAMINED: WP-14
LIMITED SCAN, SEE ATTACHED SKETCH
NRI

EXAMINER: Kenneth R. Smith LVL: II ANII: B. Earnig
 EXAMINER: N/A LVL: N/A DATE: 9/25/03
 REVIEWER: [Signature] LVL: [Signature] DATE: 9/25/03 PAGE 3 OF 3

**TENNESSEE VALLEY
AUTHORITY**


**DIGITAL ULTRASONIC
CALIBRATION
DATA SHEET**

REPORT NUMBER
Ro878

PROJECT WBN UNIT/CYCLE 11 05
 PROCEDURE: N-UT-19 REV: 14 TC: N/A
 TRANSDUCER
 MANUFACTURER KBA
 MODEL: GAMMA S/N J15204
 SIZE: 0.5x1.0" FREQ: 2.25 MHz
 SHAPE: Rectangle # ELEMENTS: 1 # CONS: 0
 CABLE TYPE RG-174 LENGTH: 6'
 MODE: SHEAR LONG RL

CALIBRATION DATE: 9-18-03
 CALIBRATION BLOCK NO. WB-55 TEMP: 78°F
 SIMULATOR BLOCK: Rompas
 THERMOMETER S/N: 522352 DUE DATE: 6-16-04
 COUPLANT: Ultragel II BATCH: 00225
 ANGLE VERIFICATION
 BLOCK TYPE: Rompas S/N: 791413
 NOMINAL ANGLE: 60° ACTUAL ANGLE 60°
 INSTRUMENT
 MANUFACTURER: Krautkramer DUE DATE 5-27-04
 MODEL NO.: USN-52L S/N: E30217

DAC



A
M
P
L
I
T
U
D
E

DISPLAY WIDTH 8.5 inches

INSTRUMENT SETTINGS

REFLECTOR		REFERENCE SENSITIVITY	MEMORY NUMBER
SCAN DIRECT.	NTC SDH		
AXIAL	<input type="checkbox"/>	41 dB	31
CIRC.	<input type="checkbox"/>	N/A dB	N/A
FREQ:	2.0-8.0 MHz		REJECT: = 0 %
ANGLE:	60 deg		DAMPING: 1000 ohms
DELAY:	0.00 msec		PULSER: SINGLE *
ZERO:	16.404 msec		
VELOCITY	.1292 msec		PRR/PRF: HIGH
RANGE:	8.50 inches		TOF: PEAK
DISP. MODE:	FULL WAV		POWER: BATTERY

REF. REFLECTOR: Rompas SDH GAIN: 44 dB
 AMPLITUDE: 60 % METAL PATH: 1.532
 VERIFICATION TIMES 1) 02:48 2) N/A 3) N/A 4) N/A 5) N/A 6) N/A 7) N/A 8) N/A 9) N/A

CALIBRATION TIMES
 INITIAL TIME: 22:45 FINAL TIME: 04:15

***PDI QUALIFIED INSTRUMENT SETTINGS:**

VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK

VERTICAL	SIGNAL 1		100	90	80	70	60	50	40	30	20
		SIGNAL 2		50	45	40	35	30	25	20	15
ATTENUATOR	GAIN	SET	-6 dB	-12dB	SET	+12	SET	+6			
	AMP	80%	32 TO 48	16 TO 24	20%	64 TO 96	40%	64 TO 96			
			40	20		80		80			

COMMENTS:

WELD / ITEMS EXAMINED

-11 db BTWN. 3/4 + 5/4 SDH'S WP-14

LIMITED SCAN, SEE ATTACHED SKETCH

NRI

EXAMINER: Kenneth R. Smith LVL: II
 EXAMINER: N/A LVL: N/A
 REVIEWER: [Signature] LVL: III DATE: 9/20/03


ANII: B. Earnigh
 DATE: 9/25/03
 PAGE 4 OF 6

TENNESSEE VALLEY AUTHORITY				MANUAL ULTRASONIC VESSEL EXAMINATION DATA SHEET								REPORT NUMBER <i>R0878</i>												
PROJECT <i>WBN</i> UNIT/CYCLE <i>1/5</i>				V _o REFERENCE: <i>HEAD SIDE WELD TDE</i>				EXAMINATION DATE <i>9-19-03</i>																
SYSTEM: <i>PZR</i>				Lo REFERENCE: <i>0" STAMP</i>				START TIME: <i>00:58</i>				END TIME: <i>04:00</i>												
WELD I.D.: <i>WP-14</i>				SURFACE TEMP.: <i>76 °F</i>				ANGLE <i>0°</i> <i>45°</i> <i>60°</i>				SCAN SENSITIVITY <i>MIN 32 dB</i> <i>40-46 dB</i> <i>47-53 dB</i>												
CONFIG.: <i>Head TO Nozzle</i> <div style="text-align: center;">→ FLOW</div>																								
PROCEDURE: <i>N-UT-19</i> REV: <i>14</i> TC: <i>N/A</i>				PYRO. SERIAL NO.: <i>522352</i>																				
RESULTS: (SCAN NUMBER)				1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19		
INDICATION RECORDED (Y/N)				<i>N/A</i>							<i>N/A</i>				<i>N/A</i>							<i>N/A</i>		
IND NO.	MAX AMP	SCAN NO.	ANG.	100% (1/2 MAX)			50%			20%			MAX			20%			50%			100% (1/2 MAX)		
				Mp1	W1	L1	Mp1	W1	L1	Mp1	W1	L1	Mp	W	L	Mp2	W2	L2	Mp2	W2	L2	Mp2	W2	L2
<i>N/A</i>																								
REMARKS/LIMITATIONS <i>NRI</i>																								
EXAMINER: <i>Kenneth R Smith</i> LEVEL: <i>II</i>						REVIEWED BY: <i>J. D. Whitaker</i>						ANII: <i>B. Eamigh</i>												
EXAMINER: <i>N/A</i> LEVEL: <i>N/A</i>						LEVEL: <i>JH</i> DATE: <i>9/20/03</i>						DATE: <i>9/25/03</i> PAGE <i>5</i> OF <i>8</i>												

TVA
Office of Nuclear Power

PROJECT: WBN SYSTEM: PZR
Unit: 1 / CYCLE 5 WELD NO.: WP-14

REPORT NO.:
R0878



DRWG. TO SCALE

BY: Kenneth R. Smith LEVEL: II DATE: 9-19-03 PAGE 6 OF 8

TVA

Office of Nuclear Power

PROJECT: WBN SYSTEM: PressurizerUnit: 1 WELD NO.: see below

REPORT NO.:

R0878

Safety and Relief Coverage Calculation

WP-12, WP-13, WP-14, WP-15

Reference CHM-2570-C-06

$$\text{Total Area} = (3.8 \times 2.5) + [(.9 \times .5)] \cdot 5 = 9.725''$$

$$0, 45 \uparrow, \frac{45}{P}, \frac{60}{P}, \frac{60}{P} = 2.35'' \text{ Limitation}$$

$$= \frac{9.725 - 2.35}{9.725} \times 100 = 75.8\% \text{ Coverage}$$

$$45 \uparrow = [.9 \times .5] \cdot 5 = .2475'' \text{ Limitation}$$

$$\frac{9.725 - .2475}{9.725} \times 100 = 97.5\% \text{ Coverage}$$

$$60 \uparrow = [1.1 \times 1] \cdot 5 = .55'' \text{ Limitation}$$

$$\frac{9.725 - .55}{9.725} \times 100 = 94.3\% \text{ Coverage}$$

$$60 \downarrow = (1.4 \times 2.1) \cdot 5 \times 100 = 15.1\% \text{ Coverage}$$

$$45 \downarrow = (2.5 \times 2.1) \cdot 5 \times 100 = 27\% \text{ Coverage}$$

0 - 75.8

45 - 75.845 - 75.860 - 75.860 - 75.845 \uparrow - 97.545 \downarrow - 15.160 \uparrow - 94.360 - 27

612.9/9 = 68.1%

Bi-directional Coverage

BY: [Signature]LEVEL: HTDATE: 9/22/03PAGE: 7OF 8

TVA
Office of Nuclear Power

PROJECT: WBN


SYSTEM: Pressurizer

REPORT NO.:

Unit: 1

WELD NO.: WP-12, WP-13, WP-14, WP-15

RD878



SCAN stops taken from TYPICAL SCAN
Field Data Reference CHM-2570-C-06

BY: [Signature]

LEVEL: III

DATE: 9/23/03

PAGE 2 OF 2

TENNESSEE VALLEY AUTHORITY		EXAMINATION SUMMARY AND RESOLUTION SHEET		REPORT NUMBER: R0879	
PROJECT: WBN UNIT: 1 CYCLE 05			COMPONENT ID: WP-15		
EXAMINATION METHOD			SYSTEM: PZR	ISI DWG NO: CHM-2570-C-01	
MT <input type="checkbox"/>	PT <input type="checkbox"/>	UT <input checked="" type="checkbox"/>	VT <input type="checkbox"/>	CONFIGURATION:	CATEGORY
PROCEDURE: N-UT-19		REV 14	TC: N/A	VHEAD TO VNOZ	B-D
EXAMINER: <i>Kenneth R. Smith</i>		EXAMINER: N/A		EXAMINER: N/A	EXAMINER: N/A
LEVEL: II		LEVEL: N/A		LEVEL: N/A	LEVEL: N/A
<p>Total coverage calculated to be approximately 81.5 % (2 ANGLE 2 DIRECTION) 68.1 % SW 9/23/03</p> <p><i>This report contains the ultrasonic examination data associated with weld #WP-15</i></p> <p><i>0.45 and 60 degree 2.25 Mhz transducers were used.</i></p> <p><i>The configuration resulted in scan limitations, an additional scan was performed looking away from the nozzle to obtain additional coverage, designated scan #9(-). See attached sketch.</i></p> <p><i>No reportable indications were detected.</i></p>					
RESOLUTION BY: <i>Kenneth R. Smith</i>		REVIEWED BY: <i>John Whiteaker</i>		ANII: <i>B. Ewing</i>	
LEVEL II DATE: 9-19-03		LEVEL: II DATE: 9/23/03		DATE: 9/29/03	
				Page: 1 OF 4	

TENNESSEE VALLEY
AUTHORITY

DIGITAL ULTRASONIC
CALIBRATION
DATA SHEET

REPORT NUMBER

20879

PROJECT WBN UNIT/CYCLE 1105
PROCEDURE: N-UT-19 REV: 14 TC: N/A

CALIBRATION DATE: 9-18-03
CALIBRATION BLOCK NO. WB-55 TEMP: 78°F
SIMULATOR BLOCK: Rompas

MANUFACTURER KBA
MODEL: GAMMA S/N J08204SP
SIZE: 1.0" FREQ: 2.25 MHz
SHAPE: Round # ELEMENTS: 1 # CONS: 0
CABLE TYPE RG-174 LENGTH: 6'

THERMOMETER S/N: 522352 DUE DATE: 6-16-04
COUPLANT: Ultragel II BATCH: 00225
ANGLE VERIFICATION


BLOCK TYPE: N/A S/N: N/A
NOMINAL ANGLE: 0° ACTUAL ANGLE 0°

MODE: SHEAR LONG RL

INSTRUMENT
MANUFACTURER: Krauthramer DUE DATE 5-27-04
MODEL NO.: USN-52L S/N: E30217

DAC

INSTRUMENT SETTINGS



A
M
P
L
I
T
U
D
E

DISPLAY WIDTH 4.0 inches

REFLECTOR		REFERENCE SENSITIVITY	MEMORY NUMBER
SCAN DIRECT.	NTC ; SDH		
AXIAL	<input type="checkbox"/> <input checked="" type="checkbox"/>	26 dB	32
CIRC.	<input type="checkbox"/> <input type="checkbox"/>	N/A dB	N/A
FREQ:	<u>2.0-8.0</u> MHz	REJECT: = <u>0</u> %	
ANGLE:	<u>0</u> deg	DAMPING: <u>1000</u> ohms	
DELAY:	<u>.039</u> msec	PULSER: <u>SINGLE</u> *	
ZERO:	<u>1.172</u> msec		
VELOCITY	<u>.2352</u> msec	PRR/PRF: <u>HIGH</u>	
RANGE:	<u>4.0</u> inches	TOF: <u>PEAK</u>	
DISP. MODE:	<u>FULL WAVE</u>	POWER: <u>BATTERY</u>	

REF. REFLECTOR: Rompas SDH GAIN: 20 dB

CALIBRATION TIMES

AMPLITUDE: 50 % METAL PATH: .728

INITIAL TIME: 22:00 FINAL TIME: 04:20

VERIFICATION TIMES 1) 00:58 2) N/A 3) N/A 4) N/A 5) N/A 6) N/A 7) N/A 8) N/A 9) N/A

*PDI QUALIFIED INSTRUMENT SETTINGS:

VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK

VERTICAL	SIGNAL 1									
		100	90	80	70	60	50	40	30	20
ATTENUATOR	SIGNAL 2									
		50	45	40	35	30	25	20	15	10
	GAIN	SET	-6 dB	-12dB	SET	+12	SET	+6		
	AMP	80%	32 TO 48	16 TO 24	20%	64 TO 96	40%	64 TO 96		
			40	20		80		80		

COMMENTS

WELD / ITEMS EXAMINED

WP-15

NRI

EXAMINER: Kenneth R. Smith LVL.: II

ANII: B. Earnigh

EXAMINER: N/A LVL.: N/A

DATE: 9/29/03

REVIEWER: [Signature] LVL.: III DATE: 9/29/03

PAGE 2 OF 2

TENNESSEE VALLEY
AUTHORITY

DIGITAL ULTRASONIC
CALIBRATION
DATA SHEET

REPORT NUMBER


20879

PROJECT WBN UNIT/CYCLE 11/05
PROCEDURE: N-UT-19 REV: 14 TC: N/A

MANUFACTURER KBA
MODEL: GAMMA S/N J15203
SIZE: 0.5x1.0" FREQ: 2.25 MHz
SHAPE: Rectangle # ELEMENTS: 1 # CONS: 0
CABLE TYPE RG-174 LENGTH: 6'

MODE: SHEAR LONG RL

DAC



A
M
P
L
I
T
U
D
E

DISPLAY WIDTH 6.0 inches

CALIBRATION DATE: 9-18-03
CALIBRATION BLOCK NO. WB-55 TEMP: 78°F
SIMULATOR BLOCK: Rompas

THERMOMETER S/N: 522352 DUE DATE: 6-16-04
COUPLANT: Ultragel II BATCH: 00225

ANGLE VERIFICATION
BLOCK TYPE: Rompas S/N: 791413
NOMINAL ANGLE: 45° ACTUAL ANGLE 45°

INSTRUMENT
MANUFACTURER: Krautkramer DUE DATE 5-27-04
MODEL NO.: USN-52L S/N: E30217

INSTRUMENT SETTINGS

REFLECTOR			REFERENCE SENSITIVITY	MEMORY NUMBER
SCAN DIRECT.	NTC	SDH		
AXIAL		<input checked="" type="checkbox"/>	34 dB	30
CIRC.		<input type="checkbox"/>	N/A dB	N/A
FREQ:	<u>2.0-8.0 MHz</u>		REJECT: =	<u>0 %</u>
ANGLE:	<u>45 deg</u>		DAMPING:	<u>1000</u> ohms
DELAY:	<u>-0.008 msec</u>		PULSER:	<u>SINGLE</u> *
ZERO:	<u>13.871 msec</u>		PRR/PRF:	<u>HIGH</u>
VELOCITY	<u>.1326 msec</u>		TOF:	<u>PEAK</u>
RANGE:	<u>6.0 inches</u>		POWER:	<u>BATTERY</u>
DISP. MODE:	<u>FULL WAY</u>			

REF. REFLECTOR: Rompas SDH GAIN: 38 dB
AMPLITUDE: 60 % METAL PATH: 1.063

CALIBRATION TIMES

INITIAL TIME: 22:20 FINAL TIME: 04:25
VERIFICATION TIMES 1) 01:48 2) N/A 3) N/A 4) N/A 5) N/A 6) N/A 7) N/A 8) N/A 9) N/A

*PDI QUALIFIED INSTRUMENT SETTINGS:

VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK

VERTICAL	SIGNAL 1									
		100	90	80	70	60	50	40	30	20
ATTENUATOR	SIGNAL 2									
		50	45	40	35	30	25	20	15	10
	GAIN	SET	-6 dB	-12dB	SET	+12	SET	+6		
	AMP	80%	32 TO 48	16 TO 24	20%	64 TO 96	40%	64 TO 96		
			40	20		80		80		

COMMENTS

WELD / ITEMS EXAMINED

-7 db BTWN. 3/4 AND 5/4 SDH'S WP-15

LIMITED SCAN, SEE ATTACHED SKETCH

NRI

EXAMINER: Kenneth R. Smith LVL.: II

ANII: B. Ennigh

EXAMINER: N/A LVL.: N/A

DATE: 9/29/03

REVIEWER: [Signature] LVL.: II DATE: 9/29/03

PAGE 3 OF 3

TENNESSEE VALLEY
AUTHORITY

DIGITAL ULTRASONIC
CALIBRATION
DATA SHEET

REPORT NUMBER

20879

PROJECT WBN UNIT/CYCLE 11 05
PROCEDURE: N-UT-19 REV: 14 TC: N/A

CALIBRATION DATE: 9-18-03
CALIBRATION BLOCK NO. WB-55 TEMP: 78°F
SIMULATOR BLOCK: Rompas

TRANSDUCER
MANUFACTURER KBA
MODEL: GAMMA S/N J15204
SIZE: 0.5x1.0" FREQ: 2.25 MHz
SHAPE: Rectangle # ELEMENTS: 1 # CONS: 0
CABLE TYPE RG-174 LENGTH: 6'

THERMOMETER S/N: 522352 DUE DATE: 6-16-04
COUPLANT: Ultragel II BATCH: 00225
ANGLE VERIFICATION


BLOCK TYPE: Rompas S/N: 791413
NOMINAL ANGLE: 60° ACTUAL ANGLE 60°

MODE: SHEAR LONG RL

INSTRUMENT
MANUFACTURER: Krautkramer DUE DATE 5-27-04
MODEL NO.: USN-52L S/N: E30217

DAC

INSTRUMENT SETTINGS



A
M
P
L
I
T
U
D
E

DISPLAY WIDTH 8.5 inches

REFLECTOR			REFERENCE SENSITIVITY	MEMORY NUMBER
SCAN DIRECT.	NTC	SDH		
AXIAL	<input type="checkbox"/>	<input checked="" type="checkbox"/>	41 dB	31
CIRC.	<input type="checkbox"/>	<input type="checkbox"/>	N/A dB	N/A
FREQ:	2.0-8.0 MHz		REJECT: =	0 %
ANGLE:	60 deg		DAMPING: 1000	ohms
DELAY:	0.00 msec		PULSER: SINGLE	*
ZERO:	16.404 msec		PRR/PRF: HIGH	
VELOCITY	.1292 msec		TOF: PEAK	
RANGE:	8.5 inches		POWER: BATTERY	
DISP. MODE:	FULL WAV			

REF. REFLECTOR: Rompas SDH GAIN: 44 dB

CALIBRATION TIMES

AMPLITUDE: 60 % METAL PATH: 1.532

INITIAL TIME: 22:45 FINAL TIME: 04:15

VERIFICATION TIMES 1) 02:48 2) N/A 3) N/A 4) N/A 5) N/A 6) N/A 7) N/A 8) N/A 9) N/A

*PDI QUALIFIED INSTRUMENT SETTINGS:

VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK

VERTICAL	SIGNAL 1		100	90	80	70	60	50	40	30	20	
		SIGNAL 2		50	45	40	35	30	25	20	15	10
ATTENUATOR	GAIN	SET	-6 dB		-12dB		SET		+12		SET	+6
	AMP	80%	32 TO 48		16 TO 24		20%		64 TO 96		40%	64 TO 96
			40		20				80			80

COMMENTS

WELD / ITEMS EXAMINED

-11 db. BTWN. 3/4 AND 5/4 SDH'S WP-15

LIMITED SCAN, SEE ATTACHED SKETCH

NRI

EXAMINER: Kenneth R. Smith LVL.: II

ANII: B. Earnigh


EXAMINER: N/A LVL.: N/A

DATE: 9/29/03

REVIEWER: [Signature] LVL.: III DATE: 9/29/03

PAGE 4 OF 8

TENNESSEE VALLEY AUTHORITY	MANUAL ULTRASONIC VESSEL EXAMINATION DATA SHEET	REPORT NUMBER <i>2087-9</i>
-----------------------------------	--	---------------------------------------

PROJECT: <i>WBN</i> UNIT/CYCLE: <i>1/5</i> SYSTEM: <i>PZR</i> WELD I.D.: <i>WP-15</i> CONFIG.: _____ TO _____ <div style="text-align: center;">  </div> PROCEDURE: <i>N-UT-19</i> REV: <i>14</i> TC: <i>N/A</i>	W ₀ REFERENCE: <i>HEAD SIDE WELD TOE</i> L ₀ REFERENCE: <i>"0" STAMP</i> SURFACE TEMP.: <i>76 °F</i> PYRO. SERIAL NO.: <i>522352</i>	EXAMINATION DATE: <i>9-19-03</i> START TIME: <i>00:58</i> END TIME: <i>04:00</i> <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th style="width:50%;">ANGLE</th> <th style="width:50%;">SCAN SENSITIVITY</th> </tr> <tr> <td style="text-align: center;"><i>0°</i></td> <td style="text-align: center;"><i>MIN 32 dB</i></td> </tr> <tr> <td style="text-align: center;"><i>45°</i></td> <td style="text-align: center;"><i>40-46 dB</i></td> </tr> <tr> <td style="text-align: center;"><i>60°</i></td> <td style="text-align: center;"><i>47-53 dB</i></td> </tr> </table>	ANGLE	SCAN SENSITIVITY	<i>0°</i>	<i>MIN 32 dB</i>	<i>45°</i>	<i>40-46 dB</i>	<i>60°</i>	<i>47-53 dB</i>
ANGLE	SCAN SENSITIVITY									
<i>0°</i>	<i>MIN 32 dB</i>									
<i>45°</i>	<i>40-46 dB</i>									
<i>60°</i>	<i>47-53 dB</i>									

RESULTS: (SCAN NUMBER)	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19
INDICATION RECORDED (Y/N)	<i>N/A</i>							<i>N/A</i>				<i>N/A</i>							<i>N/A</i>

IND NO.	MAX AMP	SCAN NO.	ANG.	100% (1/2 MAX)			50%			20%			MAX			20%			50%			100% (1/2 MAX)		
				Mp1	W1	L1	Mp1	W1	L1	Mp1	W1	L1	Mp	W	L	Mp2	W2	L2	Mp2	W2	L2	Mp2	W2	L2


REMARKS/LIMITATIONS: *NRI*

EXAMINER: <i>Kenneth R. Smith</i> LEVEL: <i>II</i> EXAMINER: <i>N/A</i> LEVEL: <i>N/A</i>	REVIEWED BY: <i>[Signature]</i> LEVEL: <i>[Signature]</i> DATE: <i>9/20/03</i>	ANII: <i>B. Emig</i> DATE: <i>9/22/03</i> PAGE <i>1</i> OF <i>2</i>
--	---	--

TVA
Office of Nuclear Power

PROJECT: WBN SYSTEM: PZR
Unit: 1 / CYCLE 5 WELD NO.: WP-15

REPORT NO.:
R0879



DRWG. TO SCALE

BY: Kenneth R. Smith LEVEL: II DATE: 9-19-03 PAGE 6 OF 8

TVA

Office of Nuclear Power

PROJECT: WBN SYSTEM: PressurizerUnit: 1 WELD NO.: see below

REPORT NO.:

R0879

Safety and Relief Coverage Calculation

WP-12, WP-13, WP-14, WP-15

Reference CHM-2570-C-06

$$\text{Total Area} = (3.8 \times 2.5) + [(.9 \times .5)] \cdot 5 = 9.725''$$

$$0, 45 \uparrow, 45 \downarrow, 60 \uparrow, 60 \downarrow = 2.35'' \text{ Limitation}$$

$$= \frac{9.725 - 2.35}{9.725} \times 100 = 75.8\% \text{ Coverage}$$

$$45 \uparrow = [.9 \times .55] \cdot 5 = .2475'' \text{ Limitation}$$

$$\frac{9.725 - .2475}{9.725} \times 100 = 97.5\% \text{ Coverage}$$

$$60 \uparrow = [1.1 \times 1] \cdot 5 = .55'' \text{ Limitation}$$

$$\frac{9.725 - .55}{9.725} \times 100 = 94.3\% \text{ Coverage}$$

$$60 \downarrow = (1.4 \times 2.1) \cdot 5 \times 100 = 15.1\% \text{ Coverage}$$

$$45 \downarrow = (2.5 \times 2.1) \cdot 5 \times 100 = 27\% \text{ Coverage}$$

0 - 75.8

45 - 75.845 - 75.860 - 75.860 - 75.845 \uparrow - 97.545 \downarrow - 15.160 \uparrow - 94.360 - 27

$$\frac{612.9}{9} = 68.1\%$$

B-directional Coverage

BY: [Signature]LEVEL: JTTDATE: 9/27/03PAGE 7OF 8

TVA
Office of Nuclear Power

PROJECT: WBN


SYSTEM: Pressurizer

REPORT NO.:

Unit: 1

WELD NO.: WP-12, WP-13, WP-14, WP-15

R0879



SCAN stops taken from TYPICAL SCAN
Field DATA Reference CAH-2570-C-06

BY: [Signature]

LEVEL: III

DATE: 9/23/03

PAGE 8 OF 20

ENCLOSURE 2

WATTS BAR NUCLEAR PLANT (WBN) UNIT 1
AMERICAN SOCIETY OF MECHANICAL ENGINEERS (ASME)
FIRST TEN YEAR INSERVICE INSPECTION INTERVAL

REQUEST FOR RELIEF, 1-ISI-15

Enclosure 2

WATTS BAR NUCLEAR PLANT
AMERICAN SOCIETY OF MECHANICAL ENGINEERS (ASME)
FIRST TEN YEAR INSERVICE INSPECTION INTERVAL
REQUEST FOR RELIEF, 1-ISI-15

I. Summary:

This request for relief addresses safety injection system circumferential pressure retaining welds SIF-D086-02 and RHRF-D054-09. The design configuration of the subject austenitic piping welds provides single side access for examination. Single side access precludes meeting the examination requirements.

An ultrasonic examination, using the Performance Demonstration Initiative (PDI) procedures, was performed on accessible areas to the maximum extent practical, given the physical limitations and materials of the subject welds. The design configuration and materials used limits the best effort ultrasonic examination to approximately 50 percent for pipe to valve welds SIF-D086-02 and RHRF-D054-09. It was concluded that performance of an ultrasonic examination of essentially 100 percent of the lower one third of the subject circumferential pressure retaining welds would be impractical. The maximum extent practical ultrasonic examination of the subject welds provides reasonable assurance of an acceptable level of quality and safety because the information and data obtained from the volume examined provides sufficient information to judge the overall integrity of the welds. The WBN Code of Record is ASME Section XI, 1989 Edition. Therefore pursuant to 10 CFR 50.55a(g)(5)(iii), it is requested that relief be granted, for the first inspection interval.

II. Component:

One 6-inch Safety Injection System Piping Weld
One 8-inch Safety Injection System Piping Weld.

Reference ISI drawing CHM-2636-C-07 and ISI-0375-C-16 Weld Identifiers RHRF-D054-09 and SIF-D086-02, (See Attachment 1).

III. Code Requirement:

1989 Edition of ASME Section XI and WCAP-14572, *Westinghouse Owners Group Application of Risk-Informed Methods to Piping Inservice Inspection Topical Report*, Revision 1-NP-A, dated February 1999, Table 4.1-1, *Examination Category R-A, Risk-Informed Piping Examinations*, Item Number R1.11, *Elements Subject to Thermal Fatigue* (See Attachment 2). NRC approved the use of the WCAP for WBN in NRC's safety evaluation for the

Enclosure 2

WATTS BAR NUCLEAR PLANT
AMERICAN SOCIETY OF MECHANICAL ENGINEERS (ASME)
FIRST TEN YEAR INSERVICE INSPECTION INTERVAL
REQUEST FOR RELIEF, 1-ISI-15

Risk Informed Inservice Inspection Program dated January 24, 2002 (TAC No. MB 2082).

The examination requirement is defined in Figure IWB-2500-8(c) (Attachment 3).

IV. Code Requirements From Which Relief Is Requested:

Relief is requested from performing the required volumetric examination on essentially 100 percent of the lower one-third volume of the referenced welds.

V. Basis for Relief:

The 10 CFR 50.55a(b) (2) (xv) (A) requires that if access is available, the weld shall be scanned in each of the four directions (parallel and perpendicular to the weld) where accessible. Coverage credit may be taken for single side exams on ferritic piping. However, for austenitic piping, a procedure must be qualified with flaws on the inaccessible side of the weld. There are currently no qualified single side examination procedures for austenitic piping welds. Current technology is not capable of reliably detecting or sizing flaws on the far side of an austenitic weld for configurations common to United States nuclear applications. The PDI Program conforms to the 10 CFR 50.55a(b) (2) (xv) (A) regarding single side access for piping.

PDI Performance Demonstration Qualification Summary (PDQS) personnel certificates for austenitic piping list the limitation that single side examination is performed on a best effort basis. The best effort qualification is provided in place of a complete single side qualification to demonstrate that the examiners qualification and the subsequent weld examination is based on application of the best available technology.

When the examination area is limited to one side of an austenitic weld, examination coverage does not comply with 10 CFR 50.55a(b) (2) (xvi) (B) and full coverage credit may not be claimed.

The design configuration and materials used in fabrication of the subject safety injection system

Enclosure 2

WATTS BAR NUCLEAR PLANT
AMERICAN SOCIETY OF MECHANICAL ENGINEERS (ASME)
FIRST TEN YEAR INSERVICE INSPECTION INTERVAL
REQUEST FOR RELIEF, 1-ISI-15

welds precludes an ultrasonic examination of the required volume because there are no current qualified single side examination procedures that demonstrate equivalency to two-sided examination procedures on austenitic piping. The design configuration and material limits ultrasonic examination to the extent indicated:

<u>Weld</u>	<u>Best Effort Coverage</u>	<u>ASME Section XI Coverage</u> ^(NOTE 1)
SIF-D086-02	50%	100%
RHRF-D054-09	50%	100%

NOTE 1 - Coverage does not consider the inherent limitations associated with the PDI for one side access.

VI. Alternative Examination:

In lieu of the code required examination coverage and qualification demonstration requirements, a best effort ultrasonic examination was performed, as qualified through the PDI for Supplement 2 to ASME Section XI, Appendix VIII with demonstrated best effort for single side examination. Refer to the examination data reports in Attachment 4.

VII. Justification For The Granting Of Relief:

The best available techniques, as qualified through the PDI for Supplement 2 of Appendix VIII with demonstrated best effort for single side examination, were used from the accessible side of the weld.

- (1) The design configuration and materials used in the fabrication of the subject piping welds precludes ultrasonic examination of essentially 100 percent of the required examination volume. In order to examine the welds in accordance with the code requirements, the safety injection system would require extensive modification.

The design configuration and materials used limits the best effort ultrasonic examination to approximately 50 percent for pipe to valve welds SIF-D086-02 and RHRF-D054-09.

Enclosure 2

WATTS BAR NUCLEAR PLANT
AMERICAN SOCIETY OF MECHANICAL ENGINEERS (ASME)
FIRST TEN YEAR INSERVICE INSPECTION INTERVAL
REQUEST FOR RELIEF, 1-ISI-15

The subject welds were examined using application of the best available ultrasonic technology currently qualified.

- (2) Radiographic examination as an alternate volumetric examination method was determined to be impractical due to the material thickness variation and the ASME Section XI Code requiring an extended coverage (weld plus ½-inch of base material from the transition point). The radiographic density variation does not lend for compliance with ASME Section V, Nondestructive Examination, requirements without extensive radiographic exposures to obtain the density for the base material on the fitting (valve) side. The additional radiography required would increase personnel radiation exposure.
- (3) A Risk-Informed approach provided by the WCAP-14572, in combination with examinations performed on similar items, provides reasonable assurance that significant degradation, if present, would have been detected.

Performance of an ultrasonic volumetric examination of essentially 100 percent of the required volume of pressure retaining circumferential welds SIF-D086-02 and RHRF-D054-09 would be impractical. As previously discussed, TVA determined that it would be impractical to attempt other volumetric examinations in order to increase examination coverage. The maximum extent practical ultrasonic examination of the subject welds provides reasonable assurance of an acceptable level of quality and safety. Significant degradation, if present, would have been detected during the best effort ultrasonic examination that was performed on the subject welds. As a result, reasonable assurance of operational readiness has been provided.

Therefore pursuant to 10 CFR 50.55a(g)(5)(iii), it is requested that relief be granted, for the first inspection interval.

Enclosure 2

WATTS BAR NUCLEAR PLANT
AMERICAN SOCIETY OF MECHANICAL ENGINEERS (ASME)
FIRST TEN YEAR INSERVICE INSPECTION INTERVAL
REQUEST FOR RELIEF, 1-ISI-15

VIII. Implementation Schedule:

This Request for Relief is applicable to WBN's first inspection interval.

Enclosure 2

WATTS BAR NUCLEAR PLANT
AMERICAN SOCIETY OF MECHANICAL ENGINEERS (ASME)
FIRST TEN YEAR INSERVICE INSPECTION INTERVAL
REQUEST FOR RELIEF, 1-ISI-15

List of Attachments

- Attachment 1 Weld Location ISI drawing CHM-2636-C-07 and ISI-0375-C-16
- Attachment 2 WCAP-14572, Westinghouse Owners Group Application of Risk-Informed Methods to Piping Inservice Inspection Topical Report, Revision 1-NP-A, dated February 1999, Table 4.1-1, Examination Category R-A, Risk-Informed Piping Examinations,
- Attachment 3 ASME Section XI, 1989 Edition, Figure IWB-2500-8(c), Similar and Dissimilar Metal Welds in Components and Piping
- Attachment 4 Examination Data Reports
SIF-D086-02 - Report R0899
RHRF-D054-09 - Report R0907

ENCLOSURE 2
ATTACHMENT 1


WATTS BAR NUCLEAR PLANT (WBN) UNIT 1
FIRST TEN YEAR INSERVICE INSPECTION INTERVAL

REQUEST FOR RELIEF, 1-ISI-15
Weld Location ISI Drawing CHM-2636-C-07

REFERENCE DRAWINGS
WBN-5-2879 IC-94
SK-2547 SH-6

MATERIAL SPECIFICATIONS
ASME CC-1 (EQUIVALENT)
PIPING SEAMLESS STAINLESS STEEL
8" SCH. 160 SA 378 TP 304
6" SCH. 160 SA 378 TP 304
4" SCH. 160 SA 378 TP 316
3" SCH. 160 SA 378 TP 304
FITTINGS SEAMLESS STAINLESS STEEL
2" 60000 S.D. SA 483 HP 304
6" & 8" SCH. 160 SA 483 HP 304

ASME CC-2 (EQUIVALENT)
PIPING SEAMLESS STAINLESS STEEL
12" SCH. 140 SA 378 TP 316
8" SCH. 160 SA 378 TP 304
6" SCH. 160 SA 312 TP 316
FITTINGS SEAMLESS STAINLESS STEEL
12" SCH. 140 SA 483 HP 316
8" SCH. 160 SA 483 HP 304



NOTES:
1. WELD RHRF-D054-01 IS A PIPE TO PIPE WELD THAT IS NOT WITHIN 3 PIPE DIAMETERS OF A RIGID ANCHOR.

SK WELDS: RHRS-141 THRU 151 RHRS-160 THRU -167, RHRS-184A, RHRS-169 THRU -171

2	PHB	GLB	REC	RDB	9-27-88
REVISE WELD RHRF-144A TO RHRS-144A, LIST SHIP WELDS AND CONTINUATION TO RCS, ADD 8" & 6" FITTING SPECS.					
3	PHB	PHB	GLB	RNE	2-8-95
REVISE CONTINUATION FOR CLARITY, TITLE BLOCK					
7	PHB	PHB	JES	RNE	04/13/91
ADD MATCH LINE A AND REDRAW ON CAD					
8	JAN	RPC	JOC	GLB	7-13-99
ADD NOTE					
9	LAD	JES	JGR	GLB	8-1-98
CORRECT US FOR PRISM AND ADD MATERIAL SPECIFICATIONS					
REV.	BY	CHECKED	SUBMITTED	APPROVED	DATE
TENNESSEE VALLEY AUTHORITY					
WATTS BAR NUCLEAR PLANT UNIT 1 RESIDUAL HEAT REMOVAL SYSTEM WELD LOCATIONS					
DESIGN:	DATE:	SCALE: NOT TO SCALE			
CHECKED: JTL	APPROVED: GLB	CAD MAINTAINED BRADING REV			
SUBMITTED:	CHM-2636-C-07 09				

E2A1-1

ENCLOSURE 2
ATTACHMENT 1

WATTS BAR NUCLEAR PLANT (WBN) UNIT 1
FIRST TEN YEAR INSERVICE INSPECTION INTERVAL

REQUEST FOR RELIEF, 1-ISI-15
Weld Location ISI Drawing ISI-0375-C-16

REFERENCE DRAWINGS
WBN-E-2879-1C-74
WBN-E-2879-1C-86
P79432-022.1

MATERIAL SPECIFICATIONS

PIPE
3" SCH. 160 SA-376 TP 304
4" SCH. 160 SA-376 TP 304

FITTINGS
4" SCH 160 SA 403 WP 304
6" SCH 160 SA 403 WP 304
4"X3" RED. SCH. 160 SA 403 WP 304


FLANGE
4" 1500# SA-182 F316

PENETRATION X-22
SA 182 GR F 304

ASME CC-2 (EQUIVALENT)

NOTES:

1. WELDS SIF-D074-12 AND SIS-242A ARE PIPE TO FLUED HEAD WELDS



2	PHB	PHB	GLB	PHB	3-22-85
REVISE TITLE BLOCK, AND WELD SYMBOLS, UNITS, SPECS., PER DETAIL					
2	PHB	PHB	GLB	PHB	6-18-84
CHANGE SERIES FROM 23 TO 26 SHEETS, CORRECT MATCH LINE AND WELD NUMBER, CHANGE STRESS TO ALIGNMENT					
1	PHB	PHB	REC	GLB	1-4-83
CHANGE WELD SIF-D074-13 & 14 TO SIF-220A & -220B, & CORRECT FIELD WELD SYMBOL					
REV.	BY	CHECKED	SUBMITTED	APPROVED	DATE
TENNESSEE VALLEY AUTHORITY					
WATTS BAR NUCLEAR PLANT UNIT 1 1100 PSI PRESSURE SAFETY INJECTION SYSTEM WELD LOCATIONS (CHEMICAL & VOLUME CONTROL)					
DRAWN	PHB	DATE	9-17-82	SCALE	NOT TO SCALE
CHECKED	PHB	APPROVED	GLB	CAD	UNATTAINED DRAWING REV
SUBMITTED	REC	ISI-0375-C-16		D3	

SIS-220 THRU SIS-242A

E2A1-2

WATTS BAR NUCLEAR PLANT (WBN) UNIT 1
FIRST TEN YEAR INSERVICE INSPECTION INTERVAL
REQUEST FOR RELIEF, 1-ISI-15

WCAP-14572, TABLE 4.1-1

Table 4.1-1
EXAMINATION CATEGORY R-A, RISK-INFORMED PIPING EXAMINATIONS

Item No.	Parts Examined	Examination Requirement/ Fig. No. ^{1a,b}	Examination Method	Acceptance Standard ^{1a}	Extent ² and Frequency		Deferral of Examination to End of Interval
					1st Interval	Successive ³ Intervals	
R1.10	High Safety-Significant Piping Structural Elements						
R1.11	Elements Subject to Thermal Fatigue	IWB-2500-8(c) ¹ IWB-2500-9,10,11 IWC-2500-7(a) ¹	Volumetric	IWB-3514	Element ^{2d}	Same as 1st	Not Permissible
R1.12	Elements Subject to High Cycle Mechanical Fatigue	IWB-2500-8(c) ¹ IWB-2500-9,10,11 IWC-2500-7(a) ¹	Visual, VT-2 ¹¹	IWB-3142	Each Refueling	Same as 1st	Not Permissible
R1.13	Elements Subject to Corrosive, Erosive, or Cavitation Wastage	Note 8	Volumetric ² (for Internal Wastage) or Surface (for External Wastage)	IWB-3514 Note 8	Element ² Element ²	Same as 1st	Not Permissible
R1.14	Elements Subject to Crevice Corrosion Cracking	Note 7	Volumetric	IWB-3514	Element ²	Same as 1st	Not Permissible
R1.15	Elements Subject to Primary Water Stress Corrosion Cracking (PWSCC) ⁴	Note 7	Visual, VT-2 ¹¹	IWB-3142	Each Refueling	Same as 1st	Not Permissible
R1.16	Elements Subject to Intergranular Stress Corrosion Cracking (IGSCC)	IWB-2500-8(c) IWB-2500-9,10,11	Volumetric	IWB-3514	Element ²	Same as 1st	Not Permissible
R1.17	Elements Subject to Microbiologically Influenced Corrosion (MIC)	IWB-2500-8(c) IWB-2500-9,10,11	Visual, VT-3 Internal Surfaces or Volumetric ²	Note 8	Element ²	Same as 1st	Not Permissible
R1.18	Elements Subject to Flow Accelerated Corrosion (FAC)	Note 9	Note 9	Note 9	Note 9	Note 9	Note 9

E2A2-1

Table 4.1-1 (cont.)
EXAMINATION CATEGORY R-A, RISK-INFORMED PIPING EXAMINATIONS

Notes:

- (1) The length for the examination volume shall be increased to include 1/2 in. beyond each side of the base metal thickness transition or counterbore.
- (2) Includes all examination locations identified in accordance with the risk-informed selection process in Section 3.7.
- (3) Includes 100% of the examination location. When the required examination volume or area cannot be examined due to interference by another component or part geometry, limited examinations shall be evaluated by the Expert Panel for acceptability. Areas with acceptable limited examinations, and their bases, shall be documented.
- (4) The examination shall include any longitudinal welds at the location selected for examination in Note 2. The longitudinal weld examination requirements shall be met for both transverse and parallel flaws examination volume defined in Note 2.
- (5) Initially-selected examination locations are to be examined in the same sequence during successive inspection intervals, to the extent practical.
- (6) Applies to mill annealed Alloy 600 nozzle welds and heat affected zone (HAZ) without stress relief.
- (7) The examination volume shall include the volume surrounding the weld, weld heat affected zone, and base metal, where applicable, in the crevice region. Examination should focus on detection of cracks initiating and propagating from the inner surface.
- (8) The examination volume shall include base metal, welds and weld HAZ in the affected regions of carbon and low alloy steel, and the welds and weld HAZ of austenitic steel. Examinations shall verify the minimum wall thickness required. Acceptance criteria for localized thinning is in course of preparation. The examination method and examination region shall be sufficient to characterize the extent of the element degradation.
- (9) In accordance with the Owner's existing FAC program.
- (10) Paragraph and Figure numbers refer to the 1989 Edition.
- (11) VT-2 examinations may be conducted during a system pressure test or a pressure test specific to that component/element.


ENCLOSURE 2
ATTACHMENT 3

WATTS BAR NUCLEAR PLANT
FIRST TEN YEAR INSERVICE INSPECTION INTERVAL

WELD LOCATION ISI DRAWINGS
IWB-2500-8(c)

Fig. IWB-2500-8

1989 SECTION XI — DIVISION 1



(c) NPS 4 or Larger

FIG. IWB-2500-8 SIMILAR AND DISSIMILAR METAL WELDS IN COMPONENTS AND PIPING (CONT'D)

ENCLOSURE 2
ATTACHMENT 4

WATTS BAR NUCLEAR PLANT
FIRST TEN YEAR INSERVICE INSPECTION INTERVAL

EXAMINATION DATA REPORTS
SIF-D086-02 - Report R0899
RHRF-D054-09 - Report R0907

TENNESSEE VALLEY AUTHORITY		EXAMINATION SUMMARY AND RESOLUTION SHEET		REPORT NUMBER: R0899	
PROJECT: WBN UNIT: 1 CYCLE 05			COMPONENT ID: SIF-D086-02		
EXAMINATION METHOD			SYSTEM: SIS		ISI DWG NO: ISI-0375-C-16
MT <input type="checkbox"/>	PT <input type="checkbox"/>	UT <input checked="" type="checkbox"/>	VT <input type="checkbox"/>	CONFIGURATION:	
PROCEDURE: N-UT-64		REV 6	TC: N/A	PC, PIPE TO PC, VLV	
EXAMINER: <i>Kenneth R. Smith</i>		EXAMINER: N/A	EXAMINER: N/A	EXAMINER: N/A	
LEVEL: II		LEVEL: N/A	LEVEL: N/A	LEVEL: N/A	
<p>Total coverage calculated to be approximately 50 %</p> <p><i>This report contains the manual ultrasonic examination data associated with weld # SIF-D086-02, A 3", SS, pipe to valve configuration.</i></p> <p><i>0.25", 2.25 Mhz, 45 & 70 degree shear wave transducers were used.</i></p> <p><i>Limited examination volume coverage was achieved due to configuration, see attached sketch.</i></p> <p><i>No recordable indications were detected.</i></p>					
RESOLUTION BY: <i>Kenneth R. Smith</i>		REVIEWED BY: <i>[Signature]</i>		ANII: <i>B. Earnigh</i>	
LEVEL II DATE: 9-23-03		LEVEL: II DATE: 9/23/03		DATE: 10/3/03	
				Page: 1 OF 5	

TENNESSEE VALLEY
AUTHORITY


DIGITAL ULTRASONIC
CALIBRATION
DATA SHEET

REPORT NUMBER

R0899

PROJECT WBN UNIT/CYCLE 11 05
 PROCEDURE: N-UT-64 REV: 6 TC: 1/1
 TRANSDUCER
 MANUFACTURER KBA
 MODEL: COMP-G S/N 00Y7FF
 SIZE: .25" FREQ: 2.25 MHz
 SHAPE: Round # ELEMENTS: 1 # CONS: 0
 CABLE TYPE RG-174 LENGTH: 6'
 MODE: SHEAR LONG RL

CALIBRATION DATE: 9-23-03
 CALIBRATION BLOCK NO. WB-11 TEMP: 78°F
 SIMULATOR BLOCK: Rompas
 THERMOMETER S/N: 558270 DUE DATE: 12-9-03
 COUPLANT: Ultragel II BATCH: 01225
 ANGLE VERIFICATION
 BLOCK TYPE: Rompas S/N: 789631
 NOMINAL ANGLE: 45° ACTUAL ANGLE 44°
 INSTRUMENT
 MANUFACTURER: Krautkramer DUE DATE 5-27-04
 MODEL NO.: USN-52L S/N: E30217



INSTRUMENT SETTINGS

REFLECTOR		REFERENCE SENSITIVITY	MEMORY NUMBER
SCAN DIRECT.	NTC SDH		
AXIAL	<input checked="" type="checkbox"/>	29 dB	40
CIRC.	<input checked="" type="checkbox"/>	41 dB	40
FREQ:	<u>2.0-8.0 MHz</u>	REJECT: = <u>0 %</u>	
ANGLE:	<u>44 deg</u>	DAMPING: <u>1000</u> ohms	
DELAY:	<u>-0.234 msec</u>	PULSER: <u>SINGLE</u> *	
ZERO:	<u>4.673 msec</u>		
VELOCITY	<u>0.1233 msec</u>	PRR/PRF: <u>HIGH</u>	
RANGE:	<u>1.50 inches</u>	TOF: <u>PEAK</u>	
DISP. MODE: <u>FULL WAV</u>		POWER: <u>BATTERY</u>	

REF. REFLECTOR: Rompas SDH GAIN: 35 dB
 AMPLITUDE: 30 % METAL PATH: 1.041
 VERIFICATION TIMES | 1) 21:30 | 2) N/A | 3) N/A | 4) N/A | 5) N/A | 6) N/A | 7) N/A | 8) N/A | 9) N/A

CALIBRATION TIMES
 INITIAL TIME: 20:45 FINAL TIME: 23:25

*PDI QUALIFIED INSTRUMENT SETTINGS:
 VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK

VERTICAL	SIGNAL 1									
		100	90	80	70	60	50	40	30	20
ATTENUATOR	SIGNAL 2									
		50	45	40	35	30	25	20	15	10
	GAIN	SET	-6 dB	-12dB	SET	+12	SET	+6		
	AMP	80%	32 TO 48	16 TO 24	20%	64 TO 96	40%	64 TO 96		
			40	20		80		80		

COMMENTS	WELD / ITEMS EXAMINED
<u>Complete exam from pipe side only due to configuration, NRI</u>	<u>SIF-D086-02</u>

EXAMINER: Kenneth R. Smith LVL: II ANII: B. Earnigh
 EXAMINED: N/A DATE: 10/3/03
 REVIEWER: [Signature] LVL: III DATE: 9/24/03 PAGE 2 OF 5

TENNESSEE VALLEY
AUTHORITY


DIGITAL ULTRASONIC
CALIBRATION
DATA SHEET

REPORT NUMBER

R0899

PROJECT WBN UNIT/CYCLE 11 05
 PROCEDURE: N-UT-64 REV: 6 TC: N/A
 TRANSDUCER
 MANUFACTURER KBA
 MODEL: COMP-G S/N 00Y7FF
 SIZE: .25" FREQ: 2.25 MHz
 SHAPE: Round # ELEMENTS: 1 # CONS: 0
 CABLE TYPE RG-174 LENGTH: 6'
 MODE: SHEAR LONG RL

CALIBRATION DATE: 9-23-03
 CALIBRATION BLOCK NO. WB-11 TEMP: 78°F
 SIMULATOR BLOCK: Rompas
 THERMOMETER S/N: 558270 DUE DATE: 12-9-03
 COUPLANT: Ultragel II BATCH: 10225
 ANGLE VERIFICATION
 BLOCK TYPE: Rompas S/N: 789631
 NOMINAL ANGLE: 70° ACTUAL ANGLE 67°
 INSTRUMENT
 MANUFACTURER: Krautkramer DUE DATE 5-27-04
 MODEL NO.: USN-52L S/N: E30217



INSTRUMENT SETTINGS

REFLECTOR		REFERENCE SENSITIVITY	MEMORY NUMBER
SCAN DIRECT.	NTC SDH		
AXIAL	<input checked="" type="checkbox"/> <input type="checkbox"/>	54 dB	41
CIRC.	<input type="checkbox"/> <input type="checkbox"/>	N/A dB	N/A
FREQ:	<u>2.0-8.0 MHz</u>	REJECT: = <u>0 %</u>	
ANGLE:	<u>67 deg</u>	DAMPING: <u>1000</u> ohms	
DELAY:	<u>-0.328 msec</u>	PULSER: <u>SINGLE</u> *	
ZERO:	<u>7.183 msec</u>		
VELOCITY	<u>0.1234 msec</u>	PRR/PRF: <u>HIGH</u>	
RANGE:	<u>2.00 inches</u>	TOF: <u>PEAK</u>	
DISP. MODE:	<u>FULL WAV</u>	POWER: <u>BATTERY</u>	

REF. REFLECTOR: Rompas SDH GAIN: 42 dB
 AMPLITUDE: 50 % METAL PATH: 0.765
 VERIFICATION TIMES | 1) 21:43 | 2) N/A | 3) N/A | 4) N/A | 5) N/A | 6) N/A | 7) N/A | 8) N/A | 9) N/A

CALIBRATION TIMES
 INITIAL TIME: 21:00 FINAL TIME: 23:20

*PDI QUALIFIED INSTRUMENT SETTINGS:
 VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK

VERTICAL	SIGNAL									
	SIGNAL 1	100	90	80	70	60	50	40	30	20
	SIGNAL 2	50	45	40	35	30	25	20	15	10
ATTENUATOR	GAIN	SET	-6 dB	-12dB	SET	+12	SET	+6		
	AMP	80%	32 TO 48	16 TO 24	20%	64 TO 96	40%	64 TO 96		
			40	20		80		80		

COMMENTS: Complete exam on pipe side only due to configuration, supplement to SIF-D086-02
45 degree for additional coverage and far side interrogation, NRI
 WELD / ITEMS EXAMINED

EXAMINER: Kenneth R. Smith LVL: II ANI: B. Earring
 EXAMINED: N/A DATE: 9/23/03
 REVIEWER: [Signature] LVL: II DATE: 9/23/03 PAGE 3 OF 5

**TENNESSEE VALLEY
AUTHORITY**

**MANUAL ULTRASONIC
PIPING EXAMINATION
DATA SHEET**

REPORT NUMBER
 R0899

PROJECT: WBN UNIT/CYCLE 1105
 SYSTEM: SIS
 WELD I.D.: SIF-D086-02
 CONFIG.: PC,PIPE TO PC,VLV
 FLOW \rightarrow
 PROCEDURE: N-UT-64 REV: 6 TC: N/A
 W_o REFERENCE: WELD CENTER LINE
 L_o REFERENCE: TDC

EXAMINATION DATE 9-23-03
 START TIME: 21:30 END TIME: 21:55
 EXAM SURFACE ID OD
 MATERIAL TYPE: CS SS CSCL CCSS
 SURFACE TEMP. 73 F PYRO NO. 558270

EXAMINATION ANGLE	45 DEG.	70 DEG.
AXIAL SCAN SENSITIVITY	41 dB	48 dB
CIRC. SCAN SENSITIVITY	43 dB	N/A dB

IND NO.	L (in) FROM REF.			AT MAX AMP			MAX AMP % DAC	EXAM NO. 3-14	NOM. ANG.	NRI	INDICATION INFORMATION: TYPE, DAMPING, ETC.
	L1	L Max	L2	W MAX	MP MAX	D MAX					
								3	45	<input checked="" type="checkbox"/>	
								5	45	<input checked="" type="checkbox"/>	
								6	45	<input checked="" type="checkbox"/>	
								3	70	<input checked="" type="checkbox"/>	
										<input type="checkbox"/>	
										<input type="checkbox"/>	

REMARKS/LIMITATIONS
Examination limited to pipe side only due to configuration, no recordable indications were detected.
5 TO 20% NOISE LEVEL MAINTAINED

EXAMINER: Kenneth R. Smith LEVEL: II
 EXAMINER: N/A LEVEL: N/A
 REVIEWED BY: [Signature] LEVEL: III DATE: 9/24/03


ANII: B. Eamigh
 DATE: 10/3/03
 PAGE 4 OF 5

<h1>TVA</h1>	<h2>WALL THICKNESS PROFILE SHEET</h2>	REPORT NO: R0899
--------------	---------------------------------------	----------------------------


PROJECT: <u>WBN</u>	WELD NO: <u>SIF-Do86-02</u>
UNIT: <u>1 / CYCLE 5</u>	SYSTEM: <u>SIS</u>

Record Thickness Measurements As Indicated, Including Weld Width, Edge-To-Edge At 0°

Position	0°	90°	180°	270°
1	0.409			
2	0.391			
3	0.534		N/A	
4	0.624			
5	N/A			



CROWN HEIGHT: <u>FLUSH</u>	DIAMETER: <u>3"</u>
CROWN WIDTH: <u>0.60"</u>	WELD LENGTH: <u>11.10"</u>



EXAMINER: <u>Kenneth R. Smith</u>	REVIEWED BY: <u>Am H H</u>	DATE: <u>10/3/03</u>
LEVEL: <u>II</u>	LEVEL: <u>III</u>	DATE: <u>10/3/03</u>
DATE: <u>9-23-03</u>	DATE: _____	PAGE <u>5</u> OF <u>5</u>

TENNESSEE VALLEY AUTHORITY	EXAMINATION SUMMARY AND RESOLUTION SHEET	REPORT NUMBER: R0907
-------------------------------	--	--------------------------------

PROJECT: <i>WBN UNIT: 1</i> CYCLE <i>05</i>		COMPONENT ID: <i>RHRF-D054-09</i>	
EXAMINATION METHOD		SYSTEM: <i>SIS</i>	ISI DWG NO: <i>CHM-2636-C-07</i>
MT <input type="checkbox"/>	PT <input type="checkbox"/>	UT <input checked="" type="checkbox"/>	VT <input type="checkbox"/>
PROCEDURE: <i>N-UT-64</i>		REV <i>6</i>	TC: <i>N/A</i>
EXAMINER: <i>Kenneth R. Smith</i>		EXAMINER: <i>N/A</i>	EXAMINER: <i>N/A</i>
LEVEL: <i>II</i>		LEVEL: <i>N/A</i>	LEVEL: <i>N/A</i>



Total coverage calculated to be approximately **50** %

This report contains the manual ultrasonic examination data associated with weld # RHRF-D054-09, an 8", SS, valve to pipe configuration.

A 0.375", 1.50 Mhz, 45 degree shear wave transducer and a 2.0 Mhz, 60 degree RL transducer were used.

The examination was performed from the pipe side only due to the configuration.

Root and counterbore geometry was seen 360 degrees with the 45 degree shear below recordable levels. Root geometry (recordable) and counterbore geometry (below recordable) was seen 360 degrees with the 60 degree RL.

RESOLUTION BY: <i>Kenneth R. Smith</i>	REVIEWED BY: <i>[Signature]</i>	ANI: <i>B. Eamigh</i>
LEVEL II DATE: <i>9-24-03</i>	LEVEL: <i>II</i> DATE: <i>9/25/03</i>	DATE: <i>10/3/03</i>
		Page: <u>1</u> OF <u>5</u>

TENNESSEE VALLEY
AUTHORITY

DIGITAL ULTRASONIC
CALIBRATION
DATA SHEET

REPORT NUMBER

 R0907

PROJECT WBN UNIT/CYCLE 11 05
PROCEDURE: N-UT-64 REV: 6 TC: N/A

CALIBRATION DATE: 9-24-03
CALIBRATION BLOCK NO. WB-02 TEMP: 78°F
SIMULATOR BLOCK: Rompas

TRANSDUCER
MANUFACTURER KBA
MODEL: COMP-G S/N 00X3DA 15-03
SIZE: .375" FREQ: 1.5 MHz
SHAPE: Round # ELEMENTS: 1 # CONS: 0
CABLE TYPE RG-174 LENGTH: 6'

THERMOMETER S/N: 558270 DUE DATE: 12-9-03
COUPLANT: Ultragel II BATCH: 01225
ANGLE VERIFICATION


BLOCK TYPE: Rompas S/N: 789631
NOMINAL ANGLE: 45° ACTUAL ANGLE 44°

MODE: SHEAR LONG RL

INSTRUMENT
MANUFACTURER: Krautkramer DUE DATE 5-27-03
MODEL NO.: USN-52L S/N: E30217

DAC

INSTRUMENT SETTINGS



A
M
P
L
I
T
U
D
E

DISPLAY WIDTH 3.00 inches

REFLECTOR		REFERENCE SENSITIVITY	MEMORY NUMBER
SCAN DIRECT.	NTC SDH		
AXIAL	<input checked="" type="checkbox"/>	24 dB	8
CIRC.	<input checked="" type="checkbox"/>	33 dB	8
FREQ:	<u>2.0-8.0 MHz</u>	REJECT: <u>0 %</u>	
ANGLE:	<u>44 deg</u>	DAMPING: <u>1000</u> ohms	
DELAY:	<u>-0.063 msec</u>	PULSER: <u>SINGLE</u> *	
ZERO:	<u>5.786 msec</u>		
VELOCITY	<u>0.1228 msec</u>	PRR/PRF: <u>HIGH</u>	
RANGE:	<u>3.00 inches</u>	TOF: <u>PEAK</u>	
DISP. MODE:	<u>FULL WAVE</u>	POWER: <u>BATTERY</u>	

REF. REFLECTOR: Rompas SDH GAIN: 24 dB
AMPLITUDE: 30 % METAL PATH: 1.027
VERIFICATION TIMES 1) 22:30 2) N/A 3) N/A 4) N/A 5) N/A 6) N/A 7) N/A 8) N/A 9) N/A

CALIBRATION TIMES

INITIAL TIME: 21:05 FINAL TIME: 23:10

*PDI QUALIFIED INSTRUMENT SETTINGS:

VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK

VERTICAL	SIGNAL									
	SIGNAL 1	100	90	80	70	60	50	40	30	20
	SIGNAL 2	50	45	40	35	30	25	20	15	10
ATTENUATOR	GAIN	SET	-6 dB	-12 dB	SET	+12	SET	+6		
	AMP	80%	32 TO 48	16 TO 24	20%	64 TO 96	40%	64 TO 96		
			40	20		80		80		

COMMENTS

WELD / ITEMS EXAMINED

Exam from pipe side only due to configuration, root and counterbore RHRF-D054-09 geometry seen 360 degrees below recordable levels, NRI

EXAMINER: Kenneth R. Smith LVL: II

ANII: B. E. Smith

EXAMINER: N/A LVL: N/A


DATE: 10/3/03

REVIEWER: [Signature] LVL: III DATE: 9/25/03

PAGE 7 OF 5

TENNESSEE VALLEY AUTHORITY	DIGITAL ULTRASONIC CALIBRATION DATA SHEET	REPORT NUMBER <u>R0907</u>
---------------------------------------	--	--------------------------------------

PROJECT <u>WBN</u> UNIT/CYCLE <u>11 05</u> PROCEDURE: <u>N-UT-64</u> REV: <u>6</u> TC: <u>N/A</u>	CALIBRATION DATE: <u>9-24-03</u> CALIBRATION BLOCK NO. <u>WB-02</u> TEMP: <u>78°F</u> SIMULATOR BLOCK: <u>Rompas</u> THERMOMETER S/N: <u>558270</u> DUE DATE: <u>12-9-03</u> COUPLANT: <u>Ultragel II</u> BATCH: <u>01225</u> ANGLE VERIFICATION BLOCK TYPE: <u>Rompas</u> S/N: <u>789631</u> NOMINAL ANGLE: <u>60°</u> ACTUAL ANGLE <u>60°</u>
MANUFACTURER <u>MEGASONICS</u> MODEL: <u>CGD</u> S/N <u>K2827</u> SIZE: <u>0.25x0.5"</u> FREQ: <u>2.0</u> MHz SHAPE: <u>Rectangle</u> # ELEMENTS: <u>2</u> # CONS: <u>0</u> CABLE TYPE <u>RG-174</u> LENGTH: <u>2x6'</u>	INSTRUMENT MANUFACTURER: <u>Krautkramer</u> DUE DATE <u>5-27-03</u> MODEL NO.: <u>USN-52L</u> S/N: <u>E30217</u>



INSTRUMENT SETTINGS			
REFLECTOR		REFERENCE SENSITIVITY	MEMORY NUMBER
SCAN DIRECT.	NTC	SDH	
AXIAL	<input checked="" type="checkbox"/>	<input type="checkbox"/>	65 dB
CIRC.	<input type="checkbox"/>	<input type="checkbox"/>	N/A dB
FREQ: <u>2.0-8.0</u> MHz		REJECT: <u>0</u> %	
ANGLE: <u>60</u> deg		DAMPING: <u>1000</u> ohms	
DELAY: <u>0.00</u> msec		PULSER: <u>DUAL</u> *	
ZERO: <u>6.909</u> msec			
VELOCITY <u>0.2317</u> msec		PRR/PRF: <u>HIGH</u>	
RANGE: <u>3.00</u> inches		TOF: <u>PEAK</u>	
DISP. MODE: <u>FULL WAV</u>		POWER: <u>BATTERY</u>	

REF. REFLECTOR: <u>Rompas SDH</u> GAIN: <u>49</u> dB AMPLITUDE: <u>50</u> % METAL PATH: <u>1.432</u>	CALIBRATION TIMES INITIAL TIME: <u>21:15</u> FINAL TIME: <u>23:08</u>
VERIFICATION TIMES 1) <u>22:00</u> 2) <u>N/A</u> 3) <u>N/A</u> 4) <u>N/A</u> 5) <u>N/A</u> 6) <u>N/A</u> 7) <u>N/A</u> 8) <u>N/A</u> 9) <u>N/A</u>	

***PDI QUALIFIED INSTRUMENT SETTINGS:**
 VERIFY INSTRUMENT SETTINGS AND CALIBRATION SEQUENCE ARE IN ACCORDANCE WITH TABLE 2 OF THE APPLICABLE PDI QUALIFICATION IMPLEMENTATION PROCEDURE!

LINEARITY CHECK										
VERTICAL	SIGNAL 1	100	90	80	70	60	50	40	30	20
		SIGNAL 2	50	45	40	35	30	25	20	15
ATTENUATOR	GAIN	SET	-6 dB	-12dB	SET	+12	SET	+6		
	AMP	80%	32 TO 48	16 TO 24	20%	64 TO 96	40%	64 TO 96		
		40	20	80	80					

COMMENTS <u>Supplement to 45 degree for far side interrogation, recordable root geometry seen 360 degrees, counterbore geometry 360 degrees below recordable levels.</u>	WELD / ITEMS EXAMINED <u>RHRF-D054-09</u>
---	--

EXAMINER: <u>Kenneth P. Smith</u>	LVL: <u>II</u>	ANI: <u>B. Earnigh</u>
EXAMINER: <u>N/A</u>	I.VI.: <u>N/A</u>	DATE: <u>10/3/03</u>
REVIEWER: <u>[Signature]</u>	LVL: <u>[Signature]</u>	DATE: <u>9/26/03</u>
		PAGE <u>3</u> OF <u>5</u>

TENNESSEE VALLEY
AUTHORITY

MANUAL ULTRASONIC
PIPING EXAMINATION
DATA SHEET

REPORT NUMBER

10907

PROJECT: WBN UNIT/CYCLE 1105

SYSTEM: SIS

WELD ID.: RHRF-D054-09

CONFIG.: PC,VLV TO PC,PIPE

FLOW →

PROCEDURE: N-UT-64 REV: 6 TC: N/A

W₀ REFERENCE: WELD CENTER LINE

L₀ REFERENCE: TDC

EXAMINATION DATE 9-24-03

START TIME: 21:50 END TIME: 22:50

EXAM SURFACE ID OD

MATERIAL TYPE: CS SS CSCL CCSS

SURFACE TEMP. 64 F PYRO NO. 558270


EXAMINATION ANGLE 45s DEG. 60RL DEG.

AXIAL SCAN SENSITIVITY 36 dB 59 dB

CIRC. SCAN SENSITIVITY 43 dB N/A dB

IND NO.	L (in) FROM REF.			AT MAX AMP			MAX AMP % DAC	EXAM NO. 3-14	NOM. ANG.	NRI	INDICATION INFORMATION: TYPE, DAMPING, ETC.
	L1	L Max	L2	W MAX	MP MAX	D MAX					
								4	45	<input checked="" type="checkbox"/>	
								5	45	<input checked="" type="checkbox"/>	
								6	45	<input checked="" type="checkbox"/>	
	*	5"ccw	*	1.40"	1.808"	.904"	200	4	60	<input type="checkbox"/>	Root geometry
										<input type="checkbox"/>	
										<input type="checkbox"/>	

T+C @ 270°



REMARKS/LIMITATIONS

Root geometry seen 360 degrees with 60 RL, verified with 0 degree

5 TO 20% NOISE LEVEL MAINTAINED

EXAMINER: Kenneth R. Smith LEVEL: II

ANII: B. Earnigh

EXAMINER: N/A LEVEL: N/A

DATE: 10/3/03

REVIEWED BY: [Signature] LEVEL: III

DATE: 9/25/02

PAGE 4 OF 5

TVA

**WALL THICKNESS
PROFILE SHEET**

REPORT NO:

R0907

PROJECT: WBN


WELD NO: RHRF-D054-09

UNIT: 1 / CYCLE 5


SYSTEM: SIS

Record Thickness Measurements As Indicated, Including Weld Width, Edge-To-Edge At 0°

Position	0°	90°	180°	270°
1				N/A
2				1.258
3		N/A		1.039
4				.820
5				.929



CROWN HEIGHT: FLUSH DIAMETER: 8.0"
 CROWN WIDTH: 1.20" WELD LENGTH: 26.5"



EXAMINER: Kenneth R. Smith
 LEVEL: II
 DATE: 9-24-03

REVIEWED BY: [Signature]
 LEVEL: [Signature] DATE: 9/25/03

DATE: 10/3/03
 PAGE 5 OF 5