

March 30, 2004

LICENSEE: Dominion Nuclear Connecticut, Inc. (DNC)

FACILITY: Millstone Power Station (Millstone)

SUBJECT: TELEPHONE SUMMARY BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION (NRC) STAFF AND DOMINION NUCLEAR CONNECTICUT, INC. REPRESENTATIVES TO DISCUSS THE MILLSTONE POWER STATION, UNITS 2 AND 3 LICENSE RENEWAL APPLICATIONS

On March 8 and 16, 2004, the NRC staff (the staff) and representatives from DNC held telephone conferences (telecon) to discuss the Millstone Unit 2 and Unit 3 License Renewal Applications (LRA) dated January 20, 2004. The telecon related to statements contained in the LRAs. The staff requested clarification of information contained in Section 2 and Appendix C of the LRAs regarding what components are included under the terms level indicators and piping. A list of telephone participants is enclosed.

Scoping Question - level indicators:

The staff requested clarification for the term "level indicators" as used in the tables in Section 2 of the LRAs (i.e. Table 2.3.3-34 Diesel Generator). The submitted license renewal drawings highlight sight glass and level glass as subject to aging management review (AMR); however, these components are not listed in the Section 2 tables. The staff questioned if sight glass and gage glass are included in the term level indicators.

Telecon Discussion:

The applicant informed the staff that the components such as sight glass and level glass fall under the definition of level indicators as used in the LRAs. The staff acknowledged the licensee's use of the term level indicators as used in the LRAs.

Scoping Question - piping and associated fittings:

The staff requested clarification for the term "pipe" as used in the tables in Section 2 of the LRAs (i.e. Table 2.3.3-1 Circulating Water). Appendix C, "Aging Management Review Methodology," of the LRA describes the methodology for performing the AMR of long-lived passive components and structural members. It also describes the process for identifying the in-scope passive components. Section C2.2 states that components such as pipe may have more than one component. It goes on further to state that the "pipe" component group includes piping and all of the associated fittings, since fittings generally are of the same material as the piping and are subject to the same environmental conditions.

The submitted license renewal drawings highlight components such as blind flanges, spectacle flanges, and fill connections as subject to aging management review; however, these components are not listed in the Section 2 tables. The staff questioned what types of components fall under the pipe and associated fittings.

Telecon Discussion:

The applicant informed the staff that the components such as: blind flange, spectacle flange, elbow, fill connection/emergency fill, vent and drain line, threaded plug, reducer, end cap, and access ports such as manway/manholes are included under the component piping and associated fittings when they are of the same material as the piping and subject to the same environmental conditions, and as such will not be uniquely identified in the LRAs. The staff acknowledged the licensee's use of the term pipe and associated fittings as used in the LRAs. The applicant will formally document this clarification in a response to a request for additional information.

DNC has had an opportunity to review and comment on this summary.

*/RA/*

Russell Arrighi, Project Manager  
License Renewal Section A  
License Renewal and Environmental Impacts Program  
Division of Regulatory Improvement Programs  
Office of Nuclear Reactor Regulation

Docket Nos.: 50-336 and 50-423

Enclosure: As stated

cc w/encl: See next page

The submitted license renewal drawings highlight components such as blind flanges, spectacle flanges, and fill connections as subject to aging management review; however, these components are not listed in the Section 2 tables. The staff questioned what types of components fall under the pipe and associated fittings.

Telecon Discussion:

The applicant informed the staff that the components such as: blind flange, spectacle flange, elbow, fill connection/emergency fill, vent and drain line, threaded plug, reducer, end cap, and access ports such as manway/manholes are included under the component piping and associated fittings when they are of the same material as the piping and subject to the same environmental conditions, and as such will not be uniquely identified in the LRAs. The staff acknowledged the licensee's use of the term pipe and associated fittings as used in the LRAs. The applicant will formally document this clarification in a response to a request for additional information.

DNC has had an opportunity to review and comment on this summary.

*/RA/*  
Russell Arrighi, Project Manager  
License Renewal Section A  
License Renewal and Environmental Impacts Program  
Division of Regulatory Improvement Programs  
Office of Nuclear Reactor Regulation

Docket Nos.: 50-336 and 50-423  
Enclosure: As stated  
cc w/encl: See next page

DISTRIBUTION:

Accession No: ML040900525

C:\ORPCheckout\FileNET\ML040900525.wpd

OFFICE	PM:RLEP:DRIP	LA:RLEP:DRIP	SC:RLEP:DRIP
NAME	RArrighi	MJenkins	SLee
DATE	03/29/2004	03/ 29/2004	03/30/2004

OFFICIAL RECORD COPY

DISTRIBUTION: Summary of Telecon with DNC Re: larification of LRAs,Dated: March 30, 2004  
Accession No: ML040900525

**HARD COPY**

RLEP RF

J. Eads

R. Arrighi

**E-MAIL:**

PUBLIC

J. Craig

D. Matthews

F. Gillespie

C. Grimes

RidsNrrDe

E. Imbro

G. Bagchi

K. Manoly

W. Bateman

J. Calvo

R. Jenkins

P. Shemanski

J. Fair

S. Black

B. Boger

D. Thatcher

R. Pettis

G. Galletti

C. Li

M. Itzkowitz

R. Weisman

M. Mayfield

A. Murphy

S. Smith (srs3)

S. Duraiswamy

Y. L. (Renee) Li

RLEP Staff

-----

V. Nerses

C. Marco

C. O'Daniell

**LIST OF PARTICIPANTS FOR TELEPHONE CONFERENCE  
TO DISCUSS THE MILLSTONE POWER STATION, UNITS 2 AND 3  
LICENSE RENEWAL APPLICATION  
MARCH 8 AND 16, 2004**

Telecon Participants

<u>PARTICIPANTS</u>	<u>AFFILIATION</u>
Russell Arrighi	NRC
Chang Li	NRC
David Shum	NRC
Bill Corbin	DNC
Bill Watson	DNC
Paul Aitken	DNC
Mark Hotchkiss	DNC
Ben Rodill	DNC
Dan Prelewicz	ISL

Millstone Power Station, Units 2 and 3

cc:

Lillian M. Cuoco, Esquire  
Senior Counsel  
Dominion Resources Services, Inc.  
Rope Ferry Road  
Waterford, CT 06385

Edward L. Wilds, Jr., Ph.D.  
Director, Division of Radiation  
Department of Environmental Protection  
79 Elm Street  
Hartford, CT 06106-5127

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406

First Selectman  
Town of Waterford  
15 Rope Ferry Road  
Waterford, CT 06385

Mr. P. J. Parulis  
Manager - Nuclear Oversight  
Dominion Nuclear Connecticut, Inc.  
Rope Ferry Road  
Waterford, CT 06385

Mr. W. R. Matthews  
Senior Vice President - Nuclear Operations  
Dominion Nuclear Connecticut, Inc.  
Rope Ferry Road  
Waterford, CT 06385

Mr. John Markowicz  
Co-Chair  
Nuclear Energy Advisory Council  
9 Susan Terrace  
Waterford, CT 06385

Mr. Evan W. Woollacott  
Co-Chair  
Nuclear Energy Advisory Council  
128 Terry's Plain Road  
Simsbury, CT 06070

Senior Resident Inspector  
Millstone Power Station  
c/o U.S. Nuclear Regulatory Commission  
P. O. Box 513  
Niantic, CT 06357

Mr. G. D. Hicks  
Director - Nuclear Station Safety  
and Licensing  
Dominion Nuclear Connecticut, Inc.  
Rope Ferry Road  
Waterford, CT 06385

Ms. Nancy Burton  
147 Cross Highway  
Redding Ridge, CT 00870

Mr. William D. Meinert  
Nuclear Engineer  
Massachusetts Municipal Wholesale  
Electric Company  
Moody Street  
P.O. Box 426  
Ludlow, MA 01056

Mr. J. Alan Price  
Site Vice President  
Dominion Nuclear Connecticut, Inc.  
Rope Ferry Road  
Waterford, CT 06385

Mr. Chris L. Funderburk  
Director, Nuclear Licensing and  
Operations Support  
Dominion Resources Services, Inc.  
Innsbrook Technical Center  
5000 Dominion Boulevard  
Glen Allen, VA 23060-6711

Mr. David W. Dodson  
Licensing Supervisor  
Dominion Nuclear Connecticut, Inc.  
Rope Ferry Road  
Waterford, CT 06385

Millstone Power Station, Units 2 and 3

- 2 -

cc:

David R. Lewis  
Shaw Pittman, LLC  
2300 N. Street N.W.  
Washington, DC 20037

Mr. S. E. Scace  
Assistant to the Site Vice President  
Dominion Nuclear Connecticut, Inc.  
Rope Ferry Road  
Waterford, CT 06385

Mr. M. J. Wilson  
Manager - Nuclear Training  
Dominion Nuclear Connecticut, Inc.  
Rope Ferry Road  
Waterford, CT 06385

Mr. A. J. Jordan, Jr.  
Director - Nuclear Engineering  
Dominion Nuclear Connecticut, Inc.  
Rope Ferry Road  
Waterford, CT 06385

Mr. S. P. Sarver  
Director - Nuclear Station Operations  
and Maintenance  
Dominion Nuclear Connecticut, Inc.  
Rope Ferry Road  
Waterford, CT 06385

Mr. Charles Brinkman, Director  
Washington Operations Nuclear Services  
Westinghouse Electric Company  
12300 Twinbrook Pkwy, Suite 330  
Rockville, MD 20852

Mr. William D. Corbin  
Director - Nuclear Projects Department  
Innsbrook Technical Center  
5000 Dominion Boulevard  
Glen Allen, VA 23060-6711

Mr. William R. Watson, Jr.  
Supervisor - License Renewal Project  
Building 475/5  
Millstone Power Station  
Rope Ferry Road  
Waterford, CT 06385

Judy Liskov, Assistant Director  
Waterford Public Library  
49 Rope Ferry Road  
Waterford, Connecticut 06385-2806

Mildred Hodge, Director  
Three Rivers Community College  
Thames River Campus  
574 New London Turnpike  
Norwich, Connecticut 06360

Mr. David A. Christian  
Senior Vice President and Chief Nuclear  
Officer  
Dominion Nuclear Connecticut, Inc.  
Innsbrook Technical Center  
5000 Dominion Boulevard  
Glen Allen, VA 23060-6711